



Department of Energy

Condition Assessment Survey **(CAS)** Program

Deficiency Standards &
Inspections Methods Manual

Prepared by:

Parsons Brinckerhoff Facilities Services, Inc.

for

The United States Department of Energy
Office of Organization, Resources and Facilities Management
1000 Independence Avenue, **S.W.**
Washington, DC 20585

VOLUME 9: 0.09 ELECTRICAL
BOOK TWO



Printed with soy ink on recycled paper

TABLE OF CONTENTS

BOOK ONE

INTRODUCTION i-3
SECTION 1 - GENERAL INFORMATION			
ASSET DETERMINANT FACTOR/CAS REPAIR CODES/CAS COST FACTORS			1.1-1
GUIDE SHEET TOOL & MATERIAL LISTING			1.2-1
TESTING METHODS			1.3-1
INSPECTION FREQUENCY			1.4-1
STANDARD SYSTEM DESIGN LIFE TABLES			1.5-1
SYSTEM WORK BREAKDOWN STRUCTURE			1.6-1
SECTION 2 - DEFICIENCY STANDARDS			
System Assembly/Component	WBS#		Page #
SERVICE & DISTRIBUTION			
Service Entrance	0.09.01.01		2.1.1-1
Low Voltage Distribution	0.09.01.02		2.1.2-1
Medium Voltage Distribution	0.09.01.03		2.1.3-1
LIGHTING			
Luminaires	0.09.02.01		2.2.1-1
SPECIAL SYSTEMS			
Cable Tray	0.09.03.01		2.3.1-1
Communication Circuits	0.09.03.02		2.3.2- 1
Control Units	0.09.03.03		2.3.3- 1
Data Processing Electrical Equipment	0.09.03.04		2.3.4- 1
Generators, Standby/Emergency	0.09.03.05		2.3.5- 1
Health Care Facilities Electrical Equipment	0.09.03.06		2.3.6- 1
Heating, Baseboard Radiation	0.09.03.07		2.3.7- 1
Lightning Protection & Surge Suppression	0.09.03.08		2.3.8- 1
Petroleum Dispensing Facilities Electrical Equipment	0.09.03.09		2.3.9-1
Signal Circuits	0.09.03.10		2.3.10- 1
Uninterruptible Power Supplies	0.09.03.11		2.3.11-1

BOOK TWO**SECTION 3 - INSPECTION METHODS**

Guide Sheet .Cross Reference Tables			
SERVICE & DISTRIBUTION			
Service Entrance	0.09.01.01		3.1-1
Low Voltage Distribution	0.09.01.02		3.1-3
Medium Voltage Distribution	0.09.01.03		3.1-5
LIGHTING	0.09.02		3.1-7
SPECIAL SYSTEMS	0.09.03		3.1-9

 TABLE OF CONTENTS

SECTION 3 - **INSPECTION** METHODS (Continued)**Guide Sheets** - Standard

General Components	3.2-3
Service Entrance Specific	3.2-33
Low Voltage Distribution Specific	3.2-35
Medium Voltage Distribution Specific	3.2-41
Lighting Specific	3.2-43
Special Systems Specific	3.2-47

Guide Shoots - Non-Standard

General Components	3.2-83
Service Entrance Specific	3.2-115
Low Voltage Distribution Specific	3.2-117
Medium Voltage Distribution Specific	3.2-123
Lighting Specific	3.2-125
Special Systems Specific	3.2-129

Data Collection Methods

Sample Data Collection Screens	3.3-1
--------------------------------------	-------

SECTION 4 . REFERENCES

FEDERAL SPECIFICATIONS	4.1-1
NATIONAL STANDARDS	4.2-1
INDUSTRY PUBLICATIONS	4.3-1
OTHER RELATED REFERENCES	4.4-1

APPENDICES

APPENDIX A

Abbreviations	A-1
---------------------	-----

APPENDIX B

Glossary	B-1
----------------	-----

APPENDIX C

Technical Bulletins/Updates/Advisories	C-1
--	-----

APPENDIX D

Revisions Summary	D-1
-------------------------	-----

 GUIDE SHEET CROSS REFERENCE TABLES

GUIDE SHEETS

The following Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general inspection of the Service Entrance System.

Assembly/Component	Control Number
STANDARD	
Service Entrance Assembly.....	GSS 0.09.01 .01
Busways.....	GSS 0.09.01.02.01
Conductors & Fittings.....	GSS 0.09.01.02.02
Disconnects	GSS 0.09.01.02.03
Metering	GSS 0.09.01.02.04
Raceway & Fittings	GSS 0.09.01.02.08
NON-STANDARD	
Service Entrance AssemblyGSN S 0.09.01 .01
Busway	GSNS 0.09.01.02.01
Conductors & Fittings.....	GSNS 0.09.01.02.02
Disconnects	GSNS 0.09.01.02.03
Metering	GSNS 0.09.01.02.04
Raceway & Fittinas	GSNS 0.09.01.02.08

 GUIDE SHEET CROSS REFERENCE TABLES

GUIDE SHEETS

The following Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general inspection of the Low Voltage **Distribution** System.

Assembly/Component	Control Number
STANDARD	
Busway	GSS 0.09.01.02.01
Conductors & Fittings..	GSS 0.09.01.02.02
Disconnects	GSS 0.09.01.02.03
Metering	GSS 0.09.01.02.04
Motors..	GSS 0.09.01.02.05
Motor Control Center..	GSS 0.09.01.02.06
Panelboard Assembly.,	GSS 0.09.01.02.07
Raceway & Fittings	GSS 0.09.01.02.08
Switchboard	GSS 0.09.01.02.09
Transfer Switches..	GSS 0.09.01.02.10
Transformers	GSS 0.09.01.02.11
NON-STANDARD	
Busway	GSNS 0.09.01.02.01
Conductors & Fittings..	GSNS 0.09.01.02.02
Disconnects	GSNS 0.09.01.02.03
Metering	GSNS 0.09.01.02.04
Motors	GSNS 0.09.01.02.05
Motor Control Center..	GSNS 0.09.01.02.06
Panelboard Assembly..	GSNS 0.09.01.02.07
Raceway & Fittings	GSNS 0.09.01.02.08
Switchboard	GSNS 0.09.01.02.09
Transfer Switches..	GSNS 0.09.01.02.10
Transformers	GSNS 0.09.01.02.11

GUIDE SHEET CROSS REFERENCE TABLES

GUIDE SHEETS

The following Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general inspection of the Medium Voltage Distribution System.

Assembly/Component	Control Number
STANDARD	
Busway	GSS 0.09.01.02.01
Conductors & Fittings..	GSS 0.09.01.02.02
Disconnects	GSS 0.09.01.02.03
Metering	GSS 0.09.01.02.04
Motors	GSS 0.09.01.02.05
Motor Control Center..	GSS 0.09.01.02.06
Raceway & Fittings	GSS 0.09.01.02.08
Switchboard	GSS 0.09.01.02.09
Transfer Switches..	GSS 0.09.01.02.10
Transformers..	GSS 0.09.01.02.11
NON-STANDARD	
Busway	GSNS 0.09.01.02.01
Conductors & Fittings..	GSNS 0.09.01.02.02
Disconnects	GSNS 0.09.01.02.03
Metering	GSNS 0.09.01.02.04
Motors	GSNS 0.09.01.02.05
Motor Control Center	GSNS 0.09.01.02.06
Raceway & Fittings	GSNS 0.09.01.02.08
Switchboard	GSNS 0.09.01.02.09
Transfer Switches..	GSNS 0.09.01.02.10
Transformers..	GSNS 0.09.01.02.11

GUIDE SHEET CROSS REFERENCE TABLES

GUIDE SHEETS

The following Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general inspection of the Lighting System.

Assembly/Component	Control Number
STANDARD	
Conductors & Fittings	GSS 0.09.01.02.02
Raceway & Fittings	GSS 0.09.01.02.08
Luminaire	GSS 0.09.02.01
NON-STANDARD	
Conductors & Fittings	GSNS 0.09.01.02.02
Raceway & Fittings	GSNS 0.09.01.02.08
Luminaire	GSNS 0.09.02.01

GUIDE SHEET CROSS REFERENCE TABLES

GUIDE SHEETS

The following Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general inspection of Special Systems.

Assembly/Component	Control Number
STANDARD	
Cable Tray.....	GSS 0.09.03.01
Communication Circuits	GSS 0.09.03.02
Control Units	GSS 0.09.03.03
Data Processing Electrical Equipment.....	GSS 0.09.03.04
Generators, Standby/Emergency..	GSS 0.09.03.05
Health Care Facilities Electrical Equipment	GSS 0.09.03.06
Heating, Baseboard Radiation.....	GSS 0.09.03.07
Lightning Protection & Surge Suppression.....	GSS 0.09.03.08
Petroleum Dispensing Facilities Electrical Equip.....	GSS 0.09.03.09
Signal Circuits	GSS 0.09.03.10
Uninterruptible Power Supplies.....	GSS 0.09.03.11
NON-STANDARD	
Cable Tray.....	GSNS 0.09.03.01
Communication Circuits	GSNS 0.09.03.02
Control Units	GSNS 0.09.03.03
Data Processing Electrical Equipment.....	GSNS 0.09.03.04
Generators, Standby/Emergency..	GSNS 0.09.03.05
Health Care Facilities Electrical Equipment	GSNS 0.09.03.06
Heating, Baseboard Radiation.....	GSNS 0.09.03.07
Lightning Protection & Surge Suppression.....	GSNS 0.09.03.08
Petroleum Dispensing Facilities Electrical Equip.....	GSNS 0.09.03.09
Signal Circuits	GSNS 0.09.03.10
Uninterruptible Power Supplies.....	GSNS 0.09.03.11

GUIDE SHEET CROSS REFERENCE TABLES

END OF SUBSECTION

INSPECTION METHODS . STANDARD

GUIDE SHEETS

Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general component inspection. Sheets have been developed for each major assembly/component as shown in TABLE ONE below:

TABLE ONE

<u>Assembly/Component</u>	<u>Control Number</u>	<u>Page #</u>
STANDARD		
<u>General Use Guide Sheets</u>		
Busway	GSS 0.09.01.02.01.....	3.2-3
Conductors & Fittings..	GSS 0.09.01.02.02..	3.2-7
Disconnects	GSS 0.09.01.02.03..	3.2-9
Metering..	GSS 0.09.01.02.04.....	3.2-11
Motors..	GSS 0.09.01.02.05.....	3.2-13
Motor Control Center..	GSS 0.09.01.02.06.....	3.2-15
Raceway & Fittings..	GSS 0.09.01.02.08.....	3.2-19
Switchboard Assembly..	GSS 0.09.01.02.09.....	3.2-21
Transfer Switches..	GSS 0.09.01.02.10..	3.2-25
Transformers..	GSS 0.09.01.02.11.....	3.2-29
<u>Service Entrance Specific</u>		
Service Entrance Assembly	GSS 0.09.01 .01.....	3.2-33
<u>Low Voltage Distribution System Specific</u>		
Low Voltage Distribution System Assembly...	GSS 0.09.01.02.....	3.2-35
Panelboard Assembly..	GSS 0.09.01.02.07..	3.2-37
<u>Medium Voltage Distribution System Specific</u>		
Medium Voltage Distribution System Ass'y.....	GSS 0.09.01.03..	3.2-41
<u>Lighting System Specific</u>		
Luminaires..	GSS 0.09.02.01.....	3.2-43
<u>Special Systems Specific</u>		
Cable Tray	GSS 0.09.03.01.....	3.2-47
Communication Circuits	GSS 0.09.03.02..	3.2-49
Control Units..	GSS 0.09.03.03..	3.2-51
Data Processing Electrical Equipment..	GSS 0.09.03.04..	3.2-55
Generators, Standby/Emergency	GSS 0.09.03.05..	3.2-59
Health Care Facilities Electrical Equipment.. ...	GSS 0.09.03.06..	3.2-63
Heating, Baseboard Radiation	GSS 0.09.03.07..	3.2-67
Lightning Protection & Surge Suppression.. ...	GSS 0.09.03.08..	3.2-69
Petroleum Dispensing Facilities Elec. Equip ...	GSS 0.09.03.09..	3.2-71
Signal Circuits	GSS 0.09.03.10..	3.2-75
Uninterruptible Power Supplies	GSS 0.09.03.11.....	3.2-77

INSPECTION METHODS • STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** BUSWAY**CONTROL NUMBER:** GSS 0.09.01.02.01**APPLICATION**

This guide applies to busway used in low and medium Voltage distribution system assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low and medium Voltage busway systems provide an input to the analysis of functional and physical deficiencies of an electrical distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of a busway system are not addressed.

PHYSICAL DEFICIENCIES**1.0 BUSWAY ENCLOSURE**

- 1.1 Inappropriate for application
- 1.2 Not adequately secured to mounting surface
- 1.3 Not secured within 3 feet of end of run or enclosure
- 1.4 Bent, crushed, ruptured
- 1.5 Unused openings not covered or plugged
- 1.6 No bushing or equivalent protection
- 1.7 Supported by other raceway
- 1.8 Exterior rusted, corroded, or other physical damage
- 1.9 Interior rusted, corroded, or other physical damage
- 1.10 Hanger rusted, corroded, or other physical damage
- 1.11 Hanger not adequately secured to structure
- 1.12 Not grounded properly
- 1.13 Ventilation not adequate
- 1.14 Ventilation perforations covered, clogged, or plugged
- 1.15 Not clean and moisture-free

2.0 FITTING

- 2.1 Missing, broken, cracked, or other damage
- 2.2 Insert broken, cracked, missing, or other damage
- 2.3 Improper fitting for application
- 2.4 Unused openings not covered or plugged
- 2.5 Elbow improperly installed and connected
- 2.6 Tee improperly installed and connected
- 2.7 Crossover improperly installed and connected
- 2.8 Cable-tap boxes improperly installed and connected
- 2.9 Bus plugs improperly installed, connected, and/or inadequate for application
- 2.10 Expansion joint improperly placed and installed
- 2.11 Switchboard flange connection improperly installed and connected

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: BUSWAY (Continued)

CONTROL NUMBER: GSS 0.09.01.02.01

PHYSICAL DEFICIENCIES**3.0 CONDUCTORS & FITTINGS**

Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.

4.0 METERING

- 4.1 Calibration standard not established
- 4.2 Device broken or other physical defect
- 4.3 Tampering of device or circuit
- 4.4 Device inadequately sized
- 4.5 Device inoperative

5.0 DISCONNECT

- 5.1 Blades bent or not aligned
- 5.2 Handle broken, bent, or other physical deformity
- 5.3 Inadequate size
- 5.4 Blade clip bent, malaligned, or other physical deformity
- 5.5 Clips pitted, burned, or discolored
- 5.6 Blades pitted, burned, or discolored
- 5.7 Improperly wired
- 5.8 Not accessible
- 5.9 Improper application
- 5.10 Improperly sized
- 5.11 No engineering study to support adjustable settings
- 5.12 High conductor, circuit breaker lug temperature as measured in thermographic test

6.0 FUSE UNIT

- 6.1 Improperly sized
- 6.2 Improper fuse type used
- 6.3 Fuse clips bent, malaligned, discolored, or other physical damage
- 6.4 Poor fuse to clip contact as measured using thermographic test

7.0 INSTALLATION

- 7.1 Missing, broken, cracked, or other damage
- 7.2 Insert broken, cracked, missing, or other damage
- 7.3 Improper fitting for application
- 7.4 Unused openings not covered or plugged
- 7.5 Elbow improperly installed and connected
- 7.6 Tee improperly installed and connected
- 7.7 Cross improperly installed and connected
- 7.0 Wye improperly installed and connected
- 7.9 Reducer improperly installed and connected
- 7.10 Divider improperly installed and connected
- 7.11 Drop out improperly installed and connected
- 7.12 End cap improperly installed and connected
- 7.13 Covers inappropriate for application
- 7.14 Covers improperly installed
- 7.15 Expansion joint improperly placed and installed
- 7.16 Panel connector improperly installed and connected

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: BUSWAY (Continued)

CONTROL NUMBER: GSS 0.09.01.02.01

PHYSICAL DEFICIENCIES**8.0 CONTACTOR**

- 8.1 Control circuits improperly connected
- 8.2 Indicator lamps inoperative
- 8.3 indicator lens missing, cracked, or broken
- 8.4 Noisy
- 8.5 Missing, loose, broken, or corroded hardware
- 8.6 Rheostat ventilation impeded
- 8.7 Plugging relays dirty or other contamination
- 8.8 Pushbuttons not labeled
- 8.9 Improper size
- 8.10 Thermal trip device wrong size
- 8.11 No engineering study to support thermal trip device rating
- 8.12 Coil discolored, burned, or other signs of high temperature

9.0 BUSBAR

- 9.1 Dirty or other contamination
- 9.2 Loose joints as measured using thermographic test
- 9.3 Current limiting busway not used as required

10.0 BUSHING/INSULATOR

- 10.1 Tracked or carbonized
- 10.2 Missing, cracked, chipped, or other damage
- 10.3 Oil leak
- 10.4 Dirty, oily, greasy, or other surface contamination
- 10.5 Not adequately secured to mounting surface

11.0 HEATER

- 11.1 Inadequate temperature in device enclosure
- 11.2 Excessive temperature in device enclosure
- 11.3 Not adequately secured to mounting surface
- 11.4 Improper conductors from source

12.0 CONTROL WIRING

- 12.1 Inappropriate for application
- 12.2 Bundled and trained inappropriately
- 12.3 Terminal boards improperly installed
- 12.4 Insulation charred, burned, or discolored
- 12.5 Splices improperly insulated
- 12.6 Unauthorized splice
- 12.7 Insulation improperly removed from conductor
- 12.8 Bimetallic connectors not used as required

13.0 MARKING

- 13.1 Illegible
- 13.2 Damaged or missing dataplate

14.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** BUSWAY (Continued)**CONTROL NUMBER:** GSS 0.09.01.02.01**TOOLS & MATERIALS**

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ▪ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: CONDUCTORS & FITTINGS****CONTROL NUMBER: GSS 0.09.01.02.02****APPLICATION**

This guide applies to conductors and fittings used in low and medium Voltage distribution system assemblies. This guide does not apply to control wiring used in devices such as motor control centers or metering.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of conductors and fittings used in low and medium Voltage distribution system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of raceway and fittings are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 1.1 Inappropriate for application
 - 1.2 Insulation burned, charred, or other damage
 - 1.3 Splices improperly insulated
 - 1.4 Unauthorized splice
 - 1.5 Not properly connected to device
 - 1.6 Insulation improperly removed from conductor
 - 1.7 Bimetallic connectors not used as required
 - 1.8 Not properly supported in vertical run
 - 1.9 Not properly bundled or trained
- 2.0 FITTING
 - 2.1 Missing, broken, cracked, or other damage
 - 2.2 Insert broken, cracked, missing, or other damage
 - 2.3 Improper fitting for application
 - 2.4 Unused openings not covered or plugged
- 3.0 MARKING
 - 3.1 Illegible
 - 3.2 Damaged or missing dataplate

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ▪ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** DISCONNECTS**CONTROL NUMBER:** GSS 0.09.01 .02.03**APPLICATION**

This guide covers those disconnects (switches with or without fuse blocks and isolating switches) and circuit breakers employed as disconnects that are normally used in low and medium Voltage distribution systems as stand alone devices; that is, the device is not part of some larger assembly. A separate guide exists for transfer switches.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks,

INSPECTION ACTIONS

Condition assessment and evaluation of circuit breakers and disconnects provides input to an analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with disconnects are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 2.0 ENCLOSURE
 - 2.1 Not adequate for application
 - 2.2 Corroded, rusted, dented, or other physical damage
 - 2.3 Not secured to mounting surface
 - 2.4 Unused openings not covered or plugged
 - 2.5 Not grounded properly
 - 2.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 2.7 Not accessible
 - 2.8 Vent defective/nonoperative
 - 2.9 Oil leak
 - 2.10 No curbing or berm for oil containment
 - 2.11 Not clean and moisture-free
- 3.0 DISCONNECT
 - 3.1 Blades bent or not aligned
 - 3.2 Handle broken, bent, or other physical deformity
 - 3.3 Inadequate size
 - 3.4 Blade clip bent, malaligned, or other physical deformity
 - 3.5 Clips pitted, burned, or discolored
 - 3.6 Blades pitted, burned, or discolored
 - 3.7 Improperly wired
 - 3.8 Not accessible

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: DISCONNECTS (Continued)

CONTROL NUMBER: GSS 0.09.01.02.03

PHYSICAL DEFICIENCIES

- 3.0 DISCONNECT
 - 3.9 Improper application
 - 3.10 Improperly sized
 - 3.11 No engineering study to support adjustable settings
 - 3.12 High conductor, circuit breaker lug temperature as measured using thermographic test
- 4.0 BUSHING/INSULATOR
 - 4.1 Tracked or carbonized
 - 4.2 Missing, cracked, chipped, or other damage
 - 4.3 Oil leak
 - 4.4 Dirty, oily, greasy, or other surface contamination
 - 4.5 Not adequately secured to mounting surface
- 5.0 FUSE UNIT
 - 5.1 Improperly sized
 - 5.2 Improper fuse type used
 - 5.3 Fuse clips bent, malaligned, discolored, or other physical damage
 - 5.4 Poor fuse to clip contact as measured using thermographic test
- 6.0 PRESSURE RELIEF
 - 6.1 High internal pressure
 - 6.2 No internal pressure
- 7.0 HEATER
 - 7.1 Inadequate temperature in device enclosure
 - 7.2 Excessive temperature in device enclosure
 - 7.3 Not adequately secured to mounting surface
 - 7.4 Improper conductors from source
- 8.0 CONTROL WIRING
 - 8.1 Inappropriate for application
 - 8.2 Bundled and trained inappropriately
 - 8.3 Terminal boards improperly installed
 - 8.4 Insulation charred, burned, or discolored
 - 8.5 Splices improperly insulated
 - 8.6 Unauthorized splice
 - 8.7 Insulation improperly removed from conductor
 - 8.8 Bimetallic connectors not used as required
- 9.0 MARKING
 - 9.1 Illegible
 - 9.2 Damaged or missing dataplate
- 10.0 INSULATING LIQUID
 - 10.1 Low liquid level

TOOLS & MATERIALS

- 1. Light, portable
- 2. Infrared camera
- 3. Stepladder

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: METERING****CONTROL NUMBER: GSS 0.09.01.02.04****APPLICATION**

This guide applies to metering used in electrical system assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of metering systems provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of a metering system are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 METERING
 - 1.1 Calibration standard not established
 - 1.2 Device broken or other physical defect
 - 1.3 Tampering of device or circuit
 - 1.4 Device inadequately sized
 - 1.5 Device inoperative
- 2.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 3.0 DISCONNECT
 - 3.1 Blades bent or not aligned
 - 3.2 Handle broken, bent, or other physical deformity
 - 3.3 Inadequate size
 - 3.4 Blade clip bent, malaligned, or other physical deformity
 - 3.5 Clips pitted, burned, or discolored
 - 3.6 Blades pitted, burned, or discolored
 - 3.7 Improperly wired
 - 3.6 Not accessible
 - 3.9 Improper application
 - 3.10 improperly sized
 - 3.11 No engineering study to support adjustable settings
 - 3.12 High conductor, circuit breaker lug temperature as measured using thermographic test
- 4.0 FUSE UNIT
 - 4.1 Improperly sized
 - 4.2 Improper fuse type used
 - 4.3 Fuse clips bent, malaligned, discolored, or other physical damage

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: METERING (Continued)

CONTROL NUMBER: GSS 0.09.01.02.04

PHYSICAL DEFICIENCIES

- 4.0 FUSE UNIT
- 4.4 Poor fuse to clip contact as measured using thermographic test
- 5.0 BUSBAR
- 5.1 Dirty or other contamination
- 5.2 Loose joints as measured using thermographic test
- 5.3 Current limiting busway not used as required
- 6.0 BUSHING/INSULATOR
- 6.1 Tracked or carbonized
- 6.2 Missing, cracked, chipped, or other damage
- 6.3 Oil leak
- 6.4 Dirty, oily, greasy, or other surface contamination
- 6.5 Not adequately secured to mounting surface
- 7.0 CONTROL WIRING
- 7.1 Inappropriate for application
- 7.2 Bundled and trained inappropriately
- 7.3 Terminal boards improperly installed
- 7.4 Insulation charred, burned, or discolored
- 7.5 Splices improperly insulated
- 7.6 Unauthorized splice
- 7.7 Insulation improperly removed from conductor
- 7.8 Bimetallic connectors not used as required
- 8.0 MARKING
- 8.1 Illegible
- 8.2 Damaged or missing dataplate
- 9.0 LIGHTING PROTECTION/SURGE PROTECTION DEVICES
Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

- 1. Light, portable
- 2. Infrared camera
- 3. Stepladder

INSPECTION METHODS . STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: MOTORS****CONTROL NUMBER: GSS 0.09.01.02.05****APPLICATION**

This guide applies to motors larger than 10 horsepower used in low and medium Voltage distribution system assemblies. This guide does not apply to motors of ten 10 horsepower and less; such motors are addressed as part of the system that employs the motor.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of motors used in low and medium Voltage distribution system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of motors are not addressed.

PHYSICAL DEFICIENCIES**1.0 CABLE/CONDUCTOR**

- 1.1 Inappropriate for application
- 1.2 Insulation burned, charred, or other damage
- 1.3 Splice insulation unraveled, brittle, cracked, or other damage
- 1.4 Unauthorized splice
- 1.5 Not properly connected to device
- 1.6 Insulation improperly removed from conductor
- 1.7 Bimetallic connectors not used as required
- 1.8 Not properly bundled or trained

2.0 FITTING

- 2.1 Missing, broken, cracked, or other damage
- 2.2 Insert broken, cracked, missing, or other damage
- 2.3 Improper fitting for application
- 2.4 Unused openings not covered or plugged

3.0 BEARINGS

- 3.1 High bearing temperature as measured in thermographic test
- 3.2 Rough or irregular bearing during rotation as measured in vibration analysis
- 3.3 Leaking seals

4.0 ROTOR/STATOR

- 4.1 Not clean and moisture-free

5.0 MOUNT

- 5.1 Dirty or other internal or external surface contamination
- 5.2 Not properly secured to mounting structure
- 5.3 Mounting structure inadequate

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTORS (Continued)

CONTROL NUMBER: GSS 0.09.01.02.05

PHYSICAL DEFICIENCIES**5.0 MOUNT**

5.4 Motor not adequately secured to mount

6.0 MOTOR APPLICATION

6.1 Inappropriate starting system

6.2 Improper motor size

6.3 Improper rotation as determined by stroboscope

6.4 Improper connection of bimetallic elements

6.5 Improper speed as measured with stroboscope

7.0 HEATER

7.1 Inadequate temperature in device enclosure

7.2 Excessive temperature in device enclosure

7.3 Not adequately secured to mounting surface

7.4 Improper conductors from source

8.0 MARKING

8.1 Illegible

8.2 Damaged or missing dataplate

9.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. infrared camera
3. Stepladder

INSPECTION METHODS - STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTOR CONTROL CENTERS

CONTROL NUMBER: GSS 0.09.01.02.06

APPLICATION

This guide covers those devices normally used in an assembly of low and medium Voltage motor control centers.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low and medium Voltage motor control center assemblies provides input to an analysis of functional and physical deficiencies of low and medium Voltage distribution systems, Because the system exists and is not in a construction process, regulatory deficiencies associated with motor control centers are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 2.0 ENCLOSURE
 - 2.1 Not adequate for application
 - 2.2 Corroded, rusted, dented, or other physical damage
 - 2.3 Not secured to mounting surface
 - 2.4 Unused openings not covered or plugged
 - 2.5 Not grounded properly
 - 2.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 2.7 Not accessible
 - 2.8 Vent defective/nonoperative
 - 2.9 Oil leak
 - 2.10 No curbing or berm for oil containment
 - 2.11 Not clean and moisture-free
- 3.0 DISCONNECT
 - 3.1 Blades bent or not aligned
 - 3.2 Handle broken, bent, or other physical deformity
 - 3.3 Inadequate size
 - 3.4 Blade clip bent, malaligned, or other physical deformity
 - 3.5 Clips pitted, burned, or discolored
 - 3.6 Blades pitted, burned, or discolored
 - 3.7 Improperly wired
 - 3.8 Not accessible
 - 3.9 Improper application

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTOR CONTROL CENTERS (Continued)

CONTROL NUMBER: GSS 0.09.01.02.06

PHYSICAL DEFICIENCIES

- 3.0 DISCONNECT
 - 3.10 Improperly sized
 - 3.11 No engineering study to support adjustable settings
 - 3.12 High conductor, circuit breaker lug temperature as measured using thermographic test
- 4.0 FUSE UNIT
 - 4.1 Improperly sized
 - 4.2 Improper fuse type used
 - 4.3 Fuse clips bent, malaligned, discolored, or other physical damage
 - 4.4 Poor fuse to clip contact as measured using thermographic test
- 5.0 PRESSURE RELIEF
 - 5.1 High internal pressure
 - 5.2 No internal pressure
- 6.0 CONTACTOR
 - 6.1 Control circuits improperly connected
 - 6.2 Indicator lamps inoperative
 - 6.3 Indicator lens missing, cracked, or broken
 - 6.4 Noisy
 - 6.5 Missing, loose, broken, or corroded hardware
 - 6.6 Rheostat ventilation impeded
 - 6.7 Plugging relays dirty or other contamination
 - 6.8 Pushbuttons not labeled
 - 6.9 Improper size
 - 6.10 Thermal trip device wrong size
 - 6.11 No engineering study to support thermal trip device rating
 - 6.12 Coil discolored, burned, or other signs of high temperature
- 7.0 HEATER
 - 7.1 Inadequate temperature in device enclosure
 - 7.2 Excessive temperature in device enclosure
 - 7.3 Not adequately secured to mounting surface
 - 7.4 Improper conductors from source
- 8.0 BUSHING/INSULATOR
 - 8.1 Tracked or carbonized
 - 8.2 Missing, cracked, chipped, or other damage
 - 8.3 Oil leak
 - 8.4 Dirty, oily, greasy, or other surface contamination
 - 8.5 Not adequately secured to mounting surface
- 9.0 CONTROL WIRING
 - 9.1 Inappropriate for application
 - 9.2 Bundled and trained inappropriately
 - 9.3 Terminal boards improperly installed
 - 9.4 Insulation charred, burned, or discolored
 - 9.5 Splices improperly insulated
 - 9.6 Unauthorized splice
 - 9.7 Insulation improperly removed from conductor

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: MOTOR CONTROL CENTERS (Continued)****CONTROL NUMBER: GSS 0.09.01.02.06****PHYSICAL DEFICIENCIES****9.0 CONTROL WIRING****9.8** Bimetallic connectors not used as required**10.0 BUS****10.1** Discolored, warped, or other signs of high temperature**10.2** Insulated connections unraveled, brittle, cracked, or other physical damage**10.3** Dirty or other contamination**10.4** Loose joints as measured using thermographic test**11.0 METERING****11.1** Calibration standard not established**11.2** Device broken or other physical defect**11.3** Tampering of device or circuit**11.4** Device inadequately sized**11.5** Device inoperative**12.0 EQUIPMENT PROTECTION****12.1** Improper or inadequate primary protection device**12.2** Improper or inadequate secondary protection device**12.3** Improper or inadequate differential protection device**12.4** No engineering study to support protection scheme**13.0 MARKING****13.1** Illegible**13.2** Damaged or missing dataplate**14.0 TRANSFORMERS**

Transformers encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.11.

15.0 PANELBOARDS

Panelboards encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.07.

16.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.10.

17.0 INSULATING LIQUID**17.1** Low liquid level**18.0 LIGHTNING PROTECTION & SURGE SUPPRESSION**

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS . STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** RACEWAY & FITTINGS**CONTROL NUMBER:** GSS 0.09.01.02.08**APPLICATION**

This guide applies to raceway and fittings used in low or medium Voltage distribution system assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of raceway and fittings used in low and medium Voltage distribution system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of raceway and fittings are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 RACEWAY**
 - 1.1 Inappropriate for application
 - 1.2 Not adequately secured to mounting surface
 - 1.3 Not adequately secured to enclosure
 - 1.4 Not secured within 3 feet of end of run or enclosure
 - 1.5 More than 360 degrees of bend between pull points
 - 1.6 Bent, crushed, ruptured
 - 1.7 Unused openings not covered or plugged
 - 1.8 No bushing or equivalent protection
 - 1.9 Supported by other raceway
 - 1.10 Exterior rusted, corroded, or other physical damage
 - 1.11 Excessive run of flexible conduit
 - 1.12 Interior rusted, corroded, or other physical damage
 - 1.13 Hanger rusted, corroded, or other physical damage
 - 1.14 Hanger not adequately secured to structure
- 2.0 FILLING**
 - 2.1 Missing, broken, cracked, or other damage
 - 2.2 Insert broken, cracked, missing, or other damage
 - 2.3 Improper fitting for application
 - 2.4 Unused openings not covered or plugged
- 3.0 MARKING**
 - 3.1 Illegible
 - 3.2 Damaged or missing dataplate

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: RACEWAY & FITTINGS (Continued)

CONTROL NUMBER: GSS 0.09.01.02.08

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS . STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: SWITCHBOARD ASSEMBLY****CONTROL NUMBER: GSS 0.09.01.02.09****APPLICATION**

This guide applies to switchboard assemblies used as part of a low and medium Voltage distribution systems. Switchboards used in medium Voltage systems are often referred to as switchgear.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of switchboard assemblies used in low and medium Voltage distribution systems provide input to an analysis of functional and physical deficiencies of the low and medium Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with switchboards are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 2.0 BUS
 - 2.1 Discolored, warped, or other signs of high temperature
 - 2.2 Insulated connections unraveled, brittle, cracked, or other physical damage
 - 2.3 Dirty or other contamination
 - 2.4 Loose joints as measured using thermographic test
- 3.0 ENCLOSURE
 - 3.1 Not adequate for application
 - 3.2 Corroded, rusted, dented, or other physical damage
 - 3.3 Not secured to mounting surface
 - 3.4 Unused openings not covered or plugged
 - 3.5 Not grounded properly
 - 3.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 3.7 Not accessible
 - 3.8 Vent defective/nonoperative
 - 3.9 Oil leak
 - 3.10 No curbing or berm for oil containment
 - 3.11 Not clean and moisture-free
- 4.0 DISCONNECT
 - 4.1 Blades bent or not aligned
 - 4.2 Handle broken, bent, or other physical deformity
 - 4.3 Inadequate size

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: SWITCHBOARD ASSEMBLY (Continued)

CONTROL NUMBER: GSS 0.09.01.02.09

PHYSICAL DEFICIENCIES

- 4.0 DISCONNECT
- 4.4 Blade clip bent, malaligned, or other physical deformity
- 4.5 Clips pitted, burned, or discolored
- 4.6 Blades pitted, burned, or discolored
- 4.7 Improperly wired
- 4.8 Not accessible
- 4.9 Improper application
- 4.10 Improperly sized
- 4.11 No engineering study to support adjustable settings
- 4.12 High conductor, circuit breaker lug temperature as measured using thermographic test
- 5.0 FUSE UNIT
- 5.1 Improperly sized
- 5.2 Improper fuse type used
- 5.3 Fuse clips bent, malaligned, discolored, or other physical damage
- 5.4 Poor fuse to clip contact as measured using thermographic test
- 6.0 PRESSURE RELIEF
- 6.1 High internal pressure
- 6.2 No internal pressure
- 7.0 HEATER
- 7.1 Inadequate temperature in device enclosure
- 7.2 Excessive temperature in device enclosure
- 7.3 Not adequately secured to mounting surface
- 7.4 Improper conductors from source
- 8.0 BUSHING/INSULATOR
- 8.1 Tracked or carbonized
- 8.2 Missing, cracked, chipped, or other damage
- 8.3 Oil leak
- 8.4 Dirty, oily, greasy, or other surface contamination
- 8.5 Not adequately secured to mounting surface
- 9.0 CONTROL WIRING
- 9.1 Inappropriate for application
- 9.2 Bundled and trained inappropriately
- 9.3 Terminal boards improperly installed
- 9.4 Insulation charred, burned, or discolored
- 9.5 Splices improperly insulated
- 9.6 Unauthorized splice
- 9.7 Insulation improperly removed from conductor
- 9.8 Bimetallic connectors not used as required
- 10.0 METERING
- 10.1 Calibration standard not established
- 10.2 Device broken or other physical defect
- 10.3 Tampering of device or circuit
- 10.4 Device inadequately sized
- 10.5 Device inoperative

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: SWITCHBOARD ASSEMBLY (Continued)

CONTROL NUMBER: GSS 0.09.01.02.09

PHYSICAL DEFICIENCIES**11.0 EQUIPMENT PROTECTION**

- 11.1 Improper or inadequate primary protection device
- 11.2 Improper or inadequate secondary protection device
- 11.3 Improper or inadequate differential protection device
- 11.4 No engineering study to support protection scheme

12.0 MARKING

- 12.1 Illegible
- 12.2 Damaged or missing dataplate

13.0 TRANSFORMERS

Transformers encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.11.

14.0 PANELBOARDS

Panelboards encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.07.

15.0 INSULATING LIQUID

- 15.1 Low liquid level

16.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ■ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: TRANSFER SWITCHES****CONTROL NUMBER: GSS 0.09.01.02.10****APPLICATION**

This guide covers switches with or without automatic control circuits.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of transfer switches provides input to an analysis of functional and physical deficiencies of the low and medium Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with switches are not addressed.

PHYSICAL DEFICIENCIES**1.0 CONDUCTORS & FITTINGS**

Conductors and fittings other than control wiring is encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.

2.0 ENCLOSURE

- 2.1 Not adequate for application
- 2.2 Corroded, rusted, dented, or other physical damage
- 2.3 Not secured to mounting surface
- 2.4 Unused openings not covered or plugged
- 2.5 Not grounded properly
- 2.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
- 2.7 Not accessible
- 2.8 Vent defective/nonoperative
- 2.9 Oil leak
- 2.10 No curbing or berm for oil containment
- 2.11 Not clean and moisture-free

3.0 DISCONNECT

- 3.1 Blades bent or not aligned
- 3.2 Handle broken, bent, or other physical deformity
- 3.3 Inadequate size
- 3.4 Blade clip bent, malaligned, or other physical deformity
- 3.5 Clips pitted, burned, or discolored
- 3.6 Blades pitted, burned, or discolored
- 3.7 Improperly wired
- 3.8 Not accessible
- 3.9 Improper application

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFER SWITCHES (Continued)

CONTROL NUMBER: GSS 0.09.01.02.10

PHYSICAL DEFICIENCIES**3.0 DISCONNECT**

- 3.10 Improperly sized
- 3.11 No engineering study to support adjustable settings
- 3.12 High conductor-circuit breaker lug temperature as measured using thermographic test

4.0 BUSHING/INSULATOR

- 4.1 Tracked or carbonized
- 4.2 Missing, cracked, chipped, or other damage
- 4.3 Oil leak
- 4.4 Dirty, oily, greasy, or other surface contamination
- 4.5 Not adequately secured to mounting surface

5.0 SOLENOID

- 5.1 Fitting missing or inappropriate
- 5.2 Noisy
- 5.3 Missing, loose, broken, or corroded hardware
- 5.4 Relays dirty or other contamination
- 5.5 Improper size
- 5.6 Coil discolored, burned, or other signs of high temperature

6.0 CONTROL WIRING

- 6.1 Adjustable settings not in accordance with engineering study
- 6.2 Indicator lamps inoperative
- 6.3 Indicator lens missing, cracked, or broken
- 6.4 Bimetallic connectors not used as required
- 6.5 Inappropriate for application
- 6.6 insulation is charred, brittle, discolored
- 6.7 Incorrect fuse installed
- 6.8 No engineering study to support installed fuse
- 6.9 Inadequate fuse/connection tension
- 6.10 Control circuits improperly connected
- 6.11 Bundled and trained inappropriately
- 6.12 Terminal boards improperly installed
- 6.13 Splices improperly insulated
- 6.14 Unauthorized splice
- 6.15 Insulation improperly removed from conductor

7.0 HEATER

- 7.1 Inadequate temperature in device enclosure
- 7.2 Excessive temperature in device enclosure
- 7.3 Not adequately secured to mounting surface
- 7.4 Improper conductors from source

8.0 METERING

- 8.1 Calibration standard not established
- 8.2 Device broken or other physical defect
- 8.3 Tampering of device or circuit
- 8.4 Device inadequately sized
- 8.5 Device inoperative

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFER SWITCHES (Continued)

CONTROL NUMBER: GSS 0.09.01.02.10

PHYSICAL DEFICIENCIES**9.0 MARKING**

9.1 Illegible

9.2 Damaged or missing dataplate

10.0 INSULATING LIQUID

10.1 Low liquid level

11.0 PRESSURE RELIEF

11.1 High internal pressure

11.2 No internal pressure

12.0 BUS

12.1 Discolored, warped, or other signs of high temperature

12.2 Insulated connections unraveled, brittle, cracked, or other physical damage

12.3 Dirty or other contamination

12.4 Loose joints as measured using thermographic test

13.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ■ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFORMERS

CONTROL NUMBER: GSS 0.09.01.02.11

APPLICATION

This guide applies to transformers used to provide voltage at the required level in an electrical system.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of transformers provide an input to the analysis of functional and physical deficiencies of an electrical distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of transformers are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 2.0 TRANSFORMER
 - 2.1 Ventilation obstructed
 - 2.2 Improper guarding
 - 2.3 Noisy
 - 2.4 Unused taps not insulated
 - 2.5 Inadequate rating
 - 2.6 High operating temperature when measured in thermographic test
 - 2.7 High cable termination temperature when measured in thermographic test
 - 2.8 Location not adequately ventilated
 - 2.9 Corona
- 3.0 ENCLOSURE
 - 3.1 Not adequate for application
 - 3.2 Corroded, rusted, dented, or other physical damage
 - 3.3 Not secured to mounting surface
 - 3.4 Unused openings not covered or plugged
 - 3.5 Not grounded properly
 - 3.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 3.7 Not accessible
 - 3.8 Vent defective/nonoperative
 - 3.9 Oil leak
 - 3.10 No curbing or berm for oil containment
 - 3.11 Not clean and moisture-free

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFORMERS (Continued)

CONTROL NUMBER: GSS 0.09.01.02.11

PHYSICAL DEFICIENCIES

- 4.0 HEATER
 - 4.1 Inadequate temperature in device enclosure
 - 4.2 Excessive temperature in device enclosure
 - 4.3 Not adequately secured to mounting surface
 - 4.4 Improper conductors from source
 - 4.5 Not adequately secured to mounting surface
- 5.0 BUSHING/INSULATOR
 - 5.1 Tracked or carbonized
 - 5.2 Missing, cracked, chipped, or other damage
 - 5.3 Oil leak
 - 5.4 Dirty, oily, greasy, or other surface contamination
- 6.0 EQUIPMENT PROTECTION
 - 6.1 No engineering study to support protection scheme
- 7.0 METERING
 - 7.1 Calibration standard not established
 - 7.2 Device broken or other physical defect
 - 7.3 Tampering of device or circuit
 - 7.4 Device inadequately sized
 - 7.5 Device inoperative
 - 7.6 Improper Display
- 8.0 CONTROL WIRING
 - 8.1 Inappropriate for application
 - 8.2 Bundled and trained inappropriately
 - 8.3 Terminal boards improperly installed
 - 8.4 Insulation charred, burned, or discolored
 - 8.5 Splices improperly insulated
 - 8.6 Unauthorized splice
 - 8.7 Insulation improperly removed from conductor
 - 8.8 Bimetallic connectors not used as required
- 9.0 MARKING
 - 9.1 Illegible
 - 9.2 Damaged or missing dataplate
- 10.0 INSULATING LIQUID
 - 10.1 Low liquid level
- 11.0 PRESSURE RELIEF
 - 11.1 High internal pressure
 - 11.2 No internal pressure
- 12.0 VENTILATION
 - 12.1 High operating temperature
 - 12.2 Inlets clogged
 - 12.3 Obstructed
 - 12.4 Location not ventilated

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** TRANSFORMERS (Continued)**CONTROL NUMBER:** GSS 0.09.01.02.11**PHYSICAL DEFICIENCIES****13.0 LIGHTNING PROTECTION & SURGE SUPPRESSION**

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

14.0 DISCONNECTS

Disconnects encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.03.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ■ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: SERVICE ENTRANCE ASSEMBLY****CONTROL NUMBER: GSS 0.09.01 .01****APPLICATION**

This guide applies to all service entrance assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of service entrance assemblies provides an analysis of functional and physical deficiencies of an electrical service entrance system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of service entrance assemblies are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 **BUSWAY**
Busways encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.01.
- 2.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control are encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 3.0 **DISCONNECTS**
Disconnects encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.03.
- 4.0 **METERING**
Metering encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.04.
- 5.0 **RACEWAY & FITTINGS**
Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ▪ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS - STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: LOW VOLTAGE DISTRIBUTION SYSTEM ASSEMBLY****CONTROL NUMBER: GSS 0.09.01.02****APPLICATION**

This guide applies to all low Voltage Distribution System assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low Voltage distribution System assemblies provides an analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of the assembly are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 **BUSWAY**
Busways encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.01.
- 2.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control are encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 3.0 **DISCONNECTS**
Disconnects encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.03.
- 4.0 **METERING**
Metering encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.04.
- 5.0 **MOTORS**
Motors encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS **0.09.02.05**.
- 6.0 **MOTOR CONTROL CENTER**
Motor control centers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS **0.09.02.06**.
- 7.0 **PANELBOARDS**
Panelboards encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.07.
- 8.0 **RACEWAY & FITTINGS**
Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.08.

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: LOW VOLTAGE DISTRIBUTION SYSTEM (Continued)****CONTROL NUMBER: GSS 0.09.01.02****PHYSICAL DEFICIENCIES****9.0 SWITCHBOARDS**

Switchboards encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.09.

10.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.10.

11.0 TRANSFORMERS

Transformers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.11.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: PANELBOARD ASSEMBLY****CONTROL NUMBER: GSS 0.09.01.02.07****APPLICATION**

This guide applies to low Voltage panelboard assemblies as used in low Voltage distribution systems.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low Voltage panelboard assemblies provides input to an analysis of functional and physical deficiencies of the low Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with panelboards are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring is encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 2.0 ENCLOSURE
 - 2.1 Not adequate for application
 - 2.2 Corroded, rusted, dented, or other physical damage
 - 2.3 Not secured to mounting surface
 - 2.4 Unused openings not covered or plugged
 - 2.5 Not grounded properly
 - 2.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 2.7 Not accessible
 - 2.8 Vent defective/nonoperative
 - 2.9 Oil leak
 - 2.10 No curbing or berm for oil containment
 - 2.11 Not clean and moisture-free
- 3.0 DISCONNECT
 - 3.1 Blades bent or not aligned
 - 3.2 Handle broken, bent, or other physical deformity
 - 3.3 Inadequate size
 - 3.4 Blade clip bent, malaligned, or other physical deformity
 - 3.5 Clips pitted, burned, or discolored
 - 3.6 Blades pitted, burned, or discolored
 - 3.7 Improperly wired
 - 3.8 Not accessible
 - 3.9 Improper application

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PANELBOARD ASSEMBLY (Continued)

CONTROL NUMBER: GSS 0.09.01.02.07

PHYSICAL DEFICIENCIES

- 3.0 DISCONNECT
 - 3.10 Improperly sized
 - 3.11 No engineering study to support adjustable settings
 - 3.12 High conductor, circuit breaker lug temperature as measured using thermographic test
- 4.0 FUSE UNIT
 - 4.1 Improperly sized
 - 4.2 Improper fuse type used
 - 4.3 Fuse clips bent, malaligned, discolored, or other physical damage
 - 4.4 Poor fuse to clip contact as measured using thermographic test
- 5.0 HEATER
 - 5.1 Inadequate temperature in device enclosure
 - 5.2 Excessive temperature in device enclosure
 - 5.3 Not adequately secured to mounting surface
 - 5.4 improper conductors from source
- 6.0 BUSHING/INSULATOR
 - 6.1 Tracked or carbonized
 - 6.2 Missing, cracked, chipped, or other damage
 - 6.3 Oil leak
 - 6.4 Dirty, oily, greasy, or other surface contamination
 - 6.5 Not adequately secured to mounting surface
- 7.0 BUS
 - 7.1 Discolored, warped, or other signs of high temperature
 - 7.2 Insulated connections unraveled, brittle, cracked, or other physical damage
 - 7.3 Dirty or other contamination
 - 7.4 Loose joints as measured using thermographic test
- 8.0 METERING
 - 8.1 Calibration standard not established
 - 8.2 Device broken or other physical defect
 - 8.3 Tampering of device or circuit
 - 8.4 Device inadequately sized
 - 8.5 Device inoperative
- 9.0 CONTROL WIRING
 - 9.1 Inappropriate for application
 - 9.2 Bundled and trained inappropriately
 - 9.3 Terminal boards improperly installed
 - 9.4 Insulation charred, burned, or discolored
 - 9.5 Splices improperly insulated
 - 9.6 Unauthorized splice
 - 9.7 Insulation improperly removed from conductor
 - 9.8 Bimetallic connectors not used as required

INSPECTION METHODS - STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** PANELBOARD ASSEMBLY (Continued)**CONTROL NUMBER:** GSS 0.09.01.02.07**PHYSICAL DEFICIENCIES****10.0 MARKING**

10.1 Illegible

10.2 Damaged or missing dataplate

11.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS . STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS - STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** MEDIUM VOLTAGE DISTRIBUTION SYSTEM ASSEMBLY**CONTROL NUMBER:** GSS 0.09.01.03**APPLICATION**

This guide applies to all Medium Voltage Distribution System assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of medium Voltage distribution System assemblies provides an analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of the assembly are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 **BUSWAY**
Busways encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.01.
- 2.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 3.0 **DISCONNECTS**
Disconnects encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.03.
- 4.0 **METERING**
Metering encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.04.
- 5.0 **MOTORS**
Motors encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.05.
- 6.0 **MOTOR CONTROL CENTER**
Motor control centers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.06.
- 7.0 **RACEWAY & FITTINGS**
Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.08.

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: MEDIUM VOLTAGE DISTRIBUTION SYSTEM (Continued)****CONTROL NUMBER: GSS 0.09.01.03****PHYSICAL DEFICIENCIES****8.0 SWITCHBOARDS (SWITCHGEAR)**

Switchboards/switchgear encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.09.

9.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.10.

10.0 TRANSFORMERS

Transformers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.02.11.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LUMINAIRES

CONTROL NUMBER: GSS 0.09.02.01

APPLICATION

This guide applies to luminaires used in a lighting system and connected to the low Voltage distribution system.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of luminaires in a lighting system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of luminaires are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than fixture wiring encountered in the evaluation of this luminaire will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.
- 2.0 CONTROL UNITS
Control units encountered in the evaluation of this luminaire will be inspected in accordance with Guide Sheet GSS 0.09.03.03.
- 3.0 RACEWAY & FITTINGS
Raceway and fittings encountered in the evaluation of this luminaire will be inspected in accordance with Guide Sheet GSS 0.09.02.02.08.
- 4.0 HOUSING
 - 4.1 Not clean and moisture-free
 - 4.2 Not adequate for application or location
 - 4.3 Corroded, rusted, dented, or other physical damage
 - 4.4 Not secured to mounting surface
 - 4.5 Unused openings not covered or plugged
 - 4.6 Not accessible
 - 4.7 Missing
 - 4.8 Top, bottom, or side cover missing
 - 4.9 Vent defective or nonoperative
 - 4.10 Ventilation obstructed or clogged
- 5.0 BALLAST
 - 5.1 Inoperative
 - 5.2 Noisy

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LUMINAIRES (Continued)

CONTROL NUMBER: GSS 0.09.02.01

PHYSICAL DEFICIENCIES

- 6.0 LAMP
 - 6.1 Inappropriate for application
 - 6.2 Inoperative
 - 6.3 Dirty, oily, greasy, or other physical contamination
 - 6.4 Low light output level
 - 6.5 Missing, chipped, cracked, or other damage
 - 6.6 Improper burning position
- 7.0 LENS
 - 7.1 Dirty, oily, greasy, or other surface contamination
 - 7.2 Not adequately secured
 - 7.3 Missing, cracked, chipped, or other damage
 - 7.4 Inappropriate for application
- 8.0 REFLECTOR
 - 8.1 Dirty, oily, greasy, or other physical contamination
 - 8.2 Not adequately secured
 - 8.3 Missing, cracked, chipped, or other damage
 - 8.4 Inappropriate for application
- 9.0 SOCKET
 - 9.1 Dirty, oily, greasy, or other physical contamination
 - 9.2 Not adequately secured
 - 9.3 Missing, cracked, chipped, or other damage
- 10.0 FIXTURE WIRING
 - 10.1 Bundled or trained inappropriately
 - 10.2 Improperly spliced
 - 10.3 Inadequately torqued at termination
 - 10.4 Inappropriate application
- 11.0 GLOBE
 - 11.1 Dirty, oily, greasy, or other physical contamination
 - 11.2 Not adequately secured
 - 11.3 Missing, cracked, chipped, or other damage
 - 11.4 Inappropriate for application
- 12.0 SAFETY GUARD
 - 12.2 Not adequately secured
 - 12.2 Missing, broken, or other damage
- 13.0 FIXTURE HANGER
 - 13.1 Inappropriate for application
 - 13.2 Not adequately secured
 - 13.3 Missing, broken, corroded, or other physical damage
- 14.0 MARKING
 - 14.1 Illegible
 - 14.2 Damaged or missing dataplate

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LUMINAIRES (Continued)

CONTROL NUMBER: GSS 0.09.02.01

PHYSICAL DEFICIENCIES**15.0 BATTERY/APPLICATION**

- 15.1 Inoperative
- 15.2 Ventilation obstructed or clogged
- 15.3 Flame arrestor missing or broken

16.0 BATTERY/CHARGER

- 16.1 Inoperative
- 16.2 Noisy
- 16.3 Indicator lamps inoperative
- 16.4 Indicator lamp missing, cracked, or broken
- 16.5 Indicator meter inoperative or missing
- 16.6 Test switch inoperative or missing

17.0 DIMMER SWITCH

- 17.1 Inoperative
- 17.2 Noisy
- 17.3 Not adequately secured to mounting surface
- 17.4 Missing, cracked, or broken components
- 17.5 Dirty, oily, greasy, or other surface contamination

TOOLS & MATERIALS

- 1. Light, portable
- 2. Light level meter
- 3. Stepladder
- 4. Light level meter
- 5. Infrared camera
- 6. MegOhmmeter
- 7. Multimeter

INSPECTION METHODS ■ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CABLE TRAY
CONTROL NUMBER: GSS 0.09.03.01

APPLICATION

This guide applies only to the unique facets of this system. Any part of the electrical system not unique to this system will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of cable tray assemblies provide an analysis of functional and physical deficiencies of an electrical cable tray system as part of a facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE TRAY**
 - 1.1 Inappropriate for application
 - 1.2 Not adequately secured to mounting surface
 - 1.3 Not secured within 3 feet of end of run or enclosure
 - 1.4 Bent, crushed, ruptured
 - 1.5 Unused openings not covered or plugged
 - 1.6 No bushing or equivalent protection
 - 1.7 Supported by other raceway
 - 1.8 Exterior rusted, corroded, or other physical damage
 - 1.9 Interior rusted, corroded, or other physical damage
 - 1.10 Hanger rusted, corroded, or other physical damage
 - 1.11 Hanger not adequately secured to structure
 - 1.12 Not grounded properly
 - 1.13 Ventilation not adequate
 - 1.14 Ventilation perforations covered, clogged, or plugged
 - 1.15 Not clean and moisture-free
- 2.0 INSTALLATION**
 - 2.1 Missing, broken, cracked, or other damage
 - 2.2 insert broken, cracked, missing, or other damage
 - 2.3 Improper fitting for application
 - 2.4 Unused openings not covered or plugged
 - 2.5 Elbow improperly installed and connected
 - 2.6 Tee improperly installed and connected
 - 2.7 Cross improperly installed and connected
 - 2.8 Wye improperly installed and connected

INSPECTION METHODS . STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** CABLE TRAY (Continued)**CONTROL NUMBER:** GSS 0.09.03.01**PHYSICAL DEFICIENCIES****2.0 INSTALLATION**

- 2.9 Reducer improperly installed and connected
- 2.10 Divider improperly installed and connected
- 2.11 Drop out improperly installed and connected
- 2.12 End cap improperly installed and connected
- 2.13 Covers inappropriate for application
- 2.14 Covers improperly installed
- 2.15 Expansion joint improperly placed and installed
- 2.16 Panel connector improperly installed and connected

3.0 CONDUCTORS & FITTINGS

The conductors and fittings found in a cable tray assembly will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.

4.0 MARKING

- 4.1 Illegible
- 4.2 Damaged or missing dataplate

5.0 PENETRATION

- 5.1 Approved seals not used in boundaries.

6.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of the cable tray assembly will be inspected in accordance with Guide Sheet GSS 0.09.01.02.08.

TOOLS & MATERIALS

- 1. Light, portable
- 2. Infrared camera
- 3. Stepladder

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: COMMUNICATION CIRCUITS

CONTROL NUMBER: GSS 0.09.03.02

APPLICATION

This guide applies to the communication systems and point-to-point wiring of the communication system used in association with electrical systems. The guide does not apply to communication devices.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.'
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical systems used in conjunction with communication systems are part of a facility electrical system assessment. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 1.1 Not located below power conductors
 - 1.2 Attached to crossarms with power conductors
 - 1.3 Insufficient climbing space
 - 1.4 Insufficient clearance from energized conductors
 - 1.5 Insufficient clearance over structures
 - 1.6 Not separated in underground application from power or light conductors
 - 1.7 Unlisted or non-identified protector employed
 - 1.8 Protectors unlisted, missing, or defective
 - 1.9 Protector improperly located
 - 1.10 Fused protector not used as required or improperly fused
 - 1.11 Metal raceway or approved building penetration device missing or defective
 - 1.12 Not listed for application
 - 1.13 Improper for application or location
 - 1.14 Less than 6 feet to lightning conductors
 - 1.15 Not adequately protected
 - 1.16 Insulation frayed, brittle or other physical damage
 - 1.17 Not bundled, trained or secured
 - 1.18 Splices improperly insulated
 - 1.19 Unauthorized splice
 - 1.20 Not properly connected to device
 - 1.21 Insulation improperly removed from conductor
 - 1.22 Not properly supported in vertical run
 - 1.23 Metallic sheath grounding inadequate

INSPECTION METHODS ▪ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: COMMUNICATION CIRCUITS (Continued)

CONTROL NUMBER: GSS 0.09.03.02

PHYSICAL DEFICIENCIES**2.0 FITTING**

- 2.1 Missing, broken, cracked, or other damage
- 2.2 Insert broken, cracked, missing, or other damage
- 2.3 Improper fitting for application
- 2.4 Approved seal not used at boundaries

3.0 MARKING

- 3.1 Illegible
- 3.2 Damaged or missing dataplate

4.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.08.

5.0 INSTALLATION

- 5.1 Missing, broken, cracked, or other damage
- 5.2 Insert broken, cracked, missing, or other damage
- 5.3 improper fitting for application
- 5.4 Unused openings not covered or plugged
- 5.5 Elbow improperly installed and connected
- 5.6 Tee improperly installed and connected
- 5.7 Cross improperly installed and connected
- 5.8 Wye improperly installed and connected
- 5.9 Reducer improperly installed and connected
- 5.10 Divider improperly installed and connected
- 5.11 Drop out improperly installed and connected
- 5.12 End cap improperly installed and connected
- 5.13 Covers inappropriate for application
- 5.14 Covers improperly installed
- 5.15 Expansion joint improperly placed and installed
- 5.16 Panel connector improperly installed and connected

6.0 PENETRATION

- 6.1 Approved seals not used in boundaries.

7.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

- 1. Light, portable
- 2. Infrared camera
- 3. Stepladder

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS

CONTROL NUMBER: GSS 0.09.03.03

APPLICATION

This guide applies only to the unique facets of this system. Any part of the electrical system not unique to this system will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of control units or assemblies provide input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with control unit are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 FITTING
 - 1.1 Missing, broken, cracked, or other damage
 - 1.2 Insert broken, cracked, missing, or other damage
 - 1.3 Improper fitting for application
 - 1.4 Unused openings not covered or plugged
 - 1.5 Elbow improperly installed and connected
 - 1.6 Tee improperly installed and connected
 - 1.7 Crossover improperly installed and connected
 - 1.8 Cable-tap boxes improperly installed and connected
 - 1.9 Bus plugs improperly installed, connected, and/or inadequate for application
 - 1.10 Expansion joint improperly placed and installed
 - 1.11 Switchboard flange connection improperly installed and connected
- 2.0 ENCLOSURE
 - 2.1 Not adequate for application
 - 2.2 Corroded, rusted, dented, or other physical damage
 - 2.3 Not secured to mounting surface
 - 2.4 Unused openings not covered or plugged
 - 2.5 Not grounded properly
 - 2.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 2.7 Not accessible
 - 2.8 Vent defective/nonoperative
 - 2.9 Not clean and moisture-free
- 3.0 DISCONNECT
 - 3.1 Improperly sized
 - 3.2 No engineering study to support adjustable settings

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS (Continued)

CONTROL NUMBER: GSS 0.09.03.03

PHYSICAL DEFICIENCIES

- 3.0 DISCONNECT
- 3.3 High conductor - breaker lug temperature as measured in thermographic test
- 3.4 Blades bent or not aligned
- 3.5 Handle broken, bent, or other physical deformity
- 3.6 Inadequate size
- 3.7 Blade clip bent, malaligned, or other physical deformity
- 3.8 Clips pitted, burned, or discolored
- 3.9 Blades pitted, burned, or discolored
- 3.10 Improperly wired
- 3.11 Not accessible
- 3.12 Improper application

- 4.0 FUSE UNIT
- 4.1 improperly sized
- 4.2 Improper fuse type used
- 4.3 Fuse clips bent, malaligned, discolored, or other physical damage
- 4.4 Poor fuse to clip contact as measured using thermographic test

- 5.0 CABLE/CONDUCTOR
- 5.1 Not located below power conductors
- 5.2 Attached to crossarms with power conductors
- 5.3 Insufficient climbing space
- 5.4 Insufficient clearance from energized conductors
- 5.5 Insufficient clearance over structures
- 5.6 Not separated in underground application from power or light conductors
- 5.7 Unlisted or non-identified protector employed
- 5.8 Protectors unlisted, missing, or defective
- 5.9 Protector improperly located
- 5.10 Fused protector not used as required or improperly fused
- 5.11 Metal raceway or approved building penetration device missing or defective
- 5.12 Not listed for application
- 5.13 Improper for application or location
- 5.14 Less than 6 feet to lightning conductors
- 5.15 Not adequately protected
- 5.16 Insulation frayed, brittle or other physical damage
- 5.17 Not bundled, trained or secured
- 5.18 Splices improperly insulated
- 5.19 Unauthorized splice
- 5.20 Not properly connected to device
- 5.21 Insulation improperly removed from conductor
- 5.22 Not properly supported in vertical run
- 5.23 Metallic sheath grounding inadequate

- 6.0 CONTACTOR
- 6.1 Control circuits improperly connected
- 6.2 Indicator lamps inoperative
- 6.3 Indicator lens missing, cracked, or broken
- 6.4 Noisy
- 6.5 Missing, loose, broken, or corroded hardware

INSPECTION METHODS - STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS (Continued)

CONTROL NUMBER: GSS 0.09.03.03

PHYSICAL DEFICIENCIES

- 6.0 CONTACTOR
 - 6.6 Rheostat ventilation impeded
 - 6.7 Plugging relays dirty or other contamination
 - 6.8 Pushbuttons not labeled
 - 6.9 Improper size
 - 6.10 Thermal trip device wrong size
 - 6.11 No engineering study to support thermal trip device rating
 - 6.12 Coil discolored, burned, or other signs of high temperature
- 7.0 HEATER
 - 7.1 Inadequate temperature in device enclosure
 - 7.2 Excessive temperature in device enclosure
 - 7.3 Not adequately secured to mounting surface
 - 7.4 Improper conductors from source
- 8.0 BUSHING/INSULATOR
 - 8.1 Tracked or carbonized
 - 8.2 Missing, cracked, chipped, or other damage
 - 8.3 Dirty, oily, greasy, or other surface contamination
 - 8.4 Not adequately secured to mounting surface
- 9.0 CONTROL WIRING
 - 9.1 Inappropriate for application
 - 9.2 Bundled and trained inappropriately
 - 9.3 Terminal boards improperly installed
 - 9.4 Insulation charred, burned, or discolored
 - 9.5 Splices improperly insulated
 - 9.6 Unauthorized splice
 - 9.7 Insulation improperly removed from conductor
 - 9.8 Bimetallic connectors not used as required
- 10.0 BUS
 - 10.1 Discolored, warped, or other signs of high temperature
 - 10.2 Insulated connections unraveled, brittle, cracked, or other physical damage
 - 10.3 Dirty or other contamination
 - 10.4 Loose joints as measured using thermographic test
- 11.0 EQUIPMENT PROTECTION
 - 11.1 Improper or inadequate primary protection device
 - 11.2 Improper or inadequate secondary protection device
 - 11.3 Improper or inadequate differential protection device
 - 11.4 No engineering study to support protection scheme
- 12.0 MARKING
 - 12.1 Illegible
 - 12.2 Damaged or missing dataplate
- 13.0 TRANSFORMERS
 - Transformers encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.11.

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS (Continued)

CONTROL NUMBER: GSS 0.09.03.03

PHYSICAL DEFICIENCIES

14.0 PANELBOARDS

Panelboards encountered will be inspected in accordance with Guide Sheet GSS 0.09.01.02.07.

15.0 TRANSFER SWITCHES

Transfer switches encountered will be inspected in accordance with Guide Sheet GSS 0.09.01.02.10.

16.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

17.0 PHOTOCCELL

17.1 Inoperative

17.2 Not clean and moisture-free

17.3 Dirty, oily, greasy, or other surface contamination

17.4 Not adequately secured to mounting surface

17.5 Missing, chipped, cracked, or other damage

17.6 Inappropriate for application

17.7 Improper aiming direction

17.8 Inappropriate turn-off/turn-on ratio

17.9 Discolored, burned, or other signs of high temperature

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** DATA PROCESSING ELECTRICAL EQUIPMENT**CONTROL NUMBER:** GSS 0.09.03.04**APPLICATION**

This guide applies to the electrical components, assemblies, or systems used in association with data processing equipment systems. The guide does not apply to the data processing equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical components, assemblies, and systems used in conjunction with automatic data processing equipment are part of a facility electrical system assessment. This guide sheet focuses on the special or unique features of the electrical component, assembly, or system necessary to serve automatic data processing equipment and is to be used with other guides as appropriate. Because the system exists and is not in a construction process, regulatory deficiencies associated with installing the electrical component, assembly, or system are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 FACILITY
 - 1.1 Improper ground circuit
 - 1.2 Not double insulated and ungrounded equipment employed
 - 1.3 Metal parts of ADP equipment not grounded
 - 1.4 No disconnect for all ADP equipment
 - 1.5 No disconnect for HVAC equipment serving ADP area
 - 1.6 Unlisted equipment installed
 - 1.7 Unauthorized supplies and materials
 - 1.8 Unauthorized personnel present
 - 1.9 Fire-resistant-rated walls, ceilings, or floor not employed
 - 1.10 Smoke and fire dampers missing
 - 1.12 Conductor ampacity less than 125% of load
 - 1.13 Cable and conductor penetrations defective or deficient
- 2.0 CABLE/CONDUCTOR
 - 2.1 Not located below power conductors
 - 2.2 Attached to crossarms with power conductors
 - 2.3 insufficient climbing space
 - 2.4 Insufficient clearance from energized conductors
 - 2.5 Insufficient clearance over structures
 - 2.6 Not separated in underground application from power or light conductors
 - 2.7 Unlisted or non-identified protector employed
 - 2.8 Protectors unlisted, missing, or defective

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: DATA PROCESSING ELECTRICAL EQUIPMENT (Continued)****CONTROL NUMBER: GSS 0.09.03.04****PHYSICAL DEFICIENCIES****2.0 CABLE/CONDUCTOR**

- 2.9 Protector improperly located
- 2.10 Fused protector not used as required or improperly fused
- 2.11 Metal raceway or approved building penetration device missing or defective
- 2.12 Not listed for application
- 2.13 Improper for application or location
- 2.14 Less than 6 feet to lightning conductors
- 2.15 Not adequately protected
- 2.16 Insulation frayed, brittle or other physical damage
- 2.17 Not bundled, trained or secured
- 2.18 Splices improperly insulated
- 2.19 Unauthorized splice
- 2.20 Not properly connected to device
- 2.21 Insulation improperly removed from conductor
- 2.22 Not properly supported in vertical run
- 2.23 Metallic sheath grounding inadequate

3.0 GROUND CIRCUIT

- 3.1 Metal parts not grounded
- 3.2 Multiple ground circuits

4.0 MALAPROPOS DISCONNECT

- 4.1 Disconnect not present

5.0 MARKING

- 5.1 Illegible
- 5.2 Damaged or missing dataplate

6.0 PENETRATION

- 6.1 Approved seals not used in boundaries.

7.0 BUSWAY

Busways encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.01.

8.0 CONDUCTORS & FITTINGS

Conductors and fittings used in association with automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.

9.0 DISCONNECTS

Disconnects encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.03.

10.0 PANELBOARDS

Panelboards encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.07.

11.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.08.

INSPECTION METHODS - STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: DATA PROCESSING ELECTRICAL EQUIPMENT (Continued)****CONTROL NUMBER: GSS 0.09.03.04****PHYSICAL DEFICIENCIES****12.0 SWITCHBOARDS**

Switchboards encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.09.

13.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.10.

14.0 TRANSFORMERS

Transformers encountered in the inspection of the automatic data processing equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.11.

15.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS ■ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** GENERATORS, STANDBY/EMERGENCY**CONTROL NUMBER:** GSS 0.09.03.05**APPLICATION**

This guide applies to alternators or generators that are driven by electrical or mechanical means and the alternator or generator is used to provide electrical energy to an electrical system. This guide does not apply to alternators or generators that are a component part of an engine system where the alternator/generator is used only to charge batteries of the start system.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of alternators or generators used in a standby or emergency generator package provide an input to the analysis of functional and physical deficiencies of that assembly. Since the assembly exists and is not in a construction process, regulatory deficiencies associated with installation of alternators are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR**
 - 1.1 Inappropriate for application
 - 1.2 Insulation burned, charred, or other damage
 - 1.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 1.4 Unauthorized splice
 - 1.5 Not properly connected to device
 - 1.6 Insulation improperly removed from conductor
 - 1.7 Bimetallic connectors not used as required
 - 1.8 Not properly bundled or trained
- 2.0 FITTING**
 - 2.1 Missing, broken, cracked, or other damage
 - 2.2 Insert broken, cracked, missing, or other damage
 - 2.3 Improper fitting for application
 - 2.4 Unused openings not covered or plugged
- 3.0 BEARINGS**
 - 3.1 High bearing temperature as measured in thermographic test
 - 3.2 Rough or irregular bearing during rotation as measured in vibration analysis
 - 3.3 Leaking seals
- 4.0 ROTOR/STATOR**
 - 4.1 Not clean and moisture-free
- 5.0 MOUNT**
 - 5.1 Dirty or other internal or external surface contamination
 - 5.2 Not properly secured to mounting structure

INSPECTION METHODS . STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: GENERATORS, STANDBY/EMERGENCY (Continued)****CONTROL NUMBER: GSS 0.09.03.05****PHYSICAL DEFICIENCIES**

- 5.0 MOUNT
 - 5.3 Mounting structure inadequate
 - 5.4 Unit not adequately secured to mount
- 6.0 EXHAUST SYSTEM
 - 6.1 Missing
- 7.0 HEATER
 - 7.1 Inadequate temperature in device enclosure
 - 7.2 Excessive temperature in device enclosure
 - 7.3 Not adequately secured to mounting surface
 - 7.4 Improper conductors from source
- 8.0 MARKING
 - 8.1 Illegible
 - 8.2 Damaged or missing dataplate
- 9.0 DISCONNECT
 - 9.1 Blades bent or not aligned
 - 9.2 Handle broken, bent, or other physical deformity
 - 9.3 Inadequate size
 - 9.4 Blade clip bent, malaligned, or other physical deformity
 - 9.5 Clips pitted, burned, or discolored
 - 9.6 Blades pitted, burned, or discolored
 - 9.7 Improperly wired
 - 9.8 Not accessible
 - 9.9 Improper application
 - 9.10 Improperly sized
 - 9.11 No engineering study to support adjustable settings
 - 9.12 High conductor-breaker lug temperature as measured in thermographic test
- 10.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.
- 11.0 CONTROL WIRING
 - 11.1 Inappropriate for application
 - 11.2 Bundled and trained inappropriately
 - 11.3 Terminal boards improperly installed
 - 11.4 Insulation charred, burned, or discolored
 - 11.5 Splices improperly insulated
 - 11.6 Unauthorized splice
 - 11.7 Insulation improperly removed from conductor
 - 11.8 Bimetallic connectors not used as required
- 12.0 BUSHING/INSULATOR
 - 12.1 Tracked or carbonized
 - 12.2 Missing, cracked, chipped, or other damage
 - 12.3 Dirty, oily, greasy, or other surface contamination

INSPECTION METHODS . STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: GENERATORS, STANDBY/EMERGENCY (Continued)

CONTROL NUMBER: GSS 0.09.03.05

PHYSICAL DEFICIENCIES

- 13.0 ENGINE
 - 13.1 Low crankcase oil level
 - 13.2 Missing or dirty combustion air intake filter
 - 13.3 Gauges missing or broken
 - 13.4 Improperly set up for operation
- 14.0 METERING
 - 14.1 Calibration standard not established
 - 14.2 Device broken or other physical defect
 - 14.3 Tampering of device or circuit
 - 14.4 Device inadequately sized
 - 14.5 Device inoperative
- 15.0 EXCITER/VOLTAGE REGULATOR
 - 15.1 Improperly set up for operation
- 16.0 TRANSFER SWITCH
 - Transfer switches encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.01.02.10.
- 17.0 START SYSTEM
 - 17.1 Air receivers discharged
 - 17.2 Batteries discharged
 - 17.3 Battery charger inoperative
 - 17.4 Inoperative solenoid
 - 17.5 Inoperative starter motor
 - 17.6 Low air capacity
- 18.0 LOCAL FUEL SYSTEM
 - 18.1 Control valves dysfunctional
 - 18.2 Filters dirty, missing, wrong size
 - 18.3 Fuel stale or old
 - 18.4 Storage tank dented, rusted, or other damage
 - 18.5 Water present
- 19.0 PENETRATION
 - 19.1 Approved seals not used
- 20.0 ENCLOSURE
 - 20.1 Not adequate for application
 - 20.2 Corroded, rusted, dented, or other physical damage
 - 20.3 Not secured to mounting surface
 - 20.4 Unused openings not covered or plugged
 - 20.5 Not grounded properly
 - 20.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 20.7 Not accessible
 - 20.8 Vent defective/nonoperative
 - 20.9 Not clean and moisture-free

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: GENERATORS, STANDBY/EMERGENCY (Continued)****CONTROL NUMBER: GSS 0.09.03.05****PHYSICAL DEFICIENCIES**

- 21.0 FUSE UNIT
- 21.1 Improperly sized
- 21.2 Improper fuse type used
- 21.3 Fuse clips bent, malaligned, discolored, or other physical damage
- 21.4 Poor fuse to clip contact as measured using thermographic test

TOOLS & MATERIALS

- 1. Light, portable
- 2. Infrared camera
- 3. Stepladder
- 4. Stroboscope

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** HEALTH CARE FACILITIES ELECTRICAL EQUIPMENT**CONTROL NUMBER:** GSS 0.09.03.06**APPLICATION**

This guide applies to the electrical components, devices, assemblies, or systems used in association with health care systems. The guide does not apply to the health care system equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical components, devices, assemblies, and systems used in conjunction with health care systems equipment are part of a facility electrical system assessment. This guide sheet focuses on the special or unique features of the electrical component, device, assembly, or system necessary to serve health care equipment and is to be used with other guides as appropriate. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of the electrical component, assembly, or system are not addressed.

PHYSICAL DEFICIENCIES**1.0 LOCATION**

- 1.1 Equipment and/or components not rated for Class 1 application
- 1.2 Metal raceway or approved cable not used
- 1.3 Storage device for flexible cord not provided
- 1.4 Two circuits are not present
- 1.5 One circuit does not originate in normal system
- 1.6 Four receptacles are not present

2.0 P E N E T R A T I O N

- 2.1 Approved seals not used in horizontal or vertical boundaries

3.0 ESSENTIAL SYSTEM

- 3.1 System not properly maintained or tested
- 3.2 Unauthorized loads connected to emergency system
- 3.3 Transfer switches are not used
- 3.4 Isolation of authorized systems not maintained as required
- 3.5 Metal raceway is not used where required
- 3.6 Two energy sources are not used
- 3.7 Receptacles not hospital grade
- 3.6 Receptacles not tamper resistant in pediatric areas

4.0 GROUNDING

- 4.1 Insulated copper conductor not used
- 4.2 Grounding conductor not appropriately sized

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: HEALTH CARE FACILITIES ELECTRICAL EQUIPMENT (Continued)****CONTROL NUMBER: GSS 0.09.03.06****PHYSICAL DEFICIENCIES****4.0 GROUNDING**

- 4.3 Metal raceway or appropriate cable not used
- 4.4 Panelboards not bonded together
- 4.5 Conductive surfaces have unacceptable potential difference

5.0 CABLE/CONDUCTOR

- 5.1 Inappropriate for application
- 5.2 Insulation burned, charred, or other damage
- 5.3 Splice insulation unraveled, brittle, cracked, or other damage
- 5.4 Unauthorized splice
- 5.5 Not properly connected to device
- 5.6 Insulation improperly removed from conductor
- 5.7 Bimetallic connectors not used as required
- 5.8 Not properly bundled or trained

6.0 MARKING

- 6.1 Illegible
- 6.2 Damaged or missing dataplate

7.0 INADEQUATE SERVICE

- 7.1 Four receptacles are not present
- 7.2 One circuit does not originate in normal system
- 7.3 Receptacles not hospital grade
- 7.4 Receptacles not tamper resistant in pediatric areas
- 7.5 Two circuits are not present

8.0 BUSWAY

Busways encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.01.

9.0 CONDUCTORS & FITTINGS

Conductors and fittings used in association with this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.

10.0 DISCONNECTS

Disconnects encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.03.

11.0 PAN ELBOARDS

Panelboards encountered in the inspection of this equipment then will be inspected in accordance with Guide Sheet GSS 0.09.01.02.07.

12.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.08.

13.0 SWITCHBOARDS

Switchboards encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.09.

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: HEALTH CARE FACILITIES ELECTRICAL EQUIPMENT (Continued)

CONTROL NUMBER: GSS 0.09.03.06

PHYSICAL DEFICIENCIES**14.0 TRANSFER SWITCHES**

Transfer switches encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.10.

15.0 TRANSFORMERS

Transformers encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.11.

16.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder
4. MegOhmmeter
5. Wheatstone bridge
6. Timer
7. Insulation materials

INSPECTION METHODS ▪ STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS - STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** HEATING, BASEBOARD RADIATION**CONTROL NUMBER:** GSS 0.09.03.07**APPLICATION**

This guide applies only to the unique facets of this system. Any part of the electrical system not unique in this system will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of baseboard radiation heating units or assemblies provide input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with baseboard radiation heating units are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 1.1 Conductor not rated at 125% or greater of load rating
 - 1.2 Not protected for installation
 - 1.3 Penetrations defective or deficient
- 2.0 ENCLOSURE
 - 2.1 Not adequate for application
 - 2.2 Corroded, rusted, dented, or other physical damage
 - 2.3 Not secured to mounting surface
 - 2.4 Unused openings not covered or plugged
 - 2.5 Not grounded properly
 - 2.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
 - 2.7 Not accessible
 - 2.8 Vent defective/nonoperative
 - 2.9 Not clean and moisture-free
- 3.0 DISCONNECT
 - 3.1 Not grouped and identified for heating application
 - 3.2 Not within sight of overcurrent protection
 - 3.3 Improper application of unit switch as disconnect
 - 3.4 Improper application of thermostat control device as disconnect
 - 3.5 Improper application
- 4.0 CONTROL WIRING
 - 4.1 Inappropriate for application
 - 4.2 Bundled and trained inappropriately
 - 4.3 Terminal boards improperly installed

INSPECTION METHODS - STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: HEATING, BASEBOARD RADIATION (Continued)

CONTROL NUMBER: GSS 0.09.03.07

PHYSICAL DEFICIENCIES

- 4.0 CONTROL WIRING
 - 4.4 Insulation charred, burned, or discolored
 - 4.5 Splices improperly insulated
 - 4.6 Unauthorized splice
 - 4.7 Insulation improperly removed from conductor
 - 4.8 Bimetallic connectors not used as required
- 5.0 EQUIPMENT PROTECTION
 - 5.1 Improper or inadequate protection device
 - 5.3 No engineering study to support protection scheme
 - 5.4 Not physically protected from damage
 - 5.5 Not isolated from combustible materials
- 6.0 MARKING
 - 6.1 Illegible
 - 6.2 Damaged or missing dataplate
- 7.0 INSTALLATION
 - 7.1 Conductor or cable not appropriate for installation
 - 7.2 Conductor or cable not listed
 - 7.3 Hanger not adequately secured to structure
 - 7.5 Inadequate grounding
 - 7.6 Inadequate ventilation
 - 7.7 Missing vertical run hardware
 - 7.8 No bushing or equivalent protection
 - 7.9 Not adequately protected from severe physical damage
 - 7.10 Not adequately secured to mounting surface
 - 7.11 Not appropriate for location
 - 7.12 Not clearly and permanently marked where required
 - 7.13 Not properly spaced from combustible materials
 - 7.14 Not secured within three feet of end of run
 - 7.15 Unauthorized conductor present
 - 7.16 Unused openings not covered or plugged

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LIGHTNING PROTECTION & SURGE SUPPRESSION

CONTROL NUMBER: GSS 0.09.03.08

APPLICATION

This guide applies only to the unique facets of these devices. That part of the electrical system in support of these devices will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of lightning protection/surge suppression devices provide an input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with lightning protection/surge suppression devices are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 2.0 CONNECTION
 - 2.1 Wrong wire size used
 - 2.2 Not connected to authorized ground point
 - 2.3 Metallic interconnection not used in grounding
 - 2.4 Spark gap or listed device not used as required in grounding
 - 2.5 Ground wire not bonded at ends of metal enclosures
 - 2.6 Shield wire not properly grounded
 - 3.0 LOCATION
 - 3.1 Accessible to public
 - 3.2 Does not protect all circuits
 - 3.3 Unacceptable ground path length
 - 3.4 Unacceptable number of bends in ground wire
 - 4.0 PENETRATION
 - 4.1 Approved seals not used in horizontal or vertical boundaries
 - 5.0 RATING
 - 5.1 Rating not adequate for operating circuit Voltage
 - 5.2 Silicon carbide type not rated at 125% of applied voltage
 - 5.3 Not appropriate for system
 - 5.4 Spark gap or listed device under Voltage rated
 - 6.0 DEVICE
 - 6.1 Isolator has opened ground circuit
 - 6.2 Air horns bent, malformed, or other physical damage

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LIGHTNING PROTECTION & SURGE SUPPRESSION

(Continued)

CONTROL NUMBER: GSS 0.09.03.08

PHYSICAL DEFICIENCIES

- 6.0 DEVICE
- 6.3 Fiber tube destroyed
- 6.4 Thyrite discs broken, missing, or other physical damage
- 6.5 Device not secured to mount
- 6.6 Dirty, oily, greasy, or other surface contamination

- 7.0 MARKING
- 7.1 Illegible
- 7.2 Damaged or missing dataplate

TOOLS & MATERIALS

- 1. Light, portable
- 2. Infrared camera
- 3. Stepladder

INSPECTION METHODS - STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PETROLEUM DISPENSING FACILITIES ELECTRICAL EQUIPMENT
CONTROL NUMBER: GSS 0.09.03.09

APPLICATION

This guide applies to the electrical components, devices, assemblies, or systems used in association with petroleum dispensing station systems. The guide does not apply to the petroleum dispensing station system equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical components, devices, assemblies, and systems used in conjunction with petroleum dispensing station systems equipment are part of a facility electrical system assessment. This guide sheet focuses on the special or unique features of the electrical component, device, assembly, or system necessary to serve petroleum dispensing facilities electrical equipment and is to be used with other guides as appropriate. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of the electrical component, assembly, or system are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 DEVICE APPLICATION
 - 1.1 Approved seals not used in horizontal or vertical boundary penetration
 - 1.2 Seal in horizontal or vertical boundary missing or defective
 - 1.3 Grounding conductor improperly sized or placed
 - 1.4 Grounded conductor not copper or insulated
 - 1.4 Heaters not listed for application
 - 1.5 Devices not listed for application
 - 1.6 Enclosure not properly rated for class one application
 - 1.7 General purpose enclosure improperly used
 - 1.8 Enclosure improperly or inadequately marked
 - 1.9 Enclosure connection devices improper or inadequate for application
 - 1.10 Drainage system missing or inadequate
 - 1.11 Bonding jumpers missing, inadequate or improperly installed
 - 1.12 Locations not properly bounded
 - 1.13 Flammable liquids located in bounded location
 - 1.14 Vaults missing or defective
 - 1.15 Bounded location improperly or inadequately ventilated
 - 1.16 Improper penetration of bounded location
- 2.0 CABLE/CONDUCTOR
 - 2.1 Inappropriate for application
 - 2.2 Insulation burned, charred, or other damage
 - 2.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 2.4 Unauthorized splice

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PETROLEUM DISPENSING FACILITIES ELECTRICAL EQUIPMENT

(Continued)

CONTROL NUMBER: GSS 0.09.03.09

PHYSICAL DEFICIENCIES**2.0 CABLE/CONDUCTOR**

- 2.5 Not properly connected to device
- 2.6 Insulation improperly removed from conductor
- 2.7 Bimetallic connectors not used as required
- 2.8 Not properly bundled or trained

3.0 ENCLOSURE

- 3.1 Not adequate for application
- 3.2 Corroded, rusted, dented, or other physical damage
- 3.3 Not secured to mounting surface
- 3.4 Unused openings not covered or plugged
- 3.5 Not grounded properly
- 3.6 Pedestal mounting surface chipped, cracked, broken, or other physical damage
- 3.7 Not accessible
- 3.8 Vent defective/nonoperative
- 3.9 Oil leak
- 3.10 No curbing or berm for oil containment
- 3.11 Not clean and moisture-free

4.0 LOCATION

- 4.1 Accessible to public
- 4.2 Does not protect all circuits
- 4.3 Equipment and/or components not rated for class 1 application
- 4.4 Flammable liquids located in area
- 4.5 Inadequate ventilation
- 4.6 Location not properly bounded
- 4.7 Metal raceway or approved cable not used
- 4.8 Storage device for flexible cord not provided
- 4.9 Unauthorized penetration between vault and class 1 location
- 4.10 Unlisted components employed
- 4.11 Vault not used as required for transformer and/or capacitor

5.0 MARKING

- 5.1 Illegible
- 5.2 Damaged or missing dataplate

6.0 PENETRATION

- 6.1 Approved seals not used in boundaries.

7.0 SEAL

- 7.1 Leaking, missing, or damaged

8.0 UNDERGROUND WIRING

- 8.1 Improper insulation
- 8.2 Inappropriate cable
- 8.3 Inappropriate raceway

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: PETROLEUM DISPENSING FACILITIES ELECTRICAL EQUIPMENT**

(Continued)

CONTROL NUMBER: GSS 0.09.03.09**PHYSICAL DEFICIENCIES****9.0 BUSWAY**

Busways encountered in the inspection of the petroleum dispensing facilities electrical equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.01.

10.0 CONDUCTORS & FITTINGS

Conductors and fittings used in association with petroleum dispensing station equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.02.

11.0 DISCONNECTS

Disconnects encountered in the inspection of the petroleum dispensing station equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.03.

12.0 PANELBOARDS

Panelboards encountered in the inspection of the petroleum dispensing station equipment then will be inspected in accordance with Guide Sheet GSS 0.09.01.02.07.

13.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of the petroleum dispensing station equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.08.

14.0 SWITCHBOARDS

Switchboards encountered in the inspection of the petroleum dispensing station equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.09.

15.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of the petroleum dispensing station equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.10.

16.0 TRANSFORMERS

Transformers encountered in the inspection of the petroleum dispensing station equipment will be inspected in accordance with Guide Sheet GSS 0.09.01.02.11.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS . STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: SIGNAL CIRCUITS****CONTROL NUMBER: GSS 0.09.03.10****APPLICATION**

This guide applies to the signal circuits and point-to-point signal circuit wiring used in association with electrical systems. The guide does not apply to signal devices.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical systems used in conjunction with signal circuits are part of a facility electrical system assessment. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 OVERCURRENT DEVICE
 - 1.1 Not adequate for conductor size smaller than 14 AWG
 - 1.2 Not located at conductor/source connection
 - 1.3 Device permits overrating
 - 1.4 Device rated in excess of 167% of source rating
- 2.0 RATING
 - 2.1 Rated in excess of 20 Amperes
 - 2.2 Unlisted supply connected in parallel
 - 2.3 More than 30 Volts and 1000 Volt-Amperes available to load
 - 2.4 More than 2500 Volt-Amperes available from non-transformer source
- 3.0 FITTING
 - 3.1 Missing, broken, cracked, or other damage
 - 3.2 Insert broken, cracked, missing, or other damage
 - 3.3 Improper fitting for application
 - 3.4 Unused openings not covered or plugged
 - 3.5 Elbow improperly installed and connected
 - 3.6 Tee improperly installed and connected
 - 3.7 Crossover improperly installed and connected
 - 3.8 Cable-tap boxes improperly installed and connected
 - 3.9 Bus plugs improperly installed, connected, and/or inadequate for application
 - 3.10 Expansion joint improperly placed and installed
 - 3.11 Switchboard flange connection improperly installed and connected
- 4.0 MARKING
 - 4.1 Illegible
 - 4.2 Damaged or missing dataplate

INSPECTION METHODS ■ STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** SIGNAL CIRCUITS (Continued)**CONTROL NUMBER:** GSS 0.09.03.10**PHYSICAL DEFICIENCIES****5.0 RACEWAY & FITTINGS**

Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.01.02.08.

6.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSS 0.09.03.08.

7.0 CABLE/CONDUCTOR**7.1** inappropriate for application**7.2** Insulation burned, charred, or other damage**7.3** Splice insulation unraveled, brittle, cracked, or other damage**7.4** Unauthorized splice**7.5** Not properly connected to device**7.6** Insulation improperly removed from conductor**7.7** Bimetallic connectors not used as required**7.8** Not properly bundled or trained**8.0 PENETRATION****8.1** Approved seals not used in boundaries.**9.0 POWER SUPPLY****9.1** Class and rating not durably marked**9.2** Parallel connection of unmarked units**TOOLS & MATERIALS**

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS - STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES

CONTROL NUMBER: GSS 0.09.03.11

APPLICATION

This guide applies only to the unique facets of these devices. The electrical system components in support of these devices will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of Uninterruptible Power Supplies provide an input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with Uninterruptible Power Supply are not addressed.

PHYSICAL DEFICIENCIES**1.0 BATTERY/APPLICATION**

- 1.1 Inoperative or discharged
- 1.2 Improper liquid level
- 1.3 Corroded terminals
- 1.4 Cracked case
- 1.5 Electrolyte leakage or spills
- 1.6 Ventilation obstructed or clogged
- 1.7 Ampacity insufficient for load
- 1.8 Undercharged when measured with voltmeter
- 1.9 Overcharged when electrolyte sampled

2.0 CABLE/CONDUCTOR

- 2.1 Wrong wire size used
- 2.2 Improper termination on connector
- 2.3 Terminations not properly torqued

3.0 MOTOR APPLICATION

- 3.1 Inappropriate starting system
- 3.2 Improper size motor
- 3.3 Improper rotation
- 3.4 Improper speed
- 3.5 Improper connection of bitmetallic elements
- 3.6 Improper winding connections

4.0 MOTORS

Motors encountered in this inspection will be evaluated in accordance with Guide Sheet GSS 0.09.02.05.

INSPECTION METHODS • STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES (Continued)

CONTROL NUMBER: GSS 0.09.03.11

PHYSICAL DEFICIENCIES**5.0 BEARINGS**

- 5.1 High temperature
- 5.2 Rough or irregular rotation
- 5.3 Leaking seals
- 5.4 Improper bearing

6.0 METERING

Metering encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSS 0.09.02.04.

7.0 MARKING

- 7.1 Illegible
- 7.2 Damaged or missing dataplate

8.0 BUSHING/INSULATOR

- 8.1 Tracked or carbonized
- 8.2 Missing, cracked, chipped, or other damage
- 8.3 Dirty, oily, greasy, or other surface contamination

9.0 CONTROL WIRING

- 9.1 Inappropriate for application
- 9.2 Bundled and trained inappropriately
- 9.3 Terminal boards improperly installed
- 9.4 Insulation charred, burned, or discolored
- 9.5 Splices improperly insulated
- 9.6 Unauthorized splice
- 9.7 Insulation improperly removed from conductor
- 9.8 Bimetallic onnetors not used as required

10.0 DEVICE APPLICATION

- 10.1 Boxes, box assemblies, or fittings not approved for use
- 10.2 Heaters not approved for application
- 10.3 Improper connection of bimetallic elements
- 10.4 Pendant devices improperly suspended
- 10.5 Signal, alarm, remote-control, and communication devices
- 10.6 Not approved for class 1 use

11.0 DISCONNECT

- 11.1 Blades bent or not aligned
- 11.2 handle broken, bent, or other physical deformity
- 11.3 Inadequate size
- 11.4 Blade clip bent, malaligned, or other physical deformity
- 11.5 Clips pitted, burned, or discolored
- 11.6 Blades pitted, burned, or discolored
- 11.7 Improperly wired
- 11.8 Not accessible
- 11.9 Improper application
- 11.10 Improperly sized
- 11.11 No engineering study to support adjustable settings
- 11.12 High conductor-breaker lug temperature as measured in thermographic test

INSPECTION METHODS • STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES (Continued)****CONTROL NUMBER: GSS 0.09.03.11****PHYSICAL DEFICIENCIES****12.0 ENCLOSURE**

- 12.1 Not grounded properly
- 12.2 Pedestal mounting surface chipped, cracked, broken, or other physical damage
- 12.3 Not accessible
- 12.4 Vent defective/nonoperative
- 12.5 Not clean and moisture-free

13.0 EXCITER/VOLTAGE REGULATOR

- 13.1 Improperly set up for operation

14.0 FITTING

- 14.1 Missing, broken, cracked, or other damage
- 14.2 insert broken, cracked, missing, or other damage
- 14.3 Improper fitting for application
- 14.4 Approved seal not used at boundaries

15.0 FUSE UNIT

- 15.1 Improperly sized
- 15.2 Improper fuse type used
- 15.3 Fuse clips bent, malaligned, discolored, or other physical damage
- 15.4 Poor fuse to clip contact as measured using thermographic test

16.0 HEATER

- 16.1 Inadequate temperature in device enclosure
- 16.2 Excessive temperature in device enclosure
- 16.3 Not adequately secured to mounting surface
- 16.4 Improper conductors from source

17.0 MOUNT

- 17.1 Dirty or other internal or external surface contamination
- 17.2 Not properly secured to mounting structure
- 17.3 Mounting structure inadequate
- 17.4 Unit not adequately secured to mount

18.0 RECTIFIER/INVERTER

- 18.1 Corroded, rusted, dented, or other physical damage
- 18.2 Inappropriate for application
- 18.3 Indicator lamps inoperative
- 18.4 Indicator lens missing, cracked, or broken
- 18.5 Indicator meter inoperative or missing
- 18.6 Inoperative
- 18.7 Noisy
- 18.8 Not adequately secured
- 18.9 Not clean and moisture-free
- 18.10 Test switch inoperative or missing
- 18.11 Top, bottom, or side cover missing

19.0 ROTOR/STATOR

- 19.1 Bent, scored, or other damage to rotor shaft
- 19.2 Burned, charred, or other signs of high temperature

INSPECTION METHODS ■ STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES (Continued)

CONTROL NUMBER: GSS 0.09.03.11

PHYSICAL DEFICIENCIES**19.0 ROTOR/STATOR**

19.3 Noisy laminations

19.4 Non-uniform air gap

19.5 Open turns or coils

19.6 Shorted turns or coils

19.7 Splice insulation unraveled, brittle, cracked, or other damage

19.8 Unbalanced rotor assembly

20.0 ALTERNATORS/GENERATORS

Alternators or generators encountered in this inspection will be evaluated using guide sheet GSS 0.09.03.05.

21.0 TRANSFER SWITCHES

Transfer switches encountered in this inspection will be evaluated using guide sheet GSS 0.09.01.02.10.

22.0 TRANSFORMERS

Transformers encountered in this inspection will be evaluated using guide sheet GSS 0.09.01.02.11.

23.0 DISCONNECTS

Disconnects encountered in this inspection will be evaluated using guide sheet GSS 0.09.01.02.03.

TOOLS & MATERIALS

1. Light, portable
2. Infrared camera
3. Stepladder

INSPECTION METHODS • NON-STANDARD

GUIDE SHEETS

Guide Sheets provide a general overview of the inspection methods and requirements used to provide a general component inspection. Sheets have been developed for each major assembly/component as shown in TABLE TWO below:

TABLE TWO

Assembly/Component	Control Number	Page #
NON-STANDARD		
<u>General Use Guide Sheets</u>		
Busway	GSNS 0.09.01.02.01	3.2-83
Conductors & Fittings	GSNS 0.09.01.02.02	3.2-87
Disconnects	GSNS 0.09.01.02.03	3.2-89
Metering..	GSNS 0.09.01.02.04..	3.2-93
Motors..	GSNS 0.09.01.02.05..	3.2-97
Motor Control Center..	GSNS 0.09.01.02.06..	3.2-99
Raceway & Fittings	GSNS 0.09.01.02.08..	3.2-103
Switchboard Assembly..	GSNS 0.09.01.02.09..	3.2-105
Transfer Switches..	GSNS 0.09.01.02.10..	3.2-10 9
Transformers	GSNS 0.09.01.02.11	3.2-11 1
<u>Service Entrance Specific</u>		
Service Entrance Assembly	GSNS 0.09.01 .01	3.2-115
<u>Low Voltage Distribution System Specific</u>		
Low Voltage Distribution System Ass'y	GSNS 0.09.01.02	3.2-117
Panelboard Assembly	GSNS 0.09.01.02.07	3.2-119
<u>Medium Voltage Distribution System Specific</u>		
Medium Voltage Distribution System Ass'y ..	GSNS 0.09.01.03	3.2-123
<u>Lighting System Specific</u>		
Luminaires	GSNS 0.09.02.01	3.2-125
<u>Special Systems Specific</u>		
Cable Tray..	GSNS 0.09.03.01	3.2-129
Communication Circuits..	GSNS 0.09.03.02..	3.2-13 1
Control Units..	GSNS 0.09.03.03..	3.2-133
Data Processing Electrical Equipment..	GSNS 0.09.03.04..	3.2-13 7
Generators, Standby/Emergency	GSNS 0.09.03.05..	3.2-139
Health Care Facilities Electrical Equipment..	GSNS 0.09.03.06	3.2-143
Heating, Baseboard Radiation	GSNS 0.09.03.07..	3.2-14 5
Lightning Protection & Surge Suppression..	GSNS 0.09.03.08..	3.2-14 9
Petroleum Dispensing Facilities Elec. Equip	GSNS 0.09.03.09..	3.2-151
Signal Circuits	GSNS 0.09.03.10..	3.2-15 3
Uninterruptible Power Supplies	GSNS 0.09.03.11	3.2-15 5

INSPECTION METHODS . NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** BUSWAY**CONTROL NUMBER:** GSNS 0.09.01.02.01**APPLICATION**

This guide applies to all non-standard inspection procedures for busway used in low and medium Voltage distribution system assemblies and requires system deenergization.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the system to be deenergized during the survey event.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of busway provides an input to the analysis of functional and physical deficiencies of an electrical distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of distribution system are not addressed.

PHYSICAL DEFICIENCIES**1.0 BUSWAY ENCLOSURE**

- 1.1 Interlock broken, missing, or inoperative as measured in protective device test

2.0 FITTING**3.0 CONDUCTORS & FITTINGS**

Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.

4.0 METERING

- 4.1 Metering does not conform to calibration standard
- 4.2 Device or indicators broken or inoperative

5.0 DISCONNECT

- 5.1 Interlock broken, maladjusted, or inoperative as measured in protective device test
- 5.2 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
- 5.3 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 5.4 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 5.5 Contact pitted, burned, or discolored
- 5.6 Stationary contacts pitted, burned, or discolored
- 5.7 Phase barriers tracked, broken, cracked, missing, or other defect
- 5.8 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: BUSWAY (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.01

PHYSICAL DEFICIENCIES**5.0 DISCONNECT**

- 5.9 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
- 5.10 Contacts not properly aligned
- 5.11 Interlock broken, missing, or inoperative as measured in protective device test
- 5.12 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test
- 5.13 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 5.14 Adjustable settings maladjusted as measured in protective device test
- 5.15 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 5.16 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
- 5.17 Resistance less than one megOhm per kilovolt of rating between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 5.18 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 5.19 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 5.20 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 5.21 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 5.22 Series trip device missing, broken, or inoperative as measured in protective device test
- 5.23 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage

6.0 FUSE UNIT

- 6.1 Resistance less than one megOhm per kiloVolt of rating between poles and/or from poles to non-energized parts as measured in insulation resistance test

7.0 INSTALLATION**8.0 CONTACTOR**

- 8.1 Coil inoperative at 85% of rated Voltage in Voltage pickup test
- 8.2 Contacts burned, pitted, or other physical damage
- 8.3 Contact pressure not in accordance with manufacturer's specifications as measured with spring scale
- 8.4 Contacts not properly aligned
- 8.5 Arc suppression components broken, eroded, cracked, or missing
- 8.6 Dash pot inoperative, broken, or missing
- 8.7 Improper fluid in dash pot as measured in insulating liquid analysis test
- 8.8 Device sticks magnetically
- 8.9 Broken strands in braided shunts
- 8.10 Terminals, contact blocks, bus bars, and connectors loose or discolored
- 8.11 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 8.12 Rheostat contact surface corroded, oxidized, uneven, or other physical defect
- 8.13 Rheostat holding coil missing or inoperative
- 8.14 Improper rolling action of drum contacts

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: BUSWAY (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.01

PHYSICAL DEFICIENCIES**8.0 CONTACTOR**

8.15 Drum contacts inadequately torqued

8.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test

9.0 BUSBAR

9.1 Resistance less than one megOhm per kiloVolt of rating between buses and/or from buses to other non-energized component when measured with insulation resistance test

9.2 Joints inadequately torqued

9.3 Discolored, warped, or other sign of high temperature

9.4 Inadequately torqued to insulators

9.5 Joints/splices inadequately insulated when required

9.6 Joint/splice insulation burned, discolored, unraveled

10.0 BUSHING/INSULATOR

10.1 Not adequately torqued to mounting surface

11.0 HEATER

11.1 Sensing device broken, missing, or inoperative

11.2 Sensing device miscalibrated

11.3 Inadequate heater resistance to ground when measured by insulation resistance test

11.5 Heater inoperative

12.0 CONTROL WIRING

12.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test

12.2 Inadequately torqued at termination

13.0 MARKING

13.1 Illegible

13.2 Damaged or missing dataplate

14.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ▪ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: CONDUCTORS & FITTINGS****CONTROL NUMBER: GSNS 0.09.01.02.02****APPLICATION**

This guide applies to all non-standard inspection procedures for conductors and fittings used in low and medium Voltage distribution system assemblies. This guide does not apply to control wiring used in devices such as motor control centers or metering.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. Deenergize the systems served by the conductors to be inspected.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of conductors and fittings used in low and medium Voltage distribution system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of conductors and fittings are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 1.1 Conductor resistance to ground or other non-energized component is less than one megOhm per kiloVolt of rating when measured by the insulation resistance test
 - 1.2 Conductor not adequately torqued at device connection
 - 1.3 High resistance splice connection as measured by thermographic inspection
- 2.0 FITTING
- 3.0 MARKING
 - 3.1 Illegible
 - 3.2 Damaged or missing dataplate

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS . NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: DISCONNECTS****CONTROL NUMBER: GSNS 0.09.01.02.03****APPLICATION**

This guide applies to all non-standard inspection procedures for those circuit breakers and disconnects (switches with or without fuse blocks and isolating switches) normally used in low and medium Voltage distribution systems as stand alone devices; that is, the disconnect is not part of some larger assembly. A separate guide exists for transfer switches.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the disconnect to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of circuit breakers and switches provide input to an analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with disconnects are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS**
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 2.0 ENCLOSURE**
 - 2.1 Interlock broken, missing, or inoperative as measured in protective device test
- 3.0 DISCONNECT**
 - 3.1 Interlock broken, maladjusted, or inoperative as measured in protective device test
 - 3.2 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
 - 3.3 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
 - 3.4 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
 - 3.5 Contact pitted, burned, or discolored
 - 3.6 Stationary contacts pitted, burned, or discolored
 - 3.7 Phase barriers tracked, broken, cracked, missing, or other defect
 - 3.8 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
 - 3.9 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
 - 3.10 Contacts not properly aligned
 - 3.11 Interlock broken, missing, or inoperative as measured in protective device test
 - 3.12 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: DISCONNECTS (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.03

PHYSICAL DEFICIENCIES**3.0 DISCONNECT**

- 3.13 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 3.14 Adjustable settings maladjusted as measured in protective device test
- 3.15 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 3.16 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
- 3.17 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 3.18 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.19 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 3.20 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 3.21 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 3.22 Series trip device missing, broken, or inoperative as measured in protective device test
- 3.23 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage

4.0 BUSHING/INSULATOR

- 4.1 inadequately torqued to mounting surface or device

5.0 FUSE UNIT

- 5.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

6.0 PRESSURE RELIEF

- 6.1 High internal pressure
- 6.2 No internal pressure

7.0 HEATER

- 7.1 Sensing device broken, missing, or inoperative
- 7.2 Sensing device miscalibrated
- 7.3 Inadequate heater resistance to ground when measured by insulation resistance test
- 7.4 Heater inoperative

8.0 CONTROL WIRING

- 8.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
- 8.2 Inadequately torqued at termination

9.0 MARKING

- 9.1 Illegible
- 9.2 Damaged or missing dataplate

10.0 INSULATING LIQUID

- 10.1 Low liquid level
- 10.2 Liquid contaminated as measured in insulating liquid tests

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: DISCONNECTS (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.03

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: METERING****CONTROL NUMBER: GSNS 0.09.01.02.04****APPLICATION**

This guide applies to all non-standard inspection procedures for metering used in system assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The metering circuit must be deenergized during this inspection. Particular attention must be given to current transformer secondary circuits.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of metering systems provide an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of a metering system are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 METERING
 - 1.1 Metering does not conform to calibration standard
 - 1.2 Device or indicators broken or inoperative
- 2.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 3.0 DISCONNECT
 - 3.1 Interlock broken, maladjusted, or inoperative as measured in protective device test
 - 3.2 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
 - 3.3 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
 - 3.4 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
 - 3.5 Contact pitted, burned, or discolored
 - 3.6 Stationary contacts pitted, burned, or discolored
 - 3.7 Phase barriers tracked, broken, cracked, missing, or other defect
 - 3.8 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
 - 3.9 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
 - 3.10 Contacts not properly aligned
 - 3.11 Interlock broken, missing, or inoperative as measured in protective device test
 - 3.12 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: METERING (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.04

PHYSICAL DEFICIENCIES

3.0 DISCONNECT

- 3.13 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 3.14 Adjustable settings maladjusted as measured in protective device test
- 3.15 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 3.16 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
- 3.17 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 3.18 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.19 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 3.20 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 3.21 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 3.22 Series trip device missing, broken, or inoperative as measured in protective device test
- 3.23 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage

4.0 FUSE UNIT

- 4.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

5.0 BUSBAR

- 5.1 Resistance less than one megOhm between buses and/or from buses to other non-energized component when measured with insulation resistance test
- 5.2 Joints inadequately torqued
- 5.3 Discolored, warped, or other sign of high temperature
- 5.4 Inadequately torqued to insulators
- 5.5 Joints/splices inadequately insulated when required
- 5.6 Joint/splice insulation burned, discolored, unraveled

6.0 BUSHING/INSULATOR

- 6.1 Not adequately torqued to mounting surface

7.0 CONTROL WIRING

- 7.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
- 7.2 Inadequately torqued at termination

8.0 MARKING

- 8.1 Illegible
- 8.2 Damaged or missing dataplate

9.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: METERING (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.04

TOOLS & MATERIALS

1. Non-Standard inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTORS

CONTROL NUMBER: GSNS 0.09.01.02.05

APPLICATION

This guide applies to all non-standard inspection procedures for motors larger than ten (10) horsepower used in low and medium Voltage distribution system assemblies. This guide does not apply to motors of ten (10) horsepower and less; such motors are addressed as part of the system that employs the motor.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The motor must be deenergized during this inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of motors used in low and medium Voltage distribution system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of motors are not addressed.

PHYSICAL DEFICIENCIES**1.0 CABLE/CONDUCTOR**

- 1.1 Conductor resistance to ground or other non-energized component is less than one megOhm per kiloVolt of rating when measured by the insulation resistance test
- 1.2 High resistance splice connection as measured by thermographic inspection
- 1.3 Not properly connected to device

2.0 FITTINGS**3.0 BEARINGS**

- 3.1 Improper bearing

4.0 ROTOR/STATOR

- 4.1 Stator windings burned, charred, or other signs of high temperature
- 4.2 Rotor windings burned, charred, or other signs of high temperature
- 4.3 Shorted turns or coils in stator as determined in rotating machinery test
- 4.4 Shorted turns or coils in rotor as determined in rotating machinery test
- 4.5 Open turns or coils in stator as determined in rotating machinery test
- 4.6 Open turns or coils in rotor as determined in rotating machinery test
- 4.7 Noisy laminations in rotor or stator as measured in noise analysis test
- 4.8 Unbalanced rotor assembly as measured in vibration analysis test
- 4.9 Insulation is charred, brittle, discolored
- 4.10 Splice insulation unraveled, brittle, cracked, or other damage
- 4.11 Improper winding connections in rotor as determined in rotating machinery test
- 4.12 Improper winding connections in stator as determined in rotating machinery test
- 4.13 Non-uniform stator, rotor air gap as determined in rotating machinery test

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTORS (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.05

PHYSICAL DEFICIENCIES

4.0 ROTOR/STATOR

- 4.14 Bent, scored, or other damage to rotor shaft as determined in rotating machinery test
- 4.15 Insulation resistance less than one megOhm per each kiloVolt of rating as measured in insulation resistance test
- 4.16 Broken or inoperative brush rigging assembly in stator as determined in rotating machinery test
- 4.17 Commutator scored, bent, out-of-round, or other damage as determined in rotating machinery test
- 4.18 Improper connections to commutator segments as determined in rotating machinery test
- 4.19 Broken or inoperative centrifugal device in rotor as determined in rotating machinery test
- 4.20 Broken or inoperative centrifugal switch in stator as determined in rotating machinery test

5.0 MOUNT

6.0 MOTOR APPLICATION

- 6.1 Inappropriate starting system in stator as determined in rotating machinery test

7.0 HEATER

- 7.1 Sensing device broken, missing, or inoperative
- 7.2 Sensing device miscalibrated
- 7.3 Inadequate heater resistance to ground when measured by insulation resistance test
- 7.5 Heater inoperative

8.0 MARKING

- 8.1 Illegible
- 8.2 Damaged or missing dataplate

9.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTOR CONTROL CENTERS

CONTROL NUMBER: GSNS 0.09.01.02.06

APPLICATION

This guide applies to all non-standard inspection procedures for those devices normally used in assembly of low and medium Voltage motor control centers.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. Physical deficiencies require the motor control center to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low and medium Voltage motor control centers provide input to an analysis of functional and physical deficiencies of the low and medium Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with motor control centers are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 2.0 ENCLOSURE
 - 2.1 Interlock broken, missing, or inoperative as measured in protective device test
- 3.0 DISCONNECT
 - 3.1 Interlock broken, missing, or inoperative as measured in protective device test
 - 3.2 Mechanical trip broken, maladjusted, or **inoperative** as measured in protective device test
 - 3.3 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
 - 3.4 Adjustable settings maladjusted as measured in protective device test
 - 3.5 Does not trip on overcurrent in accordance with NFPA **70B** as measured in protective device test
 - 3.6 **UnderVoltage** trip missing, broken, maladjusted, or inoperative as measured in protective device test
 - 3.7 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
 - 3.6 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
 - 3.9 Time current characteristics not per manufacturer's specifications as measured in protective device test

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTOR CONTROL CENTERS (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.06

PHYSICAL DEFICIENCIES**3.0 DISCONNECT**

- 3.10 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 3.11 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 3.12 Series trip device missing, broken, or inoperative as measured in protective device test
- 3.13 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 3.14 Interlock broken, maladjusted, or inoperative as measured in protective device test
- 3.15 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
- 3.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.17 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 3.18 Contact pitted, burned, or discolored
- 3.19 Stationary contacts pitted, burned, or discolored
- 3.20 Phase barriers tracked, broken, cracked, missing, or other defect
- 3.21 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
- 3.22 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
- 3.23 Contacts not properly aligned

4.0 FUSE UNIT

- 4.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

5.0 PRESSURE RELIEF

- 5.1 High internal pressure
- 5.2 No internal pressure

6.0 CONTACTOR

- 6.1 Coil inoperative at 85% of rated Voltage in Voltage pickup test
- 6.2 Contacts burned, pitted, or other physical damage
- 6.3 Contact pressure not in accordance with manufacturer's specifications as measured with spring scale
- 6.4 Contacts not properly aligned
- 6.5 Arc suppression components broken, eroded, cracked, or missing
- 6.6 Dash pot inoperative, broken, or missing
- 6.7 Improper fluid in dash pot as measured in insulating liquid analysis test
- 6.8 Device sticks magnetically
- 6.9 Broken strands in braided shunts
- 6.10 Terminals, contact blocks, bus bars, and connectors loose or discolored
- 6.11 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 6.12 Rheostat contact surface corroded, oxidized, uneven, or other physical defect
- 6.13 Rheostat holding coil missing or inoperative
- 6.14 Improper rolling action of drum contacts
- 6.15 Drum contacts inadequately torqued

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MOTOR CONTROL CENTERS (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.06

PHYSICAL DEFICIENCIES

6.0 CONTACTOR

6.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test

7.0 HEATER

7.1 Sensing device broken, missing, or inoperative

7.2 Sensing device miscalibrated

7.3 Inadequate heater resistance to ground when measured by insulation resistance test

7.4 Heater inoperative

8.0 BUSHING/INSULATOR

8.1 Not adequately torqued to mounting surface

9.0 CONTROL WIRING

9.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test

9.2 Inadequately torqued at termination

10.0 BUS

10.1 Not properly torqued

10.2 Not adequately secured or braced

10.3 Resistance less than one megOhm between buses and/or from buses to non-energized parts as measured in insulation resistance test

10.4 Not adequately secured or braced

11.0 METERING

11.1 Metering does not conform to calibration standard

11.2 Device or indicators broken or inoperative

12.0 EQUIPMENT PROTECTION

12.1 Incorrect calibration of protective devices or sensors

12.2 Time delay suppression devices missing broken or inoperative

13.0 MARKING

14.0 TRANSFORMERS

Transformers encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.11.

15.0 PANELBOARDS

Panelboards encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.07.

16.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.10.

17.0 INSULATING LIQUID

17.1 Low liquid level

17.2 Liquid contaminated as measured in insulating liquid tests

INSPECTION METHODS ▪ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: MOTOR CONTROL CENTERS (Continued)****CONTROL NUMBER: GSNS 0.09.01.02.06****PHYSICAL DEFICIENCIES****18.0 LIGHTNING PROTECTION/SURGE PROTECTION DEVICES**

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: RACEWAY & FITTINGS

CONTROL NUMBER: GSNS 0.09.01.02.08

APPLICATION

This guide applies to all non-standard inspection procedures for raceway and fittings used in low or medium Voltage distribution system assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of raceway and fittings used in distribution systems provide an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of raceway and fittings are not addressed.

FUNCTIONAL DEFICIENCIES

Conductor fill in raceway exceeds amount allowed by NFPA 70 (National electrical code).

PHYSICAL DEFICIENCIES

- 1.0 RACEWAY
 - 1.1 Low conductivity when grounded conductor neutral test or equipment ground impedance test is performed
- 2.0 FITTING
- 3.0 MARKING
 - 3.1 Illegible
 - 3.2 Damaged or missing dataplate

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: SWITCHBOARD ASSEMBLY

CONTROL NUMBER: GSNS 0.09.01.02.09

APPLICATION

This guide applies to all non-standard inspection procedures for switchboard assemblies used as part of low and medium Voltage distribution systems. Switchboards used in medium Voltage systems are often referred to as switchgear.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the switchboard to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of switchboard assemblies used in low and medium Voltage distribution systems provide input to an analysis of functional and physical deficiencies of the low and medium Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with switchboards are not addressed.

PHYSICAL DEFICIENCIES

1.0 CONDUCTORS & FITTINGS

Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.

2.0 BUS

- 2.1 Joints not properly torqued
- 2.2 Not adequately secured or braced
- 2.3 Resistance less than one megOhm between buses and/or from buses to non-energized parts as measured in insulation resistance test
- 2.4 Not adequately secured or braced

3.0 ENCLOSURE

- 3.1 Interlock broken, missing, or inoperative as measured in protective device test

4.0 DISCONNECT

- 4.1 interlock broken, missing, or inoperative as measured in protective device test
- 4.2 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test
- 4.3 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 4.4 Adjustable settings maladjusted as measured in protective device test
- 4.5 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 4.6 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
- 4.7 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: SWITCHBOARD ASSEMBLY (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.09

PHYSICAL DEFICIENCIES

- 4.0 DISCONNECT
- 4.8 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 4.9 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 4.10 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 4.11 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 4.12 Series trip device missing, broken, or inoperative as measured in protective device test
- 4.13 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 4.14 Interlock broken, maladjusted, or inoperative as measured in protective device test
- 4.15 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
- 4.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 4.17 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 4.18 Contact pitted, burned, or discolored
- 4.19 Stationary contacts pitted, burned, or discolored
- 4.20 Phase barriers tracked, broken, cracked, missing, or other defect
- 4.21 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
- 4.22 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
- 4.23 Contacts not properly aligned
- 5.0 FUSE UNIT
- 5.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 6.0 PRESSURE RELIEF
- 6.1 High internal pressure
- 6.2 No internal pressure
- 7.0 HEATER
- 7.1 Sensing device broken, missing, or inoperative
- 7.2 Sensing device miscalibrated
- 7.3 Inadequate heater resistance to ground when measured by insulation resistance test
- 7.4 Heater inoperative
- 8.0 BUSHING/INSULATOR
- 8.1 Not adequately torqued to, mounting surface
- 9.0 CONTROL WIRING
- 9.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
- 9.2 Inadequately torqued at termination

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** SWITCHBOARD ASSEMBLY (Continued)**CONTROL NUMBER:** GSNS 0.09.01.02.09**PHYSICAL DEFICIENCIES****10.0 METERING****10.1** Metering does not conform to calibration standard

10.2 Device or indicators broken or inoperative

11.0 EQUIPMENT PROTECTION

11.1 Incorrect calibration of protective devices or sensors

11.2 Time delay suppression devices missing broken or inoperative

12.0 MARKING

12.1 Illegible

12.2 Damaged or missing dataplate

13.0 TRANSFORMERS

Transformers encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.11.

14.0 PANELBOARDS

Panelboards encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.07.

15.0 INSULATING LIQUID

15.1 Low liquid level

15.2 Liquid contaminated as measured in insulating liquid tests

16.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ▪ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFER SWITCHES

CONTROL NUMBER: GSNS 0.09.01.02.10

APPLICATION

This guide applies to all non-standard inspection procedures for switches with or without automatic control circuits.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the switch to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low and medium Voltage transfer switches provide input to an analysis of functional and physical deficiencies of the low and medium Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with switches are not addressed.

FUNCTIONAL DEFICIENCIES

Transfer switch transition is not appropriate for load.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 2.0 ENCLOSURE
 - 2.1 Interlock broken, missing, or inoperative as measured in protective device test
- 3.0 DISCONNECT
 - 3.1 Interlock broken, maladjusted, or inoperative as measured in protective device test
 - 3.2 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
 - 3.3 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
 - 3.4 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
 - 3.5 Contact pitted, burned, or discolored
 - 3.6 Stationary contacts pitted, burned, or discolored
 - 3.7 Phase barriers tracked, broken, cracked, missing, or other defect
 - 3.8 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
 - 3.9 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
 - 3.10 Contacts not properly aligned

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFER SWITCHES (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.10

PHYSICAL DEFICIENCIES**4.0 BUSHING/INSULATOR**

4.1 Inadequately torqued to mounting surface or device

5.0 SOLENOID

5.1 Coil inoperative at 85% of rated Voltage

5.2 Device sticks magnetically

5.3 Conductor or control wiring terminations not adequately torqued

6.0 CONTROL WIRING

6.1 Inoperative

6.2 Less than one megOhm resistance to ground as measured in insulation resistance test

6.3 Time delays not consistent with requirements as measured with timer

6.4 Improper sensor pickup or drop out point as measured with current test set

6.5 Inadequately torqued at termination

7.0 HEATER

7.1 Sensing device broken, missing, or inoperative

7.2 Sensing device malcalibrated

7.3 Inadequate heater resistance to ground when measured by insulation resistance test

7.4 Heater inoperative

8.0 METERING

8.1 Metering does not conform to calibration standard

8.2 Device or indicators broken or inoperative

9.0 MARKING

9.1 Illegible

9.2 Damaged or missing dataplate

10.0 INSULATING LIQUID

10.1 Low liquid level

10.2 Liquid contaminated as measured in insulating liquid tests

11.0 PRESSURE RELIEF

11.1 High internal pressure

11.2 No internal pressure

12.0 BUS

12.1 Not properly torque

12.2 Not adequately secured or braced

12.3 Resistance less than one megOhm between buses and/or from buses to non-energized parts as measured in insulation resistance test

12.4 Not adequately secured or braced

13.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: TRANSFORMERS****CONTROL NUMBER: GSNS 0.09.01.02.11****APPLICATION**

This guide applies to all non-standard inspection procedures for power and distribution transformers.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. Physical deficiencies require the transformer to be deenergized during the survey event.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of transformers provide an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of transformers are not addressed.

FUNCTIONAL DEFICIENCIES

1. Review historical records for frequency of circuit breaker trip reset operations or fuse replacement caused by overcurrent of unknown origin(s). Replacement or reset has occurred with frequency of:
 - One or more instances in last 3 months.
 - One or more instances in last month.
2. Excessive operational temperature.
3. Transformer is not appropriate for the load being served.

PHYSICAL DEFICIENCIES

- 1.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 2.0 **TRANSFORMER**
 - 2.1 Contaminated coils and core
 - 2.2 Loose cable connections
 - 2.3 Insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
 - 2.4 Ventilation vents dirty, clogged, or other contamination
 - 2.5 Open relief valve
 - 2.6 Inoperative relief valve
 - 2.7 Cooling fans inoperative
 - 2.8 Tap changer inoperative
 - 2.9 Pressure leaks as measured in pressure leak test
- 3.0 **ENCLOSURE**
 - 3.1 Interlock broken, missing, or inoperative as measured in protective device test

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: TRANSFORMERS (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.11

PHYSICAL DEFICIENCIES

- 4.0 HEATER
 - 4.1 Sensing device broken, missing, or inoperative
 - 4.2 Sensing device miscalibrated
 - 4.3 Heater resistance less than one megOhm per kiloVolt of rating when measured in insulation resistance test
 - 4.4 Heater inoperative
- 5.0 BUSHING/INSULATOR
 - 5.1 Not adequately torqued to mounting surface
- 6.0 EQUIPMENT PROTECTION
 - 6.1 Improper or inadequate primary protection device
 - 6.2 Improper or inadequate secondary protection device
 - 6.3 Improper or inadequate differential protection device
 - 6.4 Incorrect calibration of protective devices or sensors
 - 6.5 Time delay suppression devices missing broken or inoperative
- 7.0 METERING
 - 7.1 Metering does not conform to calibration standard
 - 7.2 Device or indicators broken or inoperative
- 8.0 CONTROL WIRING
 - 8.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
 - 8.2 Inadequately torqued at termination
- 9.0 MARKING
 - 9.1 Illegible
 - 9.2 Damaged or missing dataplate
- 10.0 INSULATING LIQUID
 - 10.1 Low liquid level
 - 10.2 Liquid contaminated as measured in insulating liquid tests
- 11.0 PRESSURE RELIEF
 - 11.1 High internal pressure
 - 11.2 No internal pressure
- 12.0 VENTILATION
 - 12.1 High operating temperature
 - 12.2 Inlets clogged
 - 12.3 Obstructed
 - 12.4 Location not ventilated
- 13.0 LIGHTNING PROTECTION & SURGE SUPPRESSION
 - Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08
- 14.0 DISCONNECTS
 - Disconnects encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.03.

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** TRANSFORMERS (Continued)**CONTROL NUMBER:** GSNS 0.09.01.02.11**TOOLS & MATERIALS**

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: SERVICE ENTRANCE ASSEMBLY

CONTROL NUMBER: GSNS 0.09.01 .01

APPLICATION

This guide applies to all non-standard inspection procedures for all service entrance assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of service entrance assemblies provides an analysis of functional and physical deficiencies of an electrical service entrance system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of service entrance assemblies are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 **BUSWAY**
Busways encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.01.
- 2.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control are encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 3.0 **DISCONNECTS**
Disconnects encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.03.
- 4.0 **METERING**
Metering encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.04.
- 5.0 **RACEWAY & FITTINGS**
Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.08.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LOW VOLTAGE DISTRIBUTION SYSTEM ASSEMBLY

CONTROL NUMBER: GSNS 0.09.01.02

APPLICATION

This guide applies to all non-standard inspection procedures for all low Voltage Distribution System assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low Voltage distribution System assemblies provides an analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of the assembly are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 **BUSWAY**
Busways encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.01.
- 2.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control are encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 3.0 **DISCONNECTS**
Disconnects encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.03.
- 4.0 **METERING**
Metering encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.04.
- 5.0 **MOTORS**
Motors encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.05.
- 6.0 **MOTOR CONTROL CENTER**
Motor control centers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.06.
- 7.0 **PANELBOARDS**
Panelboards encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.07.

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LOW VOLTAGE DISTRIBUTION SYSTEM ASSEMBLY (Continued)

CONTROL NUMBER: GSNS 0.09.01.02

PHYSICAL DEFICIENCIES

8.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.08.

9.0 SWITCHBOARDS

Switchboards encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.09.

10.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.10.

11 .O TRANSFORMERS

Transformers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.11.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: PANELBOARD ASSEMBLY****CONTROL NUMBER: GSNS 0.09.01.02.07****APPLICATION**

This guide applies to all non-standard inspection procedures for low Voltage panelboard assemblies as used in low Voltage distribution systems.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. Physical deficiencies require the panelboard to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of low Voltage panelboard assemblies provides input to an analysis of functional and physical deficiencies of the low Voltage distribution system. Because the system exists and is not in a construction process, regulatory deficiencies associated with panelboards are not addressed.

PHYSICAL DEFICIENCIES**1.0 CONDUCTORS & FITTINGS**

Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.

2.0 ENCLOSURE

- 2.1 Interlock broken, missing, or inoperative as measured in protective device test

3.0 DISCONNECT

- 3.1 Interlock broken, missing, or inoperative as measured in protective device test
- 3.2 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test
- 3.3 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 3.4 Adjustable settings maladjusted as measured in protective device test
- 3.5 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 3.6 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
- 3.7 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 3.8 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.9 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 3.10 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 3.11 Shunt trip device missing, broken, or inoperative as measured in protective device test

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PANELBOARD ASSEMBLY (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.07

PHYSICAL DEFICIENCIES

- 3.0 DISCONNECT
 - 3.12 Series trip device missing, broken, or inoperative as measured in protective device test
 - 3.13 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
 - 3.14 Interlock broken, maladjusted, or inoperative as measured in protective device test
 - 3.15 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
 - 3.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
 - 3.17 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
 - 3.18 Contact pitted, burned, or discolored
 - 3.19 Stationary contacts pitted, burned, or discolored
 - 3.20 Phase barriers tracked, broken, cracked, missing, or other defect
 - 3.21 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
 - 3.22 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
 - 3.23 Contacts not properly aligned
- 4.0 FUSE UNIT
 - 4.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 5.0 HEATER
 - 5.1 Sensing device broken, missing, or inoperative
 - 5.2 Sensing device miscalibrated
 - 5.3 Inadequate heater resistance to ground when measured by insulation resistance test
 - 5.4 Heater inoperative
- 6.0 BUSHING/INSULATOR
 - 6.1 Not adequately torqued to mounting surface
- 7.0 BUS
 - 7.1 Not properly torqued
 - 7.2 Resistance less than one megOhm between poles and/or from buses to non-energized parts as measured in insulation resistance test
 - 7.3 Discolored, warped, or other signs of high temperature
 - 7.4 Not adequately secured or braced
- 8.0 METERING
 - 8.1 Metering does not conform to calibration standard
 - 8.2 Device or indicators broken or inoperative
- 9.0 CONTROL WIRING
 - 9.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
 - 9.2 Inadequately torqued at termination
- 10.0 MARKING

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PANELBOARD ASSEMBLY (Continued)

CONTROL NUMBER: GSNS 0.09.01.02.07

PHYSICAL DEFICIENCIES**11.0 LIGHTNING PROTECTION & SURGE SUPPRESSION**

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ▪ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: MEDIUM VOLTAGE DISTRIBUTION SYSTEM ASSEMBLY****CONTROL NUMBER: GSNS 0.09.01.03****APPLICATION**

This guide applies to all non-standard inspection procedures for all Medium Voltage Distribution System Assemblies.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of medium Voltage distribution System assemblies provides an analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of the assembly are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 **BUSWAY**
Busways encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.01.
- 2.0 **CONDUCTORS & FITTINGS**
Conductors and fittings other than control are encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 3.0 **DISCONNECTS**
Disconnects encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.03.
- 4.0 **METERING**
Metering encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.04.
- 5.0 **MOTORS**
Motors encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.05.
- 6.0 **MOTOR CONTROL CENTER**
Motor control centers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.06.
- 7.0 **RACEWAY & FITTINGS**
Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.08.

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: MEDIUM VOLTAGE DISTRIBUTION SYSTEM ASSEMBLY

(Continued)

CONTROL NUMBER: GSNS 0.09.01.03

PHYSICAL DEFICIENCIES

8.0 SWITCHBOARDS (SWITCHGEAR)

Switchboards/switchgear encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.09.

9.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.10.

10.0 TRANSFORMERS

Transformers encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.02.11.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LUMINAIRES
CONTROL NUMBER: GSNS 0.09.02.01

APPLICATION

This guide applies to all non-standard inspection procedures for luminaires used in a lighting system and connected to the low Voltage distribution system.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The luminaire must be deenergized during this inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition assessment and evaluation of luminaires in a lighting system provides an input to the analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation of luminaires are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CONDUCTORS & FITTINGS
Conductors and Fittings, other than fixture wiring, encountered in the evaluation of this luminaire will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 2.0 CONTROL UNITS
Control Units encountered in the evaluation of this luminaire will be inspected in accordance with Guide Sheet GSNS 0.09.03.03.
- 3.0 RACEWAY & FITTINGS
Raceway and Fittings encountered in the evaluation of this luminaire will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.08.
- 4.0 HOUSING
 - 4.1 Not properly grounded
- 5.0 BALLAST
 - 5.1 Inappropriate for application
 - 5.2 Defective capacitor
 - 5.3 Not adequately secured
 - 5.4 Oil leakage
 - 5.5 Dirty, oily, greasy, or other surface contamination
 - 5.6 Transformer coils discolored, burned, or other signs of high temperature
 - 5.7 Corroded, rusted, dented, or other physical damage
 - 5.8 Not properly grounded
 - 5.9 Missing
 - 5.10 Improper and/or inadequate line Voltage
 - 5.11 Inoperative thermal protector

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LUMINAIRES (Continued)

CONTROL NUMBER: GSNS 0.09.02.01

PHYSICAL DEFICIENCIES

- 6.0 LAMP
 - 6.1 inadequate base to socket contact pressure
 - 6.2 Ignitor inoperative
 - 6.3 Ignitor inappropriate for application
 - 6.4 Blackening at end of arc tube
 - 6.5 Broken or cracked arc tube
- 7.0 LENS
- 8.0 REFLECTOR
- 9.0 SOCKET
 - 9.1 Inadequate socket contact pressure
 - 9.2 Pitted, burned, or discolored
 - 9.3 Inadequate termination
- 10.0 FIXTURE WIRING
 - 10.1 Inappropriate for application
 - 10.2 Bundled or trained inappropriately
 - 10.3 Inadequately torqued at termination
 - 10.4 Unauthorized splice
 - 10.5 Splice(s) improperly insulated
 - 10.6 Improper splice
 - 10.7 Insulation improperly removed from conductor
 - 10.8 Insulation charred, burned, or discolored
 - 10.9 insulation nicked, cut, cracked, or other physical damage
 - 10.10 Insulation resistance less than one megOhm per kiloVolt of rating when measured by insulation resistance test
- 11.0 GLOBE
 - 11.1 Dirty, oily, greasy, or other physical contamination
 - 11.2 Not adequately secured
 - 11.3 Missing, cracked, chipped, or other damage
 - 11.4 inappropriate for application
- 12.0 SAFETY GUARD
 - 12.2 Not adequately secured
 - 12.2 Missing, broken, or other damage
- 13.0 FIXTURE HANGER
 - 13.1 Inappropriate for application
 - 13.2 Not adequately secured
 - 13.3 Missing, broken, corroded, or other physical damage
- 14.0 MARKING
 - 14.1 Illegible
 - 14.2 Damaged or missing dataplate

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LUMINAIRES (Continued)

CONTROL NUMBER: GSNS 0.09.02.01

PHYSICAL DEFICIENCIES

15.0 BATTERY/APPLICATION

15.1 Improper liquid level

15.2 Corroded terminals

15.3 Low capacity

15.4 Cracked case

15.5 Leakage of electrolyte

15.6 Insufficient ampacity

15.7 Undercharged

15.8 Overcharged

15.9 Pressure release vent inoperative

16.0 BATTERY/CHARGER

16.1 Inappropriate for application

16.2 Not adequately secured

16.3 Not clean or moisture-free

16.4 Corroded, rusted, dented, or other physical damage

16.5 Top, bottom, or side covering missing

16.6 Abnormal output

17.0 DIMMER SWITCH

17.1 Discolored, burned, or other signs of high temperature

17.2 Not properly grounded

17.3 Inadequate capacity

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CABLE TRAY

CONTROL NUMBER: GSNS 0.09.03.01

APPLICATION

This guide applies to all non-standard inspection procedures for all cable tray assemblies.

SPECIAL INSTRUCTIONS

1. The surveyor will accomplish the standard methods survey in conjunction with this survey.
2. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
3. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
4. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

1. Annual preventive maintenance tasks.
2. Accomplish standard method inspection.

INSPECTION ACTIONS

Analysis of functional and physical deficiencies of an electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE TRAY
- 2.0 INSTALLATION
- 3.0 CONDUCTORS & FITTINGS
Conductors and fittings other than control wiring encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.
- 4.0 MARKING
- 5.0 PENETRATION
- 6.0 RACEWAY & FITTINGS
Raceway and fittings encountered in the inspection of the cable tray assembly will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.08.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: COMMUNICATION CIRCUITS

CONTROL NUMBER: GSNS 0.09.03.02

APPLICATION

This guide applies to all non-standard inspection procedures for communication systems and point-to-point communication systems wiring used in association with electrical systems. This guide does not apply to communication devices.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. Deenergize the systems served by the conductors to be inspected.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical systems used in conjunction with communication systems are part of a facility electrical system assessment. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 1.1 Conductor not adequately torqued at device connection
 - 1.2 Metallic sheath grounding inadequate as measured in equipment ground impedance test
- 2.0 FITTING
- 3.0 MARKING
 - 3.1 Illegible
 - 3.2 Damaged or missing dataplate
- 4.0 RACEWAY
Raceway will be inspected in accordance with Guide Sheet GSNS 0.09.03.02.
- 5.0 INSTALLATION
- 6.0 PENETRATION
- 7.0 LIGHTNING PROTECTION & SURGE SUPPRESSION
Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS . NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS

CONTROL NUMBER: GSNS 0.09.03.03

APPLICATION

This guide applies to non-standard inspection procedures for control units. It applies only to the unique facets of this system. Any part of the electrical system not unique to this system will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the system to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of control units or assemblies provide input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with control unit are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 FITTING
- 2.0 ENCLOSURE
 - 2.1 Interlock broken, missing, or inoperative as measured in protective device test
- 3.0 DISCONNECT
 - 3.1 Interlock broken, missing, or inoperative as measured in protective device test
 - 3.2 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test
 - 3.3 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
 - 3.4 Adjustable settings maladjusted as measured in protective device test
 - 3.5 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
 - 3.6 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
 - 3.7 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
 - 3.8 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
 - 3.9 Time current characteristics not per manufacturer's specifications as measured in protective device test
 - 3.10 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
 - 3.11 Shunt trip device missing, broken, or inoperative as measured in protective device test
 - 3.12 Series trip device missing, broken, or inoperative as measured in protective device test

 INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS (Continued)

CONTROL NUMBER: GSNS 0.09.03.03

PHYSICAL DEFICIENCIES

3.0 DISCONNECT

- 3.13 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 3.14 Interlock broken, maladjusted, or inoperative as measured in protective device test
- 3.15 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
- 3.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.17 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 3.18 Contact pitted, burned, or discolored
- 3.19 Stationary contacts pitted, burned, or discolored
- 3.20 Phase barriers tracked, broken, cracked, missing, or other defect
- 3.21 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
- 3.22 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
- 3.23 Contacts not properly aligned

4.0 FUSE UNIT

- 4.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

5.0 CABLE/CONDUCTOR

6.0 CONTACTOR

- 6.1 Coil inoperative at 85% of rated Voltage in Voltage pickup test
- 6.2 Contacts burned, pitted, or other physical damage
- 6.3 Contact pressure not in accordance with manufacturer's specifications as measured with spring scale
- 6.4 Contacts not properly aligned
- 6.5 Arc suppression components broken, eroded, cracked, or missing
- 6.6 Dash pot inoperative, broken, or missing
- 6.7 Improper fluid in dash pot as measured in insulating liquid analysis test
- 6.8 Device sticks magnetically
- 6.9 Broken strands in braided shunts
- 6.10 Terminals, contact blocks, bus bars, and connectors loose or discolored
- 6.11 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 6.12 Rheostat contact surface corroded, oxidized, uneven, or other physical defect
- 6.13 Rheostat holding coil missing or inoperative
- 6.14 Improper rolling action of drum contacts
- 6.15 Drum contacts inadequately torqued
- 6.16 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test

7.0 HEATER

- 7.1 Sensing device broken, missing, or inoperative
- 7.2 Sensing device miscalibrated
- 7.3 Inadequate heater resistance to ground when measured by insulation resistance test

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: CONTROL UNITS (Continued)

CONTROL NUMBER: GSNS 0.09.03.03

PHYSICAL DEFICIENCIES

- 7.0 HEATER
 - 7.4 Heater inoperative
- 8.0 BUSHING/INSULATOR
 - 8.1 Not adequately torqued to mounting surface
- 9.0 CONTROL WIRING
 - 9.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
 - 9.2 Inadequately torqued at termination
- 10.0 BUS
 - 10.1 Not properly torqued
 - 10.2 Not adequately secured or braced
 - 10.3 Resistance less than one megOhm between buses and/or from buses to non-energized parts as measured in insulation resistance test
 - 10.4 Not adequately secured or braced
- 11.0 EQUIPMENT PROTECTION
 - 11.1 Incorrect calibration of protective devices or sensors
 - 11.2 Time delay suppression devices missing broken or inoperative
- 12.0 MARKING
 - 12.1 Illegible
 - 12.2 Damaged or missing dataplate
- 13.0 TRANSFORMERS

Transformers encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.11.
- 14.0 PANELBOARDS

Panelboards encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.07.
- 15.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this device will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.10.
- 16.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08.
- 17.0 PHOTOCCELL
 - 17.1 Inoperative
 - 17.2 Not clean and moisture-free
 - 17.3 Inappropriate turn-off/turn-on ratio
 - 17.4 Discolored, burned, or other signs of high temperature

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: DATA PROCESSING ELECTRICAL EQUIPMENT

CONTROL NUMBER: GSNS 0.09.03.04

APPLICATION

This guide applies to all non-standard inspection procedures for electrical components, assemblies, or systems used in association with data processing equipment systems. This guide does not apply to the data processing equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical components, assemblies and systems used in conjunction with automatic data processing equipment are part of a facility electrical system assessment. This guide sheet focuses on the special or unique features of the electrical component, assembly, or system necessary to serve automatic data processing equipment and is to be used with other guides as appropriate. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 FACILITY
 - 1.1 Smoke and fire dampers, inoperative
- 2.0 CABLE/CONDUCTOR
 - 2.1 Inappropriate for application
 - 2.2 Insulation burned, charred, or other damage
 - 2.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 2.4 Unauthorized splice
 - 2.5 Not properly connected to device
 - 2.6 Insulation improperly removed from conductor
 - 2.7 Bimetallic connectors not used as required
 - 2.8 Not properly bundled or trained
- 3.0 GROUND CIRCUIT
- 4.0 MALAPROPOS DISCONNECT
- 5.0 MARKING
 - 5.1 Illegible
 - 5.2 Damaged or missing dataplate
- 6.0 PENETRATION
 - 6.1 Approved seals not used in boundaries.
- 7.0 **BUSWAY**

Busways encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.01.

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: CONDENSING UNITS (Continued)****CONTROL NUMBER: GSNS 0.08.04.04****INSPECTION ACTIONS****Shutdown Inspection:**

18. Note any inoperative motor starters.
19. Check conduit, control housings, and panels for corrosion, leakage.
20. Check wiring for loose connections. frayed or broken insulation.
21. Check electric controls for worn or pitted contacts, improper safety devices (heaters. fuses)

Return to Service:

22. Ensure that all tools, equipment and materials used for inspection have been removed from the unit.
23. Ensure that all parts, guards and covers have been reinstalled.
24. Notify affected personnel and obtain permission to place unit back in service.
25. Restore valving to normal position.
26. Remove lockout on disconnect and restore unit to service.
27. Remove tags from all devices

TOOLS & MATERIALS

1. Non-Standard Inspection Tools - Mechanical
2. As required for the test being performed.

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: COOLING TOWERS****CONTROL NUMBER: GSNS 0.08.04.05****APPLICATION**

This guide applies to all non-standard procedures for cooling towers and related components (fittings, valves, strainers, hangers, insulation, etc.) installed in HVAC Cooling Service and Distribution Systems.

SPECIAL INSTRUCTIONS

1. Review mechanical and electrical plans to determine systems and areas affected by equipment/system outage.
2. Review manufacturer's or installer's instructions.
3. Inspection should be scheduled when system is not in use.
4. Notify affected personnel and obtain permission to take unit out-of-service.
5. Obtain necessary tools, equipment, and materials.

CONCURRENT ACTIONS

Inspect associated:

- . Pipes & Accessories
- . Pumps
- . Condensers

INSPECTION ACTIONS

Condition Assessment Survey of Cooling Subsystems includes visual survey, examination of building records and analysis. Points include:

Prior to Shutdown:

1. Run unit through a complete operation cycle to identify malfunctioning components.

Unit Shutdown:

2. Power down the unit consistent with department procedure.
3. Isolate and lock out disconnects.
4. Tag out all electrical devices.
5. Isolate unit mechanically by securing water lines.
6. Tag out all secured valves.

Shutdown Inspection:

7. Drain tower thoroughly.
8. Remove access plates (tower should be thoroughly cleaned prior to inspection).
9. Inspect access plates. Note cracks, pitting, defective seals.
10. Check tower interior for corrosion, scale buildup.
11. Check screens, louvers, fill, and eliminators for erosion, corrosion, loose or broken fasteners.
12. Inspect fan assembly for loose or missing fasteners, blading distortion, imbalance.
13. Inspect drive reducer for loose or missing fasteners, leakage, worn gears.
14. Inspect drive shaft for loose or missing fasteners, worn bearings.
15. Check belt sheaves for wear, damage.
16. Inspect basin heating elements. Check for scaling, open elements,
17. Cycle all valves (manual and regulating). Check for smooth operation and positive seating.
18. Check wiring for loose connections, frayed or broken insulation.
19. Check electric controls for worn or pitted contacts, improper safety devices (heaters, fuses).

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: GENERATORS, STANDBY/EMERGENCY (Continued)

CONTROL NUMBER: GSNS 0.09.03.05

PHYSICAL DEFICIENCIES

4.0 ROTOR/STATOR

- 4.8 Shorted turns or coils in rotor as determined in rotating machinery test
- 4.9 Open turns or coils in stator as determined in rotating machinery test
- 4.10 Open turns or coils in rotor as determined in rotating machinery test
- 4.11 Noisy laminations in rotor or stator as measured in noise analysis test
- 4.12 Unbalanced rotor assembly as measured in vibration analysis test
- 4.13 Splice insulation is charred, brittle, discolored
- 4.14 Splice insulation unraveled, brittle, cracked, or other damage
- 4.15 Improper winding connections in rotor as determined in rotating machinery test
- 4.16 Improper winding connections in stator as determined in rotating machinery test
- 4.17 Non-uniform stator-rotor air gap as determined in rotating machinery test
- 4.18 Bent, scored, or other damage to rotor shaft as determined in rotating machinery test
- 4.19 Insulation resistance less than one megOhm per each kiloVolt of rating as measured in insulation resistance test
- 4.20 Broken or inoperative brush rigging assembly in stator as determined in rotating machinery test
- 4.21 Slip rings scored, bent, out-of-round, or other damage as determined in rotating machinery test
- 4.22 Improper connections to slip rings as determined in rotating machinery test
- 4.23 Commutator scored, bent, out-of-round, or other damage as determined in rotating machinery test
- 4.24 Improper connections to commutator as determined in rotating machinery test
- 4.25 Solid state device in rotor field circuit is open or shorted in resistance test
- 4.26 Solid state device in rotor field is not properly secured to mount

5.0 MOUNT

- 5.1 Bent or misshapen

6.0 EXHAUST SYSTEM

7.0 HEATER

- 7.1 Sensing device broken, missing, or inoperative
- 7.2 Sensing device miscalibrated when measured against standard
- 7.3 Inadequate heater resistance to ground when measured by insulation resistance test
- 7.4 Heater inoperative

8.0 MARKING

- 8.1 Illegible
- 8.2 Damaged or missing dataplate

9.0 DISCONNECT

- 9.1 Interlock broken, missing, or inoperative as measured in protective device test
- 9.2 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test
- 9.3 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 9.4 Adjustable settings maladjusted as measured in protective device test
- 9.5 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 9.6 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: GENERATORS, STANDBY/EMERGENCY (Continued)

CONTROL NUMBER: GSNS 0.09.03.05

PHYSICAL DEFICIENCIES

- 9.0 DISCONNECT
- 9.7 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test
- 9.8 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 9.9 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 9.10** Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 9.11 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 9.12 Series trip device missing, broken, or inoperative as measured in protective device test
- 9.13 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage

- 10.0 LIGHTNING PROTECTION & SURGE SUPPRESSION
Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08.

- 11.0 CONTROL WIRING
- 11.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
- 11.2 Inadequately torqued at termination
- 11.3 Time delays inconsistent when measured with timer
- 11.4 Improper sensor pickup or dropout value when measured against standard
- 11.5 Interlock inoperative

- 12.0 BUSHING/INSULATOR
- 12.1 Not adequately torqued to mounting surface

- 13.0 ENGINE
- 13.1 Low compression in any cylinder when measured with compression gauge
- 13.2 Defective injector spray pattern when measured in test unit
- 13.3 Overheats under full load
- 13.4 Does not reach operating temperature under full load at one hour
- 13.5 Low oil pressure after one hour at full load
- 13.6 Combustion air filter missing, defective, or dirty
- 13.7 Lube oil filter contaminated or dirty
- 13.8 Fuel filter missing, dirty, or wrong size or type
- 13.9 Lube oil does not meet specifications as determined in oil analysis
- 13.10 Engine coolant does not meet specifications as measured in laboratory analysis
- 13.11 Engine-alternator/generator alignment improper
- 13.12 Overspeed trip device missing or defective
- 13.13 Emergency shutdown device missing or defective

- 14.0 METERING
- 14.1 Calibration standard not established
- 14.2 Device broken or other physical defect
- 14.3 Tampering of device or circuit
- 14.4 Device inadequately sized

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: GENERATORS, STANDBY/EMERGENCY (Continued)****CONTROL NUMBER: GSNS 0.09.03.05****PHYSICAL DEFICIENCIES****14.0 METERING**

14.5 Device inoperative

15.0 EXCITER/VOLTAGE REGULATOR

15.1 Will not flash field

75.2 Will not establish rated Voltage

15.3 Will not maintain rated Voltage under no-load to full-load

15.4 Will not adjust output Voltage manually

15.5 Non-linear across load rating

15.6 Response fast, slow or atypical when subjected to step load change

16.0 TRANSFER SWITCH

If transfer switches are encountered in the inspection of this device then the transfer switch will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.10.

17.0 START SYSTEM

17.1 Air receivers discharged

17.2 Batteries discharged

17.3 Battery charger inoperative

17.4 Inoperative solenoid

17.5 Inoperative starter motor

17.6 Low air capacity

18.0 LOCAL FUEL SYSTEM

18.1 Control valves dysfunctional

18.2 Filters dirty, missing, wrong size

18.3 Fuel stale or old

18.4 Storage tank dented, rusted, or other damage

18.5 Water present

19.0 PENETRATION

19.1 Approved seals not used

20.0 ENCLOSURE

20.1 Interlock broken, missing, or inoperative as measured in protective test

21.0 FUSE UNIT

21.1 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: HEALTH CARE FACILITIES ELECTRICAL EQUIPMENT****CONTROL NUMBER: GSNS 0.09.03.06****APPLICATION**

This guide applies to all non-standard inspection procedures for electrical components, devices, assemblies, or systems used in association with health care systems. The guide does not apply to the health care system equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical components, devices, assemblies and systems used in conjunction with health care systems equipment are part of a facility electrical system assessment. This guide sheet focuses on the special or unique features of the electrical component, device, assembly, or system necessary to serve health care equipment and is to be used with other guides as appropriate. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 LOCATION
 - 1.1 Components not properly rated for location
 - 1.2 Storage device for flexible cable missing or defective
 - 1.3 Panelboard bonding not used or defective
 - 1.4 Transfer switches not present or adequate for essential service
 - 1.5 Essential system not adequately tested or maintained
 - 1.6 Potential difference between conductive surfaces exceeds 500 millivolt in general care area when frequency is less than one kilohertz as measured across a 1,000 Ohm resistance
 - 1.7 Potential difference between conductive surfaces exceeds 40 millivolt in critical care area when frequency is less than one kilohertz as measured across a 1,000 Ohm resistance
- 2.0 PENETRATION
- 3.0 ESSENTIAL SYSTEMS
 - 3.1 System will not operate when tested
 - 3.2 Unauthorized loads connected to emergency system
- 4.0 GROUNDING
 - 4.1 Panelboards not bonded together
- 5.0 CABLE/CONDUCTOR
 - 5.1 Inappropriate for application
 - 5.2 Insulation burned, charred, or other damage
 - 5.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 5.4 Unauthorized splice
 - 5.5 Not properly connected to device

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** HEALTH CARE FACILITIES ELECTRICAL EQUIPMENT (Continued)**CONTROL NUMBER:** GSNS 0.09.03.06**PHYSICAL DEFICIENCIES****5.0 CABLE/CONDUCTOR**

5.6 Insulation improperly removed from conductor

5.7 Bimetallic connectors not used as required

5.8 Not properly bundled or trained

6.0 MARKING

6.1 Illegible

6.2 Damaged or missing dataplate

7.0 INADEQUATE SERVICE**8.0 BUSWAY**

Busways encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.01.

9.0 CONDUCTORS & FITTINGS

Conductors and fittings used in association with this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.

10.0 DISCONNECTS

Disconnects encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.03.

11.0 PANELBOARDS

Panelboards encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.07.

12.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.08.

13.0 SWITCHBOARDS

Switchboards encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.09.

14.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.10.

15.0 TRANSFORMERS

Transformers encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.11.

16.0 LIGHTNING PROTECTION & SURGE SUPPRESSION

Lightning protection devices or surge suppressors encountered in the inspection of this equipment will be inspected in accordance with Guide Sheet GSNS 0.09.03.08.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** HEATING, BASEBOARD RADIATION**CONTROL NUMBER:** GSNS 0.09.03.07**APPLICATION**

This guide applies to non-standard inspection procedures for heating, baseboard radiation. It applies only to the unique facets of this system. Any part of the electrical system not unique in this system will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the system to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of baseboard radiation heating units or assemblies provide input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with baseboard radiation heating units are not addressed.

PHYSICAL DEFICIENCIES**1.0 CABLE/CONDUCTOR**

- 1.1 Inappropriate for application
- 1.2 Insulation burned, charred, or other damage
- 1.3 Splice insulation unraveled, brittle, cracked, or other damage
- 1.4 Unauthorized splice
- 1.5 Not properly connected to device
- 1.6 Insulation improperly removed from conductor
- 1.7 Bimetallic connectors not used as required
- 1.8 Not properly bundled or trained

2.0 ENCLOSURE

- 2.1 Not grounded properly when measured equipment ground test

3.0 DISCONNECT

- 3.1 Mechanical trip broken, maladjusted, or inoperative as measured in protective device test
- 3.2 Contacts burned, pitted, discolored, or other physical damage as measured in protective device test
- 3.3 Adjustable settings maladjusted as measured in protective device test
- 3.4 Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test
- 3.5 UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test
- 3.6 Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: HEATING, BASEBOARD RADIATION (Continued)

CONTROL NUMBER: GSNS 0.09.03.07

PHYSICAL DEFICIENCIES**3.0 DISCONNECT**

- 3.7 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.8 Time current characteristics not per manufacturer's specifications as measured in protective device test
- 3.9 Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test
- 3.10 Shunt trip device missing, broken, or inoperative as measured in protective device test
- 3.11 Series trip device missing, broken, or inoperative as measured in protective device test
- 3.12 Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage
- 3.13 Interlock broken, maladjusted, missing, or inoperative as measured in protective device test
- 3.14 Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test
- 3.15 Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test
- 3.16 Stationary contacts pitted, burned, or discolored
- 3.17 Phase barriers tracked, broken, cracked, missing, or other defect
- 3.18 Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test
- 3.19 Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored
- 3.20 Contacts not properly aligned

4.0 CONTROL WIRING

- 4.1 Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test
- 4.2 Inadequately torqued at termination

5.0 EQUIPMENT PROTECTION

- 5.1 Improper or inadequate protection device when measured in protective device test

6.0 MARKING

- 6.1 Illegible
- 6.2 Damaged or missing dataplate

7.0 INSTALLATION

- 7.1 Conductor or cable not appropriate for installation
- 7.2 Conductor or cable not listed
- 7.3 Hanger not adequately secured to structure
- 7.5 Inadequate grounding
- 7.6 Inadequate ventilation
- 7.7 Missing vertical run hardware
- 7.8 No bushing or equivalent protection
- 7.9 Not adequately protected from severe physical damage
- 7.10 Not adequately secured to mounting surface
- 7.11 Not appropriate for location
- 7.12 Not clearly and permanently marked where required
- 7.13 Not properly spaced from combustible materials

INSPECTION METHODS . NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** HEATING, BASEBOARD RADIATION (Continued)**CONTROL NUMBER:** GSNS 0.09.03.07**PHYSICAL DEFICIENCIES**

- 7.0 INSTALLATION
- 7.14 Not secured within three feet of end of run
- 7.15 Unauthorized conductor present
- 7.16 Unused openings not covered or plugged

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ▪ NON-STANDARD

THIS PAGE INTENTIONALLY LEFT BLANK

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LIGHTNING PROTECTION & SURGE SUPPRESSION

CONTROL NUMBER: GSNS 0.09.03.08

APPLICATION

This guide applies to non-standard inspection procedures for lightning protection & surge suppression. It applies only to the unique facets of these devices. The part of the electrical system in support of these devices will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.
4. The physical deficiencies require the system to be deenergized during the survey event.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of lightning protection/surge suppression devices provide an input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with lightning protection/surge suppression devices are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 CABLE/CONDUCTOR
 - 1.1 Inappropriate for application
 - 1.2 Insulation burned, charred, or other damage
 - 1.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 1.4 Unauthorized splice
 - 1.5 Not properly connected to device
 - 1.6 Insulation improperly removed from conductor
 - 1.7 Bimetallic connectors not used as required
 - 1.8 Not properly bundled or trained
- 2.0 CONNECTION
 - 2.1 Not connected to authorized ground point
 - 2.2 Metallic interconnection not used in grounding
- 3.0 LOCATION
- 4.0 PENETRATION
- 5.0 RATING
- 6.0 DEVICE
 - 6.1 Isolator has opened ground circuit
 - 6.2 Air horns bent, malformed, or other physical damage
 - 6.3 Fiber tube destroyed
 - 6.4 Thyrite discs broken, missing, or other physical damage
 - 6.5 Device not secured to mount

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: LIGHTNING PROTECTION & SURGE SUPPRESSION

(Continued)

CONTROL NUMBER: GSNS 0.09.03.08

PHYSICAL DEFICIENCIES

- 6.0 DEVICE
- 6.6 Dirty, oily, greasy, or other surface contamination
- 7.0 MARKING
- 7.1 Illegible
- 7.2 Damaged or missing dataplate

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PETROLEUM DISPENSING FACILITIES ELECTRICAL EQUIPMENT

CONTROL NUMBER: GSNS 0.09.03.09

APPLICATION

This guide applies to all non-standard inspection procedures for electrical components, devices, assemblies, or **systems used** in association with petroleum dispensing station systems. This guide does not apply to the petroleum dispensing station system equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical components, devices, assemblies and systems used in conjunction with petroleum dispensing station systems equipment are part of a facility electrical system assessment. This guide sheet focuses on the special or unique features of the electrical component, device, assembly, or system necessary to serve petroleum dispensing facilities electrical equipment and is to be used with other guides as appropriate. Because the system exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 DEVICE APPLICATION
- 2.0 CABLE/CONDUCTOR
 - 2.1 Inappropriate for application
 - 2.2 Insulation burned, charred, or other damage
 - 2.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 2.4 Unauthorized splice
 - 2.5 Not properly connected to device
 - 2.6 Insulation improperly removed from conductor
 - 2.7 Bimetallic connectors not used as required
 - 2.8 Not properly bundled or trained
- 3.0 ENCLOSURE
 - 3.1 Not adequate for application
 - 3.2 Corroded, rusted, dented, or other physical damage
 - 3.3 Not secured to mounting surface
 - 3.4 Unused openings **not covered or plugged**
 - 3.5 **Not grounded properly**
 - 3.6 **Pedestal mounting surface chipped, cracked, broken, or other physical damage**
 - 3.7 **Not accessible**
 - 3.8 **Vent defective/nonoperative**
 - 3.9 **Oil leak**
 - 3.10 **No curbing or berm for oil containment**
 - 3.11 **Not clean and moisture-free**

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: PETROLEUM DISPENSING FACILITIES ELECTRICAL EQUIPMENT

(Continued)

CONTROL NUMBER: GSNS 0.09.03.09

PHYSICAL DEFICIENCIES

4.0 LOCATION

5.0 MARKING

5.1 Illegible

5.2 Damaged or missing dataplate

6.0 PENETRATION

7.0 SEAL

8.0 UNDERGROUND WIRING

9.0 BUSWAY

Busways encountered in the inspection of the Petroleum Dispensing Facilities Electrical Equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.01.

10.0 CONDUCTORS & FITTINGS

Conductors and fittings used in association with Petroleum Dispensing Facilities Electrical Equipment will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.02.

11.0 DISCONNECTS

Disconnects encountered in the inspection will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.03.

12.0 PANELBOARDS

Panelboards encountered in the inspection be inspected in accordance with Guide Sheet GSNS 0.09.01.02.07.

13.0 RACEWAY & FITTINGS

Raceway and fittings encountered in the inspection will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.08.

14.0 SWITCHBOARDS

Switchboards encountered in the inspection will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.09.

15.0 TRANSFER SWITCHES

Transfer switches encountered in the inspection will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.10.

16.0 TRANSFORMERS

Transformers encountered in the inspection will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.11.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: SIGNAL CIRCUITS

CONTROL NUMBER: GSNS 0.09.03.10

APPLICATION

This guide applies to all non-standard inspection procedures for signal circuits and point-to-point wiring of the signal circuit used in association with electrical systems. This guide does not apply to the connected equipment.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize circuit interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Annual preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of electrical systems used in conjunction with signal circuits are part of a facility electrical system assessment. Since the circuit exists and is not in a construction process, regulatory deficiencies associated with installation are not addressed.

PHYSICAL DEFICIENCIES

- 1.0 OVERCURRENT DEVICE
 - 1.1 Conductors less than 14 AWG not properly protected when measured by protective device test
 - 1.2 Improperly sized at more than 167% of source when measured by protective device test
- 2.0 RATING
 - 2.1 More than 20 Amperes available at full load test with load bank
 - 2.2 System rating exceeds 30 Volts and 1000 Volt-Amperes available to load when measured at load bank
 - 2.3 Non-transformer source rating exceeds 2500 Volt-Amperes when measured with load bank
- 3.0 FITTING
- 4.0 MARKING
- 5.0 RACEWAY & FITTINGS
 - Raceway and fittings encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.08.
- 6.0 LIGHTNING PROTECTION & SURGE SUPPRESSION
 - Lightning protection devices or surge suppressors encountered in the inspection of this system will be inspected in accordance with Guide Sheet GSNS 0.09.03.08.
- 7.0 CABLE/CONDUCTOR
 - 7.1 Inappropriate for application
 - 7.2 Insulation burned, charred, or other damage
 - 7.3 Splice insulation unraveled, brittle, cracked, or other damage
 - 7.4 Unauthorized splice
 - 7.5 Not properly connected to device
 - 7.6 insulation improperly removed from conductor

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT:** SIGNAL CIRCUITS**CONTROL NUMBER:** GSNS 0.09.03.10**PHYSICAL DEFICIENCIES**

- 7.0 CABLE/CONDUCTOR
- 7.7 Bimetallic connectors not used as required
- 7.8 Not properly bundled or trained

8.0 PENETRATION

9.0 POWER SUPPLY

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed.

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES

CONTROL NUMBER: GSNS 0.09.03.11

APPLICATION

This guide applies to non-standard inspection procedures for uninterruptible power supplies. It applies only to the unique facets of these devices. The part of the electrical system in support of these devices will be evaluated in accordance with the applicable method found elsewhere in this volume.

SPECIAL INSTRUCTIONS

1. Review as-builts and other documentation to ensure that all interlocks are known prior to initiating the inspection process.
2. Schedule this inspection to coincide with programmed maintenance activities to minimize system interruption and downtime.
3. Review all operating history documentation prior to inspection.

CONCURRENT ACTIONS

Preventive maintenance tasks.

INSPECTION ACTIONS

Condition Assessment Survey and evaluation of Uninterruptible Power Supplies provide an input to an analysis of functional and physical deficiencies of the facility electrical system. Because the system exists and is not in a construction process, regulatory deficiencies associated with Uninterruptible Power Supplies are not addressed.

PHYSICAL DEFICIENCIES**1.0 BATTERY/APPLICATION**

- 1.1 Low capacity when time tested with load bank
- 1.2 Corroded terminals when connectors are removed

2.0 CABLE/CONDUCTOR

- 2.1 Terminations not properly torqued

3.0 MOTOR APPLICATION**4.0 MOTORS**

Motors encountered in this inspection will be evaluated in accordance with guide sheet GSNS 0.09.02.05.

5.0 BEARINGS**6.0 METERING**

- 6.1 Calibration standard not established
- 6.2 Device broken or other physical defect
- 6.3 Tampering of device or circuit
- 6.4 Device inadequately sized
- 6.5 Device inoperative

7.0 MARKING

Metering will be inspected in accordance with Guide Sheet GSNS 0.09.01.02.04.

8.0 BUSHING/INSULATOR

- 8.1 Not adequately torqued to mounting surface

INSPECTION METHODS - NON-STANDARD

GUIDE SHEET

SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES (Continued)

CONTROL NUMBER: GSNS 0.09.03.11

PHYSICAL DEFICIENCIES**9.0 CONTROL WIRING****9.1** Control wiring insulation less than one megOhm per kiloVolt of rating when measured by insulation resistance test**9.2** Inadequately torqued at termination**10.0 DEVICE APPLICATION****11.0 DISCONNECT****11.1** Mechanical trip broken, maladjusted, or inoperative as measured in protective device test**11.2** Contacts burned, pitted, discolored, or other physical damage as measured in protective device test**11.3** Adjustable settings maladjusted as measured in protective device test**11.4** Does not trip on overcurrent in accordance with NFPA 70B as measured in protective device test**11.5** UnderVoltage trip missing, broken, maladjusted, or inoperative as measured in protective device test**11.6** Resistance less than one megOhm between poles and/or from poles to non-energized parts as measured in insulation resistance test**11.7** Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test**11.8** Time current characteristics not per manufacturer's specifications as measured in protective device test**11.9** Does not sustain rated current in accordance with NFPA 70B as measured in sustained current test**11.10** Shunt trip device missing, broken, or inoperative as measured in protective device test**11.11** Series trip device missing, broken, or inoperative as measured in protective device test**11.12** Arc suppression device broken, cracked, missing, tracked, chipped, or other physical damage**11.13** Interlock broken, maladjusted, missing, or inoperative as measured in protective device test**11.14** Low resistance between adjacent poles or from a pole to ground as measured in insulation resistance test**11.15** Individual pole resistance does not meet manufacturer's specifications as measured in contact resistance test**11.16** Stationary contacts pitted, burned, or discolored**11.17** Phase barriers tracked, broken, cracked, missing, or other defect**11.18** Transfer time not in accordance with manufacturer's specifications as measured in time travel analysis test**11.19** Terminals, contact blocks, bus bar, and connectors loose, burned, or discolored**11.20** Contacts not properly aligned**12.0 ENCLOSURE****13.0 EXCITER/VOLTAGE REGULATOR****14.0 FITTING****15.0 FUSE UNIT**

INSPECTION METHODS ■ NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES (Continued)****CONTROL NUMBER: GSNS 0.09.03.11****PHYSICAL DEFICIENCIES****16.0 HEATER**

- 16.1 Sensing device broken, missing, or inoperative
- 16.2 Sensing device miscalibrated
- 16.3 Inadequate heater resistance to ground when measured by insulation resistance test
- 16.4 Heater inoperative

17.0 MOUNT

- 17.1 Bent or misshapen

18.0 RECTIFIER/INVERTER**19.0 ROTOR/STATOR**

- 19.1 Not clean and moisture-free
- 19.2 Bent shaft
- 19.3 Parted laminations
- 19.4 Scored shaft
- 19.5 Stator windings burned, charred, or other signs of high temperature
- 19.6 Rotor windings burned, charred, or other signs of high temperature
- 19.7 Shorted turns or coils in stator as determined in rotating machinery test
- 19.8 Shorted turns or coils in rotor as determined in rotating machinery test
- 19.8 Open turns or coils in stator as determined in rotating machinery test
- 19.10 Open turns or coils in rotor as determined in rotating machinery test
- 19.11 Noisy laminations in rotor or stator as measured in noise analysis test
- 19.12 Unbalanced rotor assembly as measured in vibration analysis test
- 19.13 Splice insulation is charred, brittle, discolored
- 19.14 Splice insulation unraveled, brittle, cracked, or other damage
- 19.15 Improper winding connections in rotor as determined in rotating machinery test
- 19.16 Improper winding connections in stator as determined in rotating machinery test
- 19.17 Non-uniform stator-rotor air gap as determined in rotating machinery test
- 19.18 Bent, scored, or other damage to rotor shaft as determined in rotating machinery test
- 19.19 Insulation resistance less than one megOhm per each kiloVolt of rating as measured in insulation resistance test
- 19.20 Broken or inoperative brush rigging assembly in stator as determined in rotating machinery test
- 19.21 Slip rings scored, bent, out-of-round, or other damage as determined in rotating machinery test
- 19.22 Improper connections to slip rings as determined in rotating machinery test
- 19.23 Commutator scored, bent, out-of-round, or other damage as determined in rotating machinery test
- 19.24 Improper connections to commutator as determined in rotating machinery test
- 19.25 Solid state device in rotor field circuit is open or shorted in resistance test
- 19.26 Solid state device in rotor field is not properly secured to mount

20.0 ALTERNATORS/GENERATORS

Alternators or generators encountered in this inspection will be evaluated using guide sheet GSNS 0.09.03.05.

21.0 TRANSFER SWITCHES

Transfer switches encountered in this inspection will be evaluated using guide sheet GSNS 0.09.01.02.10.

INSPECTION METHODS • NON-STANDARD

GUIDE SHEET**SYSTEM/COMPONENT: UNINTERRUPTIBLE POWER SUPPLIES (Continued)****CONTROL NUMBER: GSNS 0.09.03.11****PHYSICAL DEFICIENCIES****22.0 TRANSFORMERS**

Transformers encountered in this inspection will be evaluated using guide sheet GSNS 0.09.01.02.11.

23.0 DISCONNECTS

Disconnects encountered in this inspection will be evaluated using guide sheet GSNS 0.09.01 .02.03.

TOOLS & MATERIALS

1. Non-Standard Inspection Tools
2. As required for the test being performed

END OF SUBSECTION

DATA COLLECTION METHODS

GENERAL

The heart of the CAS System is built around the hand-held data collection device and the CAIS software that supports it. As discussed in the Introduction, this is a “new way” of seeing and recording specific standardized information. Several phases are involved in the CAS inspection process. They include:

PHASE 1

PRESURVEY

- Facility managers review assets and assign each an Asset Determinant Factor (ADF) to define the level and type of inspection to be accomplished (see Subsection 1 .1 for definition).
- Facility managers assign specific assets to CAS inspectors.
- The CAS Inspector reviews existing asset data (including as-builts and past repair reports) and the Work Breakdown Structure (WBS) systems requiring inspection, which are then subdivided as necessary. (For example, a large roof may be subdivided into four (4) WBS items such as North, South, East and West sections.)
- The inspector establishes the Inspection Units (IU) to be surveyed based on the WBS (or multiple WBS). IUs may also be added in the field.
- Facility manager and/or staff downloads asset data into the hand-held data collection device.

PHASE 2

SURVEY

- Conduct CAS inspection.
- Upload data into PC-based CAIS.
- Review raw data “universal” reports.

PHASE 3

POSTSURVEY

- Correct data, as necessary, issue final “universal” report, and create other required reports for facility managers.
- Data and reports are created and issued through DOE hierarchy (see Introduction).

DATA COLLECTION METHODS

ENTERING DATA: DATA COLLECTION MENU

SURVEY STEP: **LOGIN**

SCREEN 1.0

The screen contains identification data including the inspector's name, ID number, and discipline to be inspected. This data may be input or preloaded. From this screen, several information and help pop-up aids can be accessed. Help functions would provide screen-specific instructions, and information functions would list special management instructions and/or schedules specifically for the inspector.

SURVEY STEP: ASSET IDENTIFICATION

SCREEN 2.0

Asset identification including class, type, ADF number (see subsection 1.1 for ADF description), and asset ID numbers are captured on this screen. Pop-up screens with preformatted picklists (for type and class) are provided for the inspector's review and selection. Additional support screens include ASSET DIMENSIONS indicating key elements required for inspection (such as asset gross square footage, perimeter, height, etc.); and ASSET DESCRIPTION for recording asset name and address. Such information would be entered (or verified) by the inspector prior to the actual asset CAS inspection.

SURVEY STEP: WBS SELECTION

SCREEN 3.0

This screen displays the preselected systems and WBS listings based on the ADF selected for the particular asset. Although all WBS assemblies for a system will be listed, the inspector selects only assemblies applicable to the specific asset. For example, although all system 0.05 Roof WBS categories are listed, the inspector would eliminate all non-applicable categories by "de-selecting" non-applicable items. Once this process is complete, the inspector can re-sort the included WBS items. Columns are also provided that indicate the survey status for each WBS item.

At this point, the inspector can subdivide the WBS. For example, the inspector may elect to split a large roof into four sections, each as a separate WBS, or isolate a pump from a WBS containing several pumps. This feature will allow the inspector to logically build his survey based on the unique properties and requirements of each asset.

Finally, while most WBS structuring will be accomplished prior to the CAS inspection, WBS subdivision can also be done in the field.

DATA COLLECTION METHODS

ENTERING **DATA:** DATA **COLLECTION** MENU (Continued)

SURVEY STEP: INSPECTION **UNIT (IU)** SELECTION

SCREEN 4.0

While screen 3.0 defines the WBS structure, screen 4.0 concerns selecting the IU for each WBS category. In the CAIS software, the base CAS (see subsection 1.1 for definition) is preset at the assembly level for all systems. For example, a WBS Roof System, Built-up Membrane Roofing (0.05.01), is set at the assembly level. At this point the inspector would select the type of assembly based on a preselected picklist. (Such a picklist at the assembly level might include various roof assembly groupings; eg., 3 to 5-ply asphalt with gravel coating and composite insulation.) If a more detailed inspection is required, the inspector would "de-select" the base CAS assembly level by crossing through the LVL Box "Assy." This action would bring up the next level "component." In our roof example, this would mean that the inspector would now assess the membrane, flashing, and insulation as separate components. As with the assembly level, the inspector would choose a type from a selected picklist for each component. Although IUs are usually determined prior to the survey, multiple IUs may also be developed during the inspection. For example, a WBS of the south quadrant built-up roof may be divided into two IUs (eg., sw corner and remaining roof) if the inspector chooses to highlight and isolate some abnormal conditions from the main IU.

Additional information developed on this screen would include the percentage of WBS served by the IU, the estimated quantity (this figure will also be independently generated by CAIS status (see subsection 1.1), estimated life remaining useful without repair (WOR), and estimated age.

SURVEY STEP: DEFICIENCY ASSESSMENT

SCREEN 4.1

With the WBS and IU established, the inspector now conducts the CAS inspection for each WBS IU. As the inspector surveys the asset, a preformatted picklist containing all deficiencies that may affect the particular WBS IU is reviewed. The default setting shows a zero in each coverage block, indicating no deficiencies. As the survey proceeds, the inspector "de-selects" this normal setting by entering a percentage of coverage under condition categories listed (light, moderate, severe, and fail). For example, inspector entries for WBS roofing, IU built-up membrane, deficiency "splitting" of 10% light, 0% moderate, 0% severe, 0% fail, would be interpreted by CAIS software as 90% normal, and light splitting occurring over 10% of the membrane. If the inspector cannot determine the condition using standard inspection methods, he can indicate the need for a non-standard inspection (NSIP) by de-selecting the "NO" in the NSIP column. To complete the inspection, the aforementioned procedures would be carried out for each deficiency noted by the inspector.

DATA COLLECTION METHODS

ENTERING DATA: DATA COLLECTION MENU (Continued)

SURVEY STEP: SUMMARY CONDITION ASSESSMENT SCREEN 5.0

This final screen summarizes the WBS IU in three major categories: urgency, purpose, and condition. In each category, the inspector will call up a picklist and select the category he feels is most appropriate for the WBS IU surveyed. (For the purpose category, the inspector may select multiple headings.) Additionally, the inspector may elect to enter an estimated cost and/or quantity. (This is optional as CAIS will generate these data based on the inspector's survey information.) The inspector will also enter an estimated remaining life post-repair. As an option, a work order may be generated based on the CAS survey information. This option is generated by selecting the WORK ORDER function key and filling out pertinent data. Finally, the inspector may choose to describe the repair more fully by selecting the REPAIR CHARACTER key.

After completing all WBS IUs, the CAS inspection for the system is complete. This procedure is repeated for each applicable system. Once all systems for the asset are complete, the information is uploaded to the PC-based CAIS program for data analysis and report generation.

In the remainder of this subsection, actual data screens, as they will appear to the inspector, are displayed to illustrate a typical inspection. As previously noted, five main screens are used in the system supported by numerous "pop-up" lists, information, comment, and other auxiliary screens. In our examples, main screens are numbered 1.0 - 5.0; secondary screens are labeled 1.1 , 1.2, etc.; and general support screens use the series 99.0. Key inspector actions on each screen are highlighted. Support function keys are listed below these main functions.

SURVEY STEP LOGIN

Screen 1.0

SCREEN	ACTION	COMMENT
1.0	1. Enter Name and Employee Id #	May be preloaded for security
	2. Tap "Discipline" title for picklist, cursor select or enter by pen	Picklist preformatted A=Arch, C=Site/Civil, E=Elec, M=Mech
	3. Tap "Type" and "Vers" title under Survey Data for picklist cursor select or enter by pen	Picklist preformatted for type of survey to be performed and version date for record
	4. Diagnostics data is system generated and for information purposes only	N/A
	5. Press (Continue) to go to Screen 2.0	By pressing (Continue) information is verified; corrections made by crossing through data and entering new information.
	(Help) (Comment) (L/RH) (<Exec>) (DataXfer) (Hotline) (InfoList)	Press to bring up screen help Screen 99.1 Press to bring up screen for entering inspector comments Screen 99.2 Press to change screen between Left or Right Hand use N/A Press to exit to the Grid System Menu This option can be password protected Press to transfer data to site computer Used for data upload/download procedures Press for important contacts and telephone numbers Screen 99.3 Press to bring up information/directions preloaded for inspector Screen 99.4

SURVEY STEP ASSET IDENTIFICATION

Screen 2.0

S C R E E N	ACTION	COMMENT
2.0	1. Tap "Site" title for picklist Cursor select or enter by pen	Picklist can be preloaded, site code appears automatically to match name selected
	2. Tap "Class" title for picklist Cursor select or enter by pen or skip to item 4	Picklist preformatted based on RPIS categories
	3. Tap "Use Cd" title for picklist Cursor select or enter by pen or skip to item 4	Picklist preformatted based on RPIS categories
	4. Enter Asset Identification information by selecting "CAS Asset Id" corresponding "RPIS Prpty Id" and "Name-1 or Name-2" will be generated	This data can be preloaded
	5. Enter a Split Asset by creating an extension to "CAS Asset ID" and selecting a new name	This data can be preloaded or created by inspector
	6. Enter Asset Determinant Factor "ADF" provided by Site Mgr.	Determined by Site Manager prior to survey
	7. Press box next to Survey Complete upon completion of Asset Survey	N/A
	8. Press Continue to go to Screen 3.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information
Escape	Press to return to Screen 1.0	By pressing Escape information is not verified and any changes made are lost
Help	Press to bring up screen help	Screen 99.1
Comment	Press to bring up screen for entering inspector comments	Screen 99.2
Logout	Press to save all data entered and leave survey	N/A
Custody	Press to bring up asset contact names	Screen 2.1 This data can be preloaded
AssetDim	Press to bring up screen for entering or verifying key asset dimensions	Sawn 2.2 This data can be preloaded
AssetDes	Press to bring up screen for entering or verifying asset name, address and descriptions	Screen 2.3 This data can be preloaded
HotLine	Press for important contacts and telephone numbers	Sawn 99.3
InfoList	Press to bring up information/directions preloaded for inspector	Sawn 99.4

SURVEY STEP ASSET CUSTODY SCREEN

Screen 2.1

The screenshot shows a terminal window titled "Asset Identification" with a sub-window titled "Asset Custody". The sub-window contains the following data:

Role	Name	Telephone	Ext
Manager	PETER JONES	615-555-5555	1234
Custodian	JOHN TURNER	615-555-5555	4321
Maint Mgr	BILL NORRIS	615-555-5555	5525
Asset Coord	SUSAN BROWN	615-555-5555	5675
CAS A		- -	
Name		- -	
Name		- -	

Navigation buttons include "Escape", "Continue", "List", "Line", "Desc", "Din", "Body", "ete", "Out", "ment", and "lp".

S C R E E N	ACTION	COMMENT
2.1	1. Pop-up window displays important names and numbers for asset. Cross through data and make any changes	Data can be either preloaded or inspector generated.
	2. Press Continue to return to Screen 2.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information.
Escape	Press to return to Screen 2.0	By pressing Escape information is not verified and any changes made are lost.

SURVEY STEP ASSET DIMENSIONS

Screen 2.2

Asset Dimensions

Net Occupiable Space	<input type="text" value="250000"/>	SqFt
Stories Above Ground	<input type="text" value="5"/>	Stories
Footprint	<input type="text" value="50000"/>	SqFt
Roof	<input type="text" value="50000"/>	SqFt
Perimeter	<input type="text" value="325"/>	LnFt
Basement Below Ground	<input type="text" value="0"/>	Levels
Story Heights	<input type="text" value="12"/>	LnFt
Parapet Height	<input type="text" value="2"/>	LnFt
Interior/Exterior Wall	<input type="text" value="80"/>	Ratio
Window/Exterior Wall	<input type="text" value="40"/>	Ratio
Roof Pitch	<input type="text" value="25"/>	Ratio

Navigation buttons: **Escape**, **Next Page**, **Prior Page**, **Continue**

SCREEN	ACTION	COMMENT
2.2	1. Screen displays important dimension related to the asset verify data or cross through data and make any changes	Data can be either preloaded or inspector generated.
	2. Press Continue to return to Screen 2.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information.
Escape	Press to return to Screen 2.0	By pressing Escape information is not verified and any changes made are lost.
NextPage	Press to bring up next screen of important dimensions	Data can be either preloaded or inspector generated.
PriorPage	Press to return to previous asset dimension screen	Data can be either preloaded or inspector generated.


SURVEY STEP ASSET DESCRIPTION

Screen 2.3

SCREEN	ACTION	COMMENT
2.3	1. Screen displays important asset description information verify data or cross through and make changes	Data can be either preloaded or inspector generated
	2. Press Continue to return to Screen 2.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information
Escape	Press to return to Screen 2.0	By pressing Escape information is not verified and any changes made are lost
NextPage	Press to bring up next screen of important descriptions	Data can be either preloaded or inspector generated
PriorPage	Press to return to previous asset description screen	Data can be either preloaded or inspector generated

SURVEY STEP WBS SELECTION


Screen 3.0



SCREEN	ACTION	COMMENT
3.0	1. Select WBS item to inspect from picklist	Picklist preformatted and is presorted by ADF numbers. Columns at end of WBS list show: "Inc" (included) by sort order 1,2,3...; "M" (multiple items); and "Stat" (Status) (In Progress, Complete, or Not Started [?])
	2. All WBS for ADF included on screen, cross through number in "Inc" column to deselect	By crossing through "Inc" number, WBS item is deselected
	3. Press (Continue) to go to Screen 4.0	By pressing (Continue) information is verified and inspections units under the selected WBS are loaded
(Escape)	Press to return to Screen 2.0	By pressing (Escape) information is not verified and any changes made are lost.
(Help)	Press to bring up screen help	screen 99.1
(Comment)	Press to bring up screen for entering inspector comments	Screen 99.2
(Logout)	Press to save all data entered and leave survey	N/A
(Multi WBS)	Press to create, view or select multiple WBS and locations	Screen 3.1
(CalcSort)	Press to re-calculate the status of or number of multiple locations	N/A
(SetSort)	Resets the sort sequence of systems, etc. by accessing a pop-up window	N/A
(Resort)	Press to resort list in order of priority of WBS items selected	N/A
(HotLine)	Press for important contacts and telephone numbers	Screen 99.3
(InfoList)	Press to bring up information/directions preloaded for inspector	sawn 99.4
(Scroll Up)	Press Scroll Up button	Used to scroll up through information.
(Scroll Down)	Press Scroll Down button	used to scroll down through information.

SURVEY STEP CREATE/REVIEW/SELECT MULTIPLE WBS

Screen 3.1



SCREEN	ACTION	COMMENT
3.1	1. Define locations of multiple WBS. Could be multiple systems or multiple parts of single system.	Inspector developed
	2. Define percentage of Asset serviced by WBS section	Inspector developed
	3. Press Continue after selecting multiple WBS locations from list and continue to Screen 4.0 to select Inspection Unit (IU).	By pressing Continue information is verified; corrections made by crossing through data and entering new information or selecting another item
Escape	Press to return to Screen 3.0	By pressing Escape information is not verified and any changes made are lost
RtrnWBS	Press to return to WBS selection screen to make additional selections	N/A
Delete	Press to delete a highlighted entry on screen	N/A
	Press scroll up button	Used to scroll up through information.
	Press scroll down button	Used to scroll down through information.

SURVEY STEP IU SELECTION

Screen 4.0

IU Selection

WBS
 Loc
 IU
 Loc

IU Level/Component/Type **IU status**
 Insp Interval Years Est Life WOR Yrs
 Cmp Est Yr Inst
 Typ Status
 Service

IU Quantity @ Location
 IU Qty as Percent of WBS %
 IU Qty @ Loc U/M Reqd

SCREEN	ACTION	COMMENT
4.0	1. Tap "Cmp" title for component picklist Cursor select or enter by pen	Picklist is preformatted
	2. Tap "Typ" title for type of component picklist Cursor select or enter by pen	Picklist is preformatted
	3. Press (Deficiency) to bring up deficiency assessment screen	Screen 4.1 brings up deficiency picklist for WBS IU
	4. Enter estimated life without repair	Inspector generated
	5. Enter estimated year "IU" installed	Inspector generated
	6. Tap "Status" title for picklist Cursor select or enter by pen	Picklist is preformatted
	7. Tap "Service" title for picklist Cursor select or enter by pen	Picklist is preformatted
	8. Tap "Importance" title for picklist	Picklist is preformatted
	9. Tap "Access" title for picklist Cursor select or enter by pen	Picklist is preformatted
	10. Enter year "IU" last inspected	Inspector generated
	11. Enter percentage of WBS served by inspection unit	Inspector generated
	12. Enter quantity of inspection unit at location as required	Inspector generated
	13. Press (Continue) to go to Screen 5.0	By pressing (Continue) information is verified; corrections made by crossing through data and entering new information

-
-
-
-
-
-
-
-
-
-

Press to return to Screen 3.0

Press to bring up screen help

Press to bring up screen for entering inspector comments

Press to delete an inspection unit record

Press to scroll up thru inspection units selected

Press to scroll down thru inspection units selected

Press to create, view, or select multiple IUs and locations

Press to repeat or copy inspection unit selection data as a new entry

Press to bring up Additional Data screen and enter boiler plate information

Press to save data entered and go to Screen 3.0 for next selection

By pressing (Escape) information is not verified; and any changes made are lost

Screen 99.1

Screen 99.2

N/A

N/A

N/A

Screen 4.2

WA

Screen 4.3 - Inspector generated

By pressing (RtrnWBS) information is verified; corrections made by crossing through data and entering new information

SURVEY STEP DEFICIENCY ASSESSMENT

Screen 4.1

Deficiency Assessment

Deficiency Group: RACEWAY+FITTINGS NSIP: N/A

Code	Description	Coverage (%)			NSIP
		Light	Mod	Sev	
01	Fitting - Improper, Exposed Conductors, Broken, Missing	10			N/A
02	Installation - Improper Parts, Ground Faulty, Mounts Bad, Poor Ventilation		5		N/A
03	Marking - Nameplate Missing/Illegible	15			N/A
04	Raceway - Inappropriate, Corroded, Damaged	5			N/A


Buttons: Escape, Help, Comment, Clear, Page Up, Page Dn, DetailDef, InfoList, Continue

SCREEN	ACTION	COMMENT
4.1	1. Select deficiency from list	Picklist preformatted
	2. Select degree of severity of deficiency	Inspector developed
	3. Enter percentage of coverage under selected severity	Inspector developed
	4. Indicate whether non-standard inspection/test procedures are required or recommended	Inspector choice, preset at "No"; line through to deselect
	5. Press (Continue) to go to Screen 5.0	By pressing (Continue) information is verified; corrections made by crossing through data and entering new information
	Press to return to Screen 4.0	By pressing (Escape) information is not verified and any changes made are lost
	Press to bring up screen help	Screen 99.1
	Press to bring up screen for entering inspector comments	Screen 99.2
	Press to unselect a deficiency	N/A
	Press to scroll up though data by page	WA
	Press to scroll down through data by page	N/A
	Press to bring up long description of selected deficiency	N/A
	Press to bring up information/directions preloaded for inspector	Screen 99.4

- (Escape)
- (Help)
- (Comment)
- (Clear)
- (Page Up)
- (Page Dn)
- (Detail Def)
- (InfoList)

SURVEY STEP CREATE/REVIEW/SELECT MULTIPLE IU

Screen 4.2



SCREEN	ACTION	COMMENT
4.2	1. Define locations of Multiple IUs by room, floor and/or location description - optional equipment identification number can be added	Inspector developed
	2. Define percentage of Asset or WBS serviced by IU	Inspector developed
	3. Press Continue after selecting Multiple IU location from list and continue to Screen 4.1 to select deficiencies	By pressing Continue information is verified; corrections made by crossing thru data and entering new information or selecting another item
Escape	Press to return to Screen 4.0	By pressing Escape information is not verified and any changes made are lost
RtrnWBS	Press to return to Screen 3.0	N/A
RtrnIU	Press to return to Screen 4.0	N/A
Delete	Press to delete a highlighted entry on screen	N/A
	Press scroll up button	Used to scroll up through information
	Press scroll down button	Used to scroll down through information

SURVEY STEP ADDITIONAL DATA

Screen 4.3

Additional Data

WBS

Loc

IU

Loc

Mfg Id

Model Type

Cap UM

Size UM

Ser # Parent 1

DOE # Parent 2

DWG

Escape

Help

Comment

HotLine

InfoList

Continue

SCREEN	ACTION	COMMENT
4.3	1. Enter boiler plate data about component being inspected	Inspector generated from data on the component, drawing specifications or determined in the field. This data can be used for inventorying inspection units
	2. Press Continue to go to Screen 4.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information
<p>Escape</p> <p>Help</p> <p>Comments</p> <p>Hotline</p> <p>InfoList</p>	<p>Press to return to Screen 4.0</p> <p>Press to bring up screen help</p> <p>Press to bring up screen for entering inspector comments</p> <p>Press for important contacts and telephone numbers</p> <p>Press to bring up information/directions preloaded for inspector</p>	<p>By pressing Escape information is not verified; and any changes made are lost</p> <p>Screen 99.1</p> <p>Screen 99.2</p> <p>Screen 99.3</p> <p>Screen 99.4</p>

SURVEY STEP SUMMARY CONDITION ASSESSMENT

Screen 5.0

SCREEN	ACTION	COMMENT
5.0	1. Tap "Overall Condition" title for picklist Cursor select or select by pen	Picklist preformatted, inspector determined
	2. Tap "Urgency" title for picklist Cursor select or enter by pen	Picklist preformatted, inspector determined
	3. Tap "Purp" title for picklist Cursor select or enter by pen Multiple purposes can be specified	Picklist preformatted, inspector determined
	4. Enter estimated life of IU after repairs in years	Inspector determined
	5. Enter an estimated cost for repairs (optional)	Inspector determined
	6. Enter repair quantity as required	Inspector determined
	7. Press to save data entered and go to Screen 4.0 for next selection	By pressing ReturnIU information is verified, corrections made by crossing through data and entering new information
	8. Press to save data entered and go to Screen 3.0 for next selection	By pressing ReturnWBS information is verified, corrections made by crossing through data and entering new information
Escape	Press to return to Screen 4.0	By pressing Escape information is not verified and any changes made are lost
Help	Press to bring up screen help	Screen 99.1
Comment	Press to bring up screen for entering inspector comments	Screen 99.2
Logout	Press to save all data entered and leave survey	N/A
Clear	Press to clear or delete an entry	N/A
Work Order	Press to bring up work order screen pop-up	Screen 5.1
Spec Cond	Press to bring up special condition screen pop-up	Screen 5.2
Repair Char	Press to bring up special repair characteristics screen pop-up	Screen 5.3


SURVEY STEP WORK ORDER GENERATION

Screen 5.1

SCREEN	ACTION	COMMENT
5.1	1. Enter data to define Work Order number to tag repair to create a job estimate for repairs	Inspector generated as determined by Site Manager prior to survey
	2. Press Continue to go to Screen 5.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information
	3. Press Escape to return to Screen 5.0	By pressing Escape information is not verified; and any changes made are lost

SURVEY STEP SPECIAL CONDITIONS SELECTION


Screen 5.2



SCREEN	ACTION	COMMENT
5.2	1. Press box next to special condition to select	Picklist is preloaded by site. Selections determined by Site Manager prior to survey
	2. Press Continue to go to Screen 5.0 3. Press Escape to return to Screen 5.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information By pressing Escape information is not verified; and any changes made are lost

SURVEY STEP REPAIR CHARACTER DOCUMENTATION


Screen 5.3



S C R E E N	ACTION	COMMENT
5.3	1. Enter repair characteristics for tracking related deficiencies	Inspector generated from input of asset users to document what is deficient, what caused deficiency and any symptoms. Picklist can be preformatted
	2. Press Continue to go to Screen 5.0 3. Press-to return to Screen 5.0	By pressing Continue information is verified; corrections made by crossing through data and entering new information By pressing Escape information is not verified; and any changes made are lost

SURVEY STEP HELP

Screen 99.1



S C R E E N	A C T I O N	C O M M E N T
99.1	N/A	Screen pop-up help information Dynamic help for locations selected Screen data cannot be changed
<p>Escape</p> <p>▲</p> <p>▼</p>	<p>Press to exit Help Screen and return to previous screen</p> <p>Press scroll up button</p> <p>Press scroll down button</p>	<p>N/A</p> <p>Used to scroll up through information</p> <p>Used to scroll down through informatiin</p>


SURVEY STEP COMMENT SCREEN

Screen **99.2**

SCREEN	ACTION	COMMENT
99.2	1. Select a Comment Type Selection	Picklist preformatted
	2. Enter Comment inside comment text field (QWERTY keyboard can be called in to use)	Text field expands as required
	3. Enter a Photo, Sketch, or Note Log tag number	Can be standardized or inspector generated
	4. Press Continue to return to previous screen	By pressing Continue information is verified; corrections made by crossing thru data and entering new information
Escape	press to exit comment screen and return to previous screen	By pressing- information is not verified and any changes made are lost
Delete	press to delete a selected comment	N/A
Backout	press to move backwards through the navigation screen at top	This option allows an inspector to move backwards to enter or change a comment tagged to a previous screen
Reset	press to move forward through the navigation screen at top	This option allows an inspector to move forward after entering a comment on a previous screen to continue the inspection

SURVEY STEP HOTLINE SCREEN


Screen 99.3





S C R E E N	ACTION	COMMENT
99.3	N/A	Screen pop-up for important contacts and telephone numbers Preformatted and adjusted by Site Manager. Screen data cannot be changed by inspector
<p>Escape</p> <p>▲</p> <p>▼</p>	<p>Press to exit Hotline screen and return to previous screen</p> <p>Press scroll up button</p> <p>Press scroll down button</p>	<p>N/A</p> <p>Used to scroll up through information</p> <p>Used to scroll down through information</p>

SURVEY STEP INFO SCREEN

Screen 99.4



SCREEN	ACTION	COMMENT
99.4	1. CAS inspection parameters & schedules as inputted by site manager	Cannot be changed by inspector
Escape  	Press to exit InfoList screen and return to previous screen Press scroll up button Press scroll down button	N/A Used to scroll up through information Used to scroll down through information

DATA COLLECTION METHODS

END OF SUBSECTION

FEDERAL SPECIFICATIONS

**FEDERAL
SPECIFICATION****TITLE**

US Department of Energy
Design Criteria

DOE 6430.1A Dtd 4-6-89

FEDERAL SPECIFICATIONS

END OF SUBSECTION

NATIONAL STANDARDS

AMERICAN SOCIETY FOR TESTING & MATERIALS (ASTM)

ASTM D 877-87	Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using Disk Electrodes
ASTM D 924-65	Test method for A-C Loss Characteristics and Relative Permittivity (Dielectric Constant) of Electrical Insulating Liquids
ASTM D 971-82	Test Method for Interfacial Tension of Oil Against Water by the Ring Method
ASTM D 974-87	Test Method for Acid and Base Number by Color-Indicator Titration
ASTM D 1500-87	Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)
ASTM D 1524-U	Test Method for Visual Examination of Used Electrical Insulating Oils of Petroleum Origin in the Field

NATIONAL STANDARDS

END OF SUBSECTION

INDUSTRY PUBLICATIONS

PUBLICATION**PUBLISHER**

Westinghouse Maintenance Hints

HB 6001 -R

National Fire Protection Assn

National Electrical Code NFPA 70, 1990 Edition
Recommended Practice for Electrical Equipment
Maintenance NFPA 70B, 1990 edition

INDUSTRY PUBLICATIONS

END OF SUBSECTION

OTHERRELATEDREFERENCES

Other Pertinent
Reference Sources
As Applicable

OTHER RELATED REFERENCES

END OF SUBSECTION

APPENDIX A

ABBREVIATIONS

A, Amp	Ampere, Area
A/E	Architect-Engineer
AA	Aluminum Association
AABC	Associated Air Balance Council
AAMA	American Architectural Manufacturers Association
AASHTO	American Association of State Highway and Transportation Officials
ABMA	American Boiler Manufacturers Association
ABS	Acrylonitrile-Butadiene-Styrene
AC	Alternating Current, Air Conditioning
ACFM	Actual Cubic Feet per Minute
ACGIH	American Conference of Governmental Industrial Hygienists
ACI	American Concrete Institute
ACSM	American Congress on Surveying and Mapping
ADF	Asset Determinant Factor
ADJ	Adjustable
ADM	Action Description Memorandum
ADP	Automated Data Processing
AEC	U.S. Atomic Energy Commission
AFM	U.S. Air Force Manual
AFR	U.S. Air Force Regulation
AFWL	U.S. Air Force Weapons
AGA	American Gas Association
AHU	Air Handling Unit
AIA	American Institute of Architects
AISC	American Institute of Steel Construction
AISI	American Iron and Steel Institute
ALARA	As Low as Reasonably Achievable
Allow	Allowance
Amb	Ambient
AMC	U.S. Army Materiel Command
AMCA	Air Movement Contractors Association
AMC-R	Army Materiel Command Regulation
Amp	Ampere
ANS	American Nuclear Society
ANSI	American National Standards Institute
API	American Petroleum Institute
Approx.	Approximately
AR	U.S. Army Regulation
AREA	American Railway Engineering Association
ARI	American Refrigeration Institute
ARMA	Asphalt Roofing Manufacturers Association
ASBC	American Standard Building Code
ASCE	American Society of Civil Engineers
ASHRAE	American Society of Heating, Refrigeration & Air-Conditioning Engineers
ASME	American Society of Mechanical Engineers
ASTM	American Society for Testing and Materials
ATM	Atmosphere
AVG	Average
AVLIS	Atomic Vapor Laser Isotope Separation
AWG	American Wire Gauge
AWS	American Welding Society

APPENDIX A

AWWA	American Water Works Association
BAT	Best Available Technology
BATEA	Best Available Technology Economically Achievable
BCPCT	Best Conventional Pollutant Control Technology
BESEP	Base Electronic System Engineering Plan
BHP	Brake Horsepower
BI	Black Iron
BIA	Brick Institute of America
BIL	Basic Impulse Insulation Level
BKRS	Breakers
BLDG	Building
BOCA	Building Official Code Association
BOD	Biochemical Oxygen Demand
	Building Research Advisory Board (now Building Research Board)
BRB	Building Research Board
BRG	Bearing
BTU	British Thermal Unit
°C	Degrees Centigrade (Celsius)
C&GS	U.S. Coast and Geodetic Survey (now National Geodetic Survey)
C M	Clean Air Act
CAMS	Continuous Air Monitoring System
CAS	Condition Assessment Survey
c c w	Closed Circuit Television
CDR	Conceptual Design Report
CEM	Continuous Emissions Monitoring
CERC	U.S. Army Coastal Engineering Research Center
CERCLA	Comprehensive Environmental Response, Compensation, & Liability Act
CF	Cubic Feet
CFC	Chlorofluorocarbon
CFM	Cubic Feet per Minute
CFR	Code of Federal Regulations
CGA	Compressed Gas Association
CHW	Chilled Water
CI	Cast Iron
CIP	Cast-in-Place, Cast Iron Pipe
CISCA	Ceiling and Interior Systems Contractors Association
CISPI	Cast Iron Soil Pipe Institute
CMP	Corrugated Metal Pipe
CO₂	Carbon Dioxide
COE	U.S. Army Corps of Engineers
COMPR	Compressor
COP	Coefficient of Performance
CP	Concrete Pipe
CPLG	Coupling
CPSC	Consumer Product Safety Commission
CPVC	Chlorinated Polyvinyl Chloride
CRI	Carpet and Rug Institute
CRT	Cathode Ray Tube
C_v	Flow coefficient
c w	Cold Water
CWA	Clean Water Act
CYL	Cylinder
DAC	Derived Air Concentration

 APPENDIX A

DARCOM	U.S. Army Development, Acquisition and Readiness Command
DB	Dry Bulb, Decibel
DBA	Design Basis Accident
DBE	Design Basis Earthquake
DBF	Design Basis Fire
DBFL	Design Basis Flood
DBG	Distance Between Guides
DBT	Design Basis Tornado
DBW	Design Basis Wind
DC	Direct Current
DCG	Derived Concentration Guide
D CPA	Defense Civil Preparedness Agency
DL	Dead Load
DM	NAVFAC Design Manual
DOD	U.S. Department of Defense
DOE	U.S. Department of Energy
DOP	Diocetylphthalate
DOT	U.S. Department of Transportation
DP	Differential Pressure
DP-1	Assistant Secretary for Defense Programs
DP-34	Director of Safeguards and Security Agreement
DPDT	Double-Pole Double-Throw
DSC	Differential Scanning Calorimetry
DTA	Differential Thermal Analysis
DWT	Double Wrap Traction
DWV	Drain, Waste & Vent
DX	Direct Expansion
DYN	Dyne
EA	Each
ECC	Emergency Control Center
ECP	Entry Control Point
EMCS	Energy Monitoring and Control System
ECS	Emergency Control Station
EDE	Effective Dose Equivalent
EED	Electroexplosive Device
EIA	Electronics Industries Association
EIFS	Exterior Insulation and Finish System
EIMA	Exterior Insulation Manufacturers Association
EIS	Environmental Impact Statement
Elev	Elevator
EM	U.S. Army Engineering Manual
EMS	Energy Management System
EMT	Electrical Metallic Tubing
EO	Executive Order
EOC	Emergency Operating Center
EPA	U.S. Environmental Protection Agency
EPS	Emergency Power System
Equip	Equipment
ERDA	Energy Research and Development Administration (precursor to DOE)
ESF	Engineered Safety Feature
Est	Estimated
Ext	Exterior
°F	Degrees Fahrenheit

 APPENDIX A

F M	Federal Aviation Administration
FAI	Fauske and Associates, Inc.
FAR	Federal Acquisition Regulation
FCC	Federal Construction Council
FEMA	Federal Emergency Management Agency
FGA	Flat Glass Marketing Association
FGCC	Federal Geodetic Control Committee
FGD	Flue Gas Desulphurization
FHWA	Federal Highway Administration
FHDA	Fir and Hemlock Door Association
Fig	Figure
FIPS	Federal information Processing Standards
Flxt	Fixture
Flr	Floor
FM	Factory Mutual
Fndtn	Foundation
FPM	Feet Per Minute
FPT	Female Pipe Thread
FR	Federal Register
fr	Frame
FS	Federal Specifications
FSAR	Final Safety Analysis Report
Ft	Foot, feet
Ft/lb	Foot-Pound
FWPCA	Federal Water Pollution Control Act
fy	Yield strength
G	Gauss
g	Gram
GA	Gypsum Association
ga	Gauge
Gal	Gallon
Galv	Galvanized
GDC	General Design Criteria, DOE 6430.1A
GPD	Gallon Per Day
GPH	Gallon Per Hour
GPM	Gallons Per Minute
GSA	General Services Administration
HE	High Explosives
HE-Pu	High Explosives-Plutonium
HF	High Frequency, Hydrogen Fluoride
HI	Hydraulic Institute
HID	High Intensity Discharge
HLW	High-Level Waste
HOA	Hand-Off-Automatic
HP	Horsepower
HR	Hour
Htg	Heating
Htr	Heater
HTW	High Temperature Water
HVAC	Heating, Ventilating, and Air-Conditioning
Hvy	Heavy
HW	Hot Water
Hyd	Hydraulic

APPENDIX A

HX	Heat Exchanger
HZ	Hertz, frequency
IAPMO	International Association of Plumbing and Mechanical Officials
IAS	Intrusion Alarm System
ICBO	International Conference of Building Officials
ICRP	International Commission on Radiological Protection
ID	Inside Diameter
IDA	Intrusion Detection and Assessment
IDS	Intrusion Detection System
IEEE	Institute of Electrical and Electronic Engineers
IES	Illumination Engineering Society
IFM	Irradiated Fissile Material
IFMSF	Irradiated Fissile Material Storage Facility
IHE	Insensitive High Explosives
IMC	Intermediate Metal Conduit
In	Inch
Incl	Installed, Including
Inst	Installation
Insul	Insulation
IP	Iron Pipe
IPS	Iron Pipe Size
IPT	Iron Pipe Threaded
ISDSI	Insulated Steel Door Systems Institute
IU	Inspection Unit
IUEC	International Union of Elevator Contractors
J	Joule
°K	Degrees Kelvin
K	Subgrade modulus, Thousand, heavy wall copper tubing
Kg	Kilogram
kHz	Kilohertz
Klp	1000 pounds
Km	Kilometer
kPa	kilo Pascal
KV	Kilovolt
kVA	kiloVolt Ampere
kW	kilowatt
kWh	kilowatt hour
lb	Pound
lb/hr	Pounds Per Hour
lbf	Pounds Per Foot
LCC	Life-Cycle Cost
LCD	Liquid Crystal Display
LF	Linear Feet
LL	Live load psf - pounds per square foot
LLW	Low-Level Waste
LP	Liquid Petroleum, Low Pressure
LPG	Liquified Petroleum Gas
Lt	Light
LV	Low Voltage
MA	Management and Administration (U.S. DOE)
mA	milliAmpre
MAA	Material Access Area
Mach	Machine

APPENDIX A

Maint	Maintenance
MAWP	Maximum Allowable Working Pressure
MBA	Material Balance Area
MBH	Thousand BTUs per Hour
MBMA	Metal Building Manufacturers' Association
MC&A	Material Control and Accountability
MCF	Thousand Cubic Feet
Mfg	Manufacturing
Mfr	Manufacturer
MCC	Motor Control Center
mg	Milligram
mg/l	Milligrams per liter
MGPH	Thousand Gallons Per Hour
Mhz	Megahertz
MI	Miles, total level route
MIL-HDBK	U.S. DOD military handbook
MIN	Minute
mIn	Minimum
MIsc	Miscellaneous
ml	Millileter
ML/SFA	Metal Lath/Steel Framing Association
mm	Millimeter
M&O	Management and Operations
MPH	Miles Per Hour
MPT	Male Pipe Thread
mr/h	milli roentgen/hour
mrad/h	milli roentgen, absorbed dose/hour
mrem	milli roentgen equivalent man
MSSA	Master Safeguards and Security Agreement
Mtng	Mounting
MVA	Million-Volt-Amps
N₂	Nitrogen
N/A	Not Applicable
NAAMM	National Association of Architectural Metal Manufacturers
NACE	National Association of Corrosion Engineers
NAD	North American Datum
NAEC	National Association of Elevator Contractors
NAESA	National Association of Elevator Safety Authorities
NAPHCC	National Association of Plumbing-Heating-Cooling Contractors
NASA	National Aeronautics and Space Administration
NAVFAC	Naval Facilities Engineering Command
NBC	National Building Code
NBS	National Bureau of Standards
NC	Noise Criteria
NCEL	Naval Civil Engineering Laboratory (references listed under NAVFAC)
NCMA	National Concrete Masonry Association
NDA	Non-Destructive Assay
NEC	National Electrical Code
NEII	National Elevator Industry Incorporated
NEMA	National Electrical Manufacturers Association
NEMI	National Elevator Manufacturing Industry, Inc. (now NEII)
NEPA	National Environmental Policy Act
NFGS	Naval Facilities Guide Specification (references listed under NAVFAC)

APPENDIX A

NFPA	National Fire Protection Association
NGS	National Geodetic Survey (formerly U.S.Coast and Geodetic Survey)
NGVD	National Geodetic Vertical Datum
NHPA	National Historic Preservation Act
NIJ	National Institute of Justice
NIST	National Institute of Standards and Technology (see NBS)
N O M	National Oceanic and Atmospheric Administration
NO	Normally Open
NO_x	Oxides of Nitrogen
NPDES	National Pollutant Discharge Elimination System
NPDWS	National Primary Drinking Water Standards
NPSH	Net Positive Suction Head
NPT	National Pipe Thread
NRC	Nuclear Regulatory Commission
NRCA	National Roofing Contractors Association
NRTA	Near-Real-Time Accountancy
NRTL	Nationally Recognized Testing Laboratory
NSA	National Security Agency
NSPC	National Standard Plumbing Code
NSPS	New Source Performance Standards
NTIA	National Telecommunications and Information Administration
NTMA	National Terrazzo and Mosaic Association
NUREG	Nuclear Regulatory Commission-produced reference document
NWWDA	National Wood Window and Door Association
OA	Outside Air
OBA	Operating Basis Accident
OBE	Operating Basis Earthquake
o c	On Center
o c s	Office of Computer Services (U.S. DOE)
OD	Outside Dimension
ODH	Oxygen Deficiency Hazards
O & M	Operations and Maintenance
OMB	Office of Management and Budget
OP AMP	Operational Amplifier
Oper	Operator
OPFM	Office of Project and Facilities Management (US. DOE)
OS&Y	Outside Screw and Yoke
OSHA	Occupational Safety and Health Administration
OSR	Operational Safety Requirement
o s s	Office of Safeguards and Security (U.S. DOE)
OSTI	Office of Scientific and Technical Information (U.S. DOE)
OWG	Oil, Water, or Gas
Oz	Ounce
P	Minimum reinforcing ratio
PA	Protected area
PB	Polybutylene
PCB	Polychlorinated biphenyls
PCI	Prestressed Concrete Institute
PEL	Permissible Exposure Limit
PF	Protection Factor
Ph	Phase
PI	Point of Intersection, Proportional-plus Integral
PIV	Post Indicator Valve

APPENDIX A

PLF	Pounds per Linear Foot
Pkg	Package
PMFL	Probable Maximum Flood
POL	Petroleum, Oil, and Lubricants
POTW	Publicly-Owned Treatment Works
PPHF	Plutonium Processing and Handling Facility
PPM	Parts Per Million
PRV	Pressure Regulating Valve
PSAR	Preliminary Safety Analysis Report
PSF	Plutonium Storage Facility, Pound-force per square foot
PSI	Pound-force per square inch
PSIA	Pounds per square inch absolute
PSIG	Pound-force per square inch gauge
PTI	Post Tensioning Institute
Pu	Plutonium
PUBN	Publication
PURPA	Public Utility Regulatory Policy Act
PVC	Polyvinyl Chloride
QA	Quality Assurance
Qty	Quantity
R	Resistance
R12, R22	Refrigerant (12,22, etc.)
°R	Degrees Rankine
RCP	Reinforced Concrete Pipe
RCRA	Resource Conservation and Recovery Act
RDF	Refuse-Derived Fuel
REM	Roentgen Equivalent Man
Reqd	Required
RFCI	Resilient Floor Covering Institute
RG	Regulatory Guide
RLWF	Radioactive Liquid Waste Facility
RPFM	Real Property and Facilities Management (U.S. DOE)
RPIS	Real Property Inventory System (U.S. DOE)
RPM	Revolutions Per Minute
RSWF	Radioactive Solid Waste Facility
RTD	Resistance Temperature Detector
S&S	Safeguards and Security
SAR	Safety Analysis Report
SARS	Safety Analysis and Review System
SAS	Secondary Alarm Station
SC	Safety Class
SCFM	Standard Cubic Feet per Minute
SCR	Silicon Control Rectifier
SCS	U.S. Department of Agriculture, Soil Conservation Service
SDI	Steel Deck Institute, Steel Door Institute
SDWA	Safe Drinking Water Act
SF	Safety Factor
SGFT	Structural Glazed Facing Tile
SISL	Special Isotope Separation Laser
SJI	Steel Joist Institute
SMA	Screen Manufacturers Association
SMACNA	Sheet Metal and Air Conditioning Contractors National Association
SNG	Supplementary Natural Gas

APPENDIX A

SNM	Special Nuclear Materials
SO₂	Sulfur dioxide
SOP	Standard Operating Procedure
SP	Special Publication (of the American Concrete Association)
SPCC	Spill Prevention Control and Countermeasure
SPDT	Single-Pole Double-Throw
SPRI	Single Ply Roofing Institute
SPST	Single-Pole Single-Throw
SSCO	Single Speed Center-Opening
SQFT	Square foot
SSE	Safe Shutdown Earthquake
SSFI	Scaffolding, Shoring, and Framing Institute
SSSP	Site Safeguards and Security Plan
SSPC	Steel Structures Painting Council.
SSSS	Single Speed Side-Sliding
STC	Sound Transmission Classification
Std	Standard
STP	Standard Temperature and Pressure
Sys	System
SWI	Steel Window Institute
SWP	Safe Working Pressure
SWT	Single Wrap Traction
T	Ton, Temperature
TCA	Tile Council of America, Inc.
TCDD	Tetrachlorodibenzo-p-dioxin
TDS	Total Dissolved Solids
TEC	Total Estimated Cost
TID	Tamper Indicating Device
TIMA	Thermal Insulation Manufacturers Association
TLV	Threshold Limit Value
TM	U.S. Army technical manual
tot	Total
TR	DOD technical report
Transf	Transformer
TRU	Transuranic
TSCA	Toxic Substances Control Act
TSD	Treatment, Storage and Disposal
Tstat	Thermostat
TYP	Typical
N	Television
U value	Overall heat transfer coefficient value
UBC	Uniform Building Code
UCRF	Uranium Conversion and Recovery Facility
UEF	Uranium Enrichment Facility
UEU	Unirradiated Enriched Uranium
UEUSF	Unirradiated Enriched Uranium Storage Facility
UF₄	Uranium tetrafluoride
UF₆	Uranium hexafluoride
UFAS	Uniform Federal Accessibility Standards
UHF	Ultra High Frequency
UL	Underwriters Laboratory
UMC	Uniform Mechanical Code
UO₂	Uranium dioxide

 APPENDIX A

UO₃	Uranium trioxide
" P A	Unit Process Area
UPC	Uniform Plumbing Code
UPHF	Uranium Processing and Handling Facility
UPS	Uninterruptible Power Supply
" RF	Uranium Recovery Facility
USC	U.S. Code
USCE	U.S. Army Corps of Engineers
USGS	U.S. Geological Survey
USPHS	U.S. Public Health Service
USPS	U.S. Postal Service
V	Volt
VA	Volt-Ampere
Vac	Vacuum
VAV	Variable Air Volume
VCT	Vinyl Composition Floor Tile
Vel	Velocity
Vent	Ventilating
VHF	Very High Frequency
Vol	Volume
W	Watt
WB	Wet Bulb
WBT	Wet Bulb Temperature
WC	Water Column
WG	Water Gauge
WB	Wet Bulb
WBS	Work Breakdown Structure
WPCF	Water Pollution Control Federation
WRC	Water Resources Council
Yd	Yard
Yr	Year

APPENDIX A

SYMBOLS

°R	Degrees Rankine
°K	Degrees Kelvin
°F	Degrees Fahrenheit
°C	Degrees Centigrade (Celsius)
>	Greater Than
<	Less Than
≥	Greater Than or Equal To
≤	Less Than or Equal To
%	Percent
#	Pound, Number
α, A	Alpha
β, B	Beta
θ, Θ	Theta
λ, Λ	Lambda
μ, M	Mu
π, Π	Pi
σ, Σ	Sigma
ω, Ω	Omega

APPENDIX A

END OF SUBSECTION

APPENDIX B

GLOSSARY

Accessible:	Capable of being removed or exposed without damaging the building structure or finish, or not permanently closed in by the structure or finish of the building (as applied to wiring methods).
Accessible:	Admitting close approach; not guarded by locked doors, elevation or other effective means (as applied to equipment).
Ancillary Equipment:	Selected equipment such as but not limited to meters, instrument transformers and surge arrestors. Specifically, items of equipment installed or in place only as augmentation to another device.
Branch Circuit:	The circuit conductors between the final overcurrent device and the outlet(s).
Circuit Breaker:	A device designed to open and close a circuit by nonautomatic means and to open the circuit automatically on a predetermined overcurrent without damage to itself when properly applied within its rating.
Device:	A unit of an electrical system which is intended to carry but not utilize electric energy.
Enclosure:	The case or housing of apparatus, or the fence, or walls which will prevent persons from accidentally contacting energized parts.
Equipment:	A general term including material, fittings, devices, appliances, fixtures, apparatus, and the like used as a part of, or in connection with, an electrical installation.
Feeder:	All circuit conductors between the service equipment or the source of a separately derived system and the final branch-circuit overcurrent device.
Fitting:	An accessory such as a locknut, bushing, or other part of a wiring system that is intended primarily to perform a mechanical rather than an electrical function.
Overcurrent:	Any current in excess of the rated current of equipment or the ampacity of a conductor. It may result from overload, short circuit, or ground fault.
Overload:	Operation of equipment in excess of normal, full-load rating, or of a conductor in excess of rated ampacity which, when it persists for a sufficient length of time, would cause damage or dangerous overheating. A fault, such as a short circuit or ground fault is not an overload.
Panelboard:	A single panel or group of panel units designed for assembly in the form of a single panel; including bases, automatic overcurrent devices, and with or without switched for the control of light, heat, or power circuits; designed to be placed in a cabinet or cutout box placed in or against a wall of partition and accessible only from the front.

APPENDIX B

Raceway:	An enclosed channel designed expressly for holding wires, cable, or busbars, with additional functions as permitted. Raceways may be of metal or insulating material, and the term includes rigid metal conduit, rigid nonmetallic conduit, intermediate metal conduit, liquid tight flexible conduit, flexible metallic conduit, electrical nonmetallic conduit, electrical metallic conduit, underfloor raceways, cellular concrete floor raceways, cellular metal floor raceways, surface raceways, wireways, and busways.
Service Drop:	The overhead conductors that extend from the last pole or other aerial support to and including the splices, if any, connecting to the service-entrance conductors at the building or other structure.
Service Entrance Conductors:	The service conductors between the terminals of the service equipment and a point usually outside the building, clear of building walls, where joined by tap or splice to the service drop or the service conductors between the terminals of the service equipment and the point of connection to the service lateral. The service conductors may be individual insulated conductors or in the form of a cable. The insulation will be appropriate to the environmental application.
Service Entrance Equipment:	The necessary equipment, usually consisting of a circuit breaker or switch and fuses, and their accessories, located near the point of entrance of supply conductors to a building or other structure, or an otherwise defined area, and intended to constitute the main control and means of cutoff of the supply.
Service Lateral:	The underground service conductors between the street main, including any risers at a pole or other structure or from transformers, and the first point of connection to the service-entrance conductors in a terminal box or meter or other enclosure with adequate space, inside or outside the building wall. Where there is no terminal box, meter, or other enclosure with adequate space, the point of connection will be considered to be the point of entrance of the service conductors into the building.
Switchboard:	A large single panel, frame, or assembly of panels on which are mounted, on the face or back or both, switches, overcurrent and other protective devices, buses, and usually instruments. Switchboards are generally accessible from the rear as well as from the front and are not intended to be installed in cabinets.
Utilization Equipment:	Equipment which utilizes electric energy for mechanical, chemical, heating, lighting, or similar purposes.

END OF SUBSECTION

APPENDIX C

TECHNICAL BULLETINS/UPDATES/ADVISORIES

Index of Bulletins/Advisories
followed by Bulletins/Advisories
as developed

APPENDIX C

TECHNICAL ADVISORY**T0501- 1**

DATE: 10/91
SYSTEM: Roofing (CSI 07000)
ASSEMBLY: Built-Up (CSI 07510)
SUBJECT: Roof Top Lighting and Insect Damage

“In March, 1988 a professional roofing magazine article described a bizarre but apparently avoidable, phenomenon. In about a dozen documented cases ranging from Washington State to Florida, beetles have bored through roof membranes, causing leaks. It was determined that the beetles are attracted to lights (especially mercury vapor) mounted on, over, or near roof surfaces, including nearby billboard lighting. Falling to the roof, they burrow into the roof substrate, seeking protection from the sun during the day. The types of roof membrane affected were asphaltic BUR, modified bitumen, and single-ply roofing. Evidently, no instance has yet been found among coal tar BUR. It is advisable to exercise care in the selection of roof membranes where billboards may exist adjacent to a planned roof installation, or when rooftop lighting is required. The roof specifier should discuss the types of luminaire to be used with project electrical engineers before mercury vapor fixtures are specified.”

Source: Roofing Design Criteria Options. **R.D. Herbert II**

EXAMPLE: TECHNICAL ADVISORY BULLETIN

END OF SUBSECTION

APPENDIX D

REVISIONS SUMMARY

AT A GLANCE SUMMARY OF ALL
REVISIONS UP TO LATEST REVISION DATE

APPENDIX D

END OF SUBSECTION