

**U. S. Department of Energy
Facilities Information Management System
Request for Change
Change Request #: 17-20 rev 1**

Requestor Name:	Cindy Hunt	Date:	6/20/2017	Affiliation:	
Email Address:	cindy.hunt@hq.doe.gov	Phone No:	202-586-4539	DOE	X
Program Office:	Office of Asset Management (MA-50)			Contractor	
Proposed Change:	<p>Revise the definition for <i>Safety Inspection Date</i>.</p> <p><u>Proposed Definition</u></p> <p>The date of the most recent safety inspection conducted in accordance with designated inspection standards.</p> <p>a) Required reporting - inspection standard and frequency:</p> <ul style="list-style-type: none"> • 1468-Public Access Bridge (Trains) and 1469-Controlled Access Bridge (Trains), with a Status of Operating, Standby and Outgranted <ul style="list-style-type: none"> – 49 CFR Part 237 – one inspection per calendar year, with not more than 540 days between successive inspections • 1768-Public Access Bridge (Vehicular), regardless of operational Status <ul style="list-style-type: none"> – 23 CFR 650 – regular intervals not to exceed twenty-four (24) months – Public access vehicle bridges with a Structure Length of more than 20 feet (6.1 meter) will be included in the National Bridge Inventory (NBI) regardless of operational status. <p>For required inspections, the <i>Safety Inspection Date</i> field must be changed to represent the most current inspection date within thirty (30) days of inspection completion.</p> <p>b) Optional reporting - inspection standard and frequency:</p> <ul style="list-style-type: none"> • 1168-Public Access Bridge (Walking) and 1169-Controlled Access Bridge (Walking), including elevated walkways <ul style="list-style-type: none"> – a customized inspection plan based on American Association of State Highway and Transportation Officials (AASHTO) MBE-1, <i>Manual for Bridge Evaluation</i> – regular intervals not to exceed twenty-four (24) months • 1769-Controlled Access Bridge (Vehicular) <ul style="list-style-type: none"> – 23 CFR 650 				

**U. S. Department of Energy
Facilities Information Management System
Request for Change
Change Request #: 17-20 rev 1**

	<ul style="list-style-type: none"> – regular intervals not to exceed twenty-four (24) months • 2629-Culvert <ul style="list-style-type: none"> – FHWA-IP-86-2, Culvert Inspection Manual – regular intervals not to exceed twenty-four (24) months <p>For optional reporting, record the <i>Safety Inspection Date</i> <u>only</u> if inspection was in compliance with designated standard. Leave the date blank when designated inspection standards are not used.</p> <p>POC for Safety Inspection Policy: Cindy Hunt, 202-586-4539, Cindy.Hunt@hq.doe.gov</p>
Justification:	<p>Revisions consistent with current policy provided in OECM memo Requirements for Bridge Inspections dated September 14, 2009.</p> <p>Ensures reporting consistency.</p>
Please Do Not Type Below This Line	
FAC Remarks:	<p>06/14/2017 – FAC is reviewing. Currently on Hold.</p> <p>08/17/2017 – FAC conducted a follow up review. No issues. FAC Recommended.</p>
OAM Remarks:	
FDDC Remarks:	<p>10/23/2017 – FDDC Approved</p>
Implemented:	<p>11/21/2017 – Implemented into FIMS v3.3</p>